

ADDENDUM 01

ALL GROUNDWATER MONITORING PROJECTS

June 21, 2024

This Addendum, effective immediately, is in regard to the Groundwater Monitoring Projects that the District is currently accepting bids for. Section 1 of this addendum addresses general questions that have been asked by potential bidders and the respective answers. Section 2 of this addendum addresses site-specific questions and answers.

Section 1: General Q&A

Q: What does the basic well construction consist of?

A: Our wells are typically 2-inch diameter PVC stick ups with a protective aluminum casing.

Q: What is the screen interval for the wells?

A: The screen intervals and well depths will be posted in a separate document.

Q: Will the District allow for an equivalent SM 2540C analytical method to the EPA method for Total Dissolved Solids (TDS)?

A: Yes.

Q: If bidding on all three projects, is it acceptable to send three RFP submittals in individual sealed envelopes in one sealed package?

A: Yes, but note on the exterior of the package that there are three individual RFP submittals inside.

Q: What price is the District currently paying for these projects?

A:

Contract Region	2021-24 Price Per Event
Nassau/Duval/St. Johns/Flagler	\$4,150.00
Volusia/Brevard/Indian River	\$7,250.00
St. Lucie/Martin/Palm Beach	\$4,500.00

Section 2: Site-Specific Q&A

Q: Can you please advise on the depths to water for the wells listed below?

1. BV-2C – MW 8 (79 ft total depth)
2. DU-2 – MW-4 (100 ft), MW-5 (95 ft), MW-6 (100 ft)

A: The depth to water for these wells can be assumed to be 8-12 ft.