



ADDENDUM NO. 3

FLORIDA INLAND NAVIGATION DISTRICT DREDGED MATERIAL MANAGEMENT AREA DU-9 EXPANSION ST. JOHNS COUNTY, FLORIDA

SUMMARY OF QUESTIONS AND RESPONSES

1. **QUESTION:** How does the discharge in the expanded area to the existing discharge Or will you add a new discharge in the future.

RESPONSE: The existing discharge will be used for all future dredging operations. FIND will either (1) have the dredging contractor cut a section into the existing DMMA southern wall or (2) remove/offload the previously placed dredged material and the existing DMMA southern wall prior to use.