



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Keith Langlotz
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

5/24/2021

Phone: (716) 626-8860

Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/11/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012104884. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104884
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: **2021 Lead in Water Testing**

Analytical Results

Client Sample Description CP-190
 Room 132 Classroom Sink
Collected: 5/1/2021 7:14:00 AM
Lab ID: 012104884-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.63	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:00

Client Sample Description CP-192
 Room 133 Classroom Sink
Collected: 5/1/2021
Lab ID: 012104884-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.90	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:04

Client Sample Description CP-194
 Room 134 Classroom Sink
Collected: 5/1/2021 7:17:00 AM
Lab ID: 012104884-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.96	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:06

Client Sample Description CP-196
 Room 135 Classroom Sink
Collected: 5/1/2021 7:16:00 AM
Lab ID: 012104884-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.08	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:07

Client Sample Description CP-198
 Room 136 Classroom Sink
Collected: 5/1/2021 7:18:00 AM
Lab ID: 012104884-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.37	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:08

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	012104884
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-200
Room 136 Classroom Sink
Collected: 5/1/2021 7:32:00 AM
Lab ID: 012104884-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.6	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:12

Client Sample Description CP-201
Room 138 Classroom Sink
Collected: 5/1/2021 7:12:00 AM
Lab ID: 012104884-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.53	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:13

Client Sample Description CP-202
Room 139 Classroom Sink
Collected: 5/1/2021 7:09:00 AM
Lab ID: 012104884-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.55	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:15

Client Sample Description CP-203
Girls Bathroom Main Hallway Sink #1
Collected: 5/1/2021 7:20:00 AM
Lab ID: 012104884-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.73	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:16

Client Sample Description CP-204
Girls Bathroom Main Hallway Sink #2
Collected: 5/1/2021
Lab ID: 012104884-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.67	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:17

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104884
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-205
 Girls Bathroom Main Hallway Sink #3
Collected: 5/1/2021 **Lab ID:** 012104884-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.75	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:19

Client Sample Description CP-206
 Girls Bathroom Main Hallway Sink #4
Collected: 5/1/2021 **Lab ID:** 012104884-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.13	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:23

Client Sample Description CP-207
 Boys Bathroom Main Hallway Sink #1
Collected: 5/1/2021 7:22:00 AM **Lab ID:** 012104884-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.40	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:24

Client Sample Description CP-208
 Boys Bathroom Main Hallway Sink #2
Collected: 5/1/2021 7:22:00 AM **Lab ID:** 012104884-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.96	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:28

Client Sample Description CP-209
 Boys Bathroom Main Hallway Sink #3
Collected: 5/1/2021 7:22:00 AM **Lab ID:** 012104884-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.85	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104884
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-210 Boys Bathroom Main Hallway Sink #4 **Collected:** 5/1/2021 7:23:00 AM **Lab ID:** 012104884-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.23	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:30

Client Sample Description CP-211 Handicapped Bathroom by Kitchen Sink **Collected:** 5/1/2021 7:25:00 AM **Lab ID:** 012104884-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:32

Client Sample Description CP-212 Kitchen Bathroom Sink **Collected:** 5/1/2021 7:25:00 AM **Lab ID:** 012104884-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	35.9	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:33

Client Sample Description CP-213 Kitchen Sink #1 **Collected:** 5/1/2021 **Lab ID:** 012104884-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.11	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:34

Client Sample Description CP-214 Kitchen Sink #2 **Collected:** 5/1/2021 7:29:00 AM **Lab ID:** 012104884-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.81	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:36

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104884
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: **2021 Lead in Water Testing**

Analytical Results

Client Sample Description CP-215 Kitchen Sink #3 **Collected:** 5/1/2021 7:29:00 AM **Lab ID:** 012104884-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.3	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:35

Client Sample Description CP-216 Boiler Room Source **Collected:** 5/1/2021 7:33:00 AM **Lab ID:** 012104884-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:36

Client Sample Description CP-217 Custodial Bathroom Sink **Collected:** 5/1/2021 7:33:00 AM **Lab ID:** 012104884-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.03	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:37

Client Sample Description CP-218 Faculty Mail Room Sink **Collected:** 5/1/2021 6:49:00 AM **Lab ID:** 012104884-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.4	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:39

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results