



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Keith Langlotz
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

5/24/2021

Phone: (716) 626-8860
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/11/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012104987. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-100
Custodial Office Bathroom Sink
Collected: 5/1/2021 5:58:00 AM
Lab ID: 012104987-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.07	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:09

Client Sample Description FE-102
Room 38 Sink
Collected: 5/1/2021 6:03:00 AM
Lab ID: 012104987-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.76	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:13

Client Sample Description FE-103
Room 38 Bathroom Sink #1
Collected: 5/1/2021 6:04:00 AM
Lab ID: 012104987-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	98.1 D	5.00 µg/L	5/20/2021 VD	5/21/2021 VD 08:30

Client Sample Description FE-105
Room 47 Kitchen Sink
Collected: 5/1/2021 6:05:00 AM
Lab ID: 012104987-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.03	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:15

Client Sample Description FE-106
Boys Lav by Room 47 Sink #1
Collected: 5/1/2021 6:09:00 AM
Lab ID: 012104987-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.11	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:17

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104987
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-107
 Boys Lav by Room 47 Sink #2
Collected: 5/1/2021 6:10:00 AM
Lab ID: 012104987-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:21

Client Sample Description FE-108
 Boys Lav by Room 47 Sink #3
Collected: 5/1/2021 6:11:00 AM
Lab ID: 012104987-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:22

Client Sample Description FE-109
 Girls Lav by Room 36 Sink #1
Collected: 5/1/2021 6:12:00 AM
Lab ID: 012104987-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:23

Client Sample Description FE-110
 Girls Lav by Room 36 Sink #2
Collected: 5/1/2021 6:13:00 AM
Lab ID: 012104987-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:25

Client Sample Description FE-111
 Girls Lav by Room 36 Sink #3
Collected: 5/1/2021 6:13:00 AM
Lab ID: 012104987-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-112
 Girls Lav by Room 36 Sink #4
Collected: 5/1/2021 6:13:00 AM
Lab ID: 012104987-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:27

Client Sample Description FE-113
 Room 36 Classroom Sink
Collected: 5/1/2021 6:15:00 AM
Lab ID: 012104987-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.8	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:31

Client Sample Description FE-115
 Room 45 Classroom Sink
Collected: 5/1/2021 6:16:00 AM
Lab ID: 012104987-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.54	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:32

Client Sample Description FE-117
 Room 34 Classroom Sink
Collected: 5/1/2021 6:17:00 AM
Lab ID: 012104987-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.08	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:36

Client Sample Description FE-119
 Room 43 Classroom Sink
Collected: 5/1/2021 6:18:00 AM
Lab ID: 012104987-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.94	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:38

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-121
 Room 32 Classroom Sink
Collected: 5/1/2021 6:19:00 AM
Lab ID: 012104987-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.54	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:39

Client Sample Description FE-123
 Room 41 Classroom Sink
Collected: 5/1/2021 6:21:00 AM
Lab ID: 012104987-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.89	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:40

Client Sample Description FE-125
 Room 39 Classroom Sink
Collected: 5/1/2021 6:22:00 AM
Lab ID: 012104987-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.3	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:42

Client Sample Description FE-127
 Room 30 Classroom Sink
Collected: 5/1/2021 6:23:00 AM
Lab ID: 012104987-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.25	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:43

Client Sample Description FE-129
 Room 37 Classroom Sink
Collected: 5/1/2021 6:24:00 AM
Lab ID: 012104987-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.36	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:44

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-131
Room 28 Classroom Sink
Collected: 5/1/2021 6:26:00 AM
Lab ID: 012104987-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:52

Client Sample Description FE-133
Room 28 Bathroom Sink
Collected: 5/1/2021 6:27:00 AM
Lab ID: 012104987-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:56

Client Sample Description FE-134
Room 26 Classroom Sink
Collected: 5/1/2021 6:29:00 AM
Lab ID: 012104987-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.27	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:57

Client Sample Description FE-136
Room 35 Classroom Sink
Collected: 5/1/2021 6:31:00 AM
Lab ID: 012104987-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.10	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:59

Client Sample Description FE-138
Room 33 Classroom Sink
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012104987-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.98	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:00

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104987
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-140
 Room 24 Classroom Sink
Collected: 5/1/2021 6:33:00 AM
Lab ID: 012104987-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:01

Client Sample Description FE-142
 Room 22 Classroom Sink
Collected: 5/1/2021 6:34:00 AM
Lab ID: 012104987-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.68	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:02

Client Sample Description FE-144
 Room 31 Classroom Sink
Collected: 5/1/2021 6:35:00 AM
Lab ID: 012104987-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:04

Client Sample Description FE-146
 Room 20 Classroom Sink #1
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012104987-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.89	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:08

Client Sample Description FE-147
 Room 20 Classroom Sink #2
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012104987-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.77	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:09

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-148
Room 20 Classroom Sink #3
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012104987-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	20.5	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:10

Client Sample Description FE-149
Room 29 Classroom Sink
Collected: 5/1/2021 6:38:00 AM
Lab ID: 012104987-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.49	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:14

Client Sample Description FE-150
Room 27 Classroom Sink
Collected: 5/1/2021 6:40:00 AM
Lab ID: 012104987-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:16

Client Sample Description FE-151
Boys Lav by Room 27 Sink #1
Collected: 5/1/2021 6:41:00 AM
Lab ID: 012104987-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:17

Client Sample Description FE-152
Boys Lav by Room 27 Sink #2
Collected: 5/1/2021 6:41:00 AM
Lab ID: 012104987-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:18

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104987
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-153
 Girls Lav by Room 27 Sink #1
Collected: 5/1/2021 6:43:00 AM
Lab ID: 012104987-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.17	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:19

Client Sample Description FE-154
 Girls Lav by Room 27 Sink #1
Collected: 5/1/2021 6:43:00 AM
Lab ID: 012104987-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:23

Client Sample Description FE-155
 Hallway fountain by Room 27
Collected: 5/1/2021 6:45:00 AM
Lab ID: 012104987-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:25

Client Sample Description FE-156
 Lav by Room 23
Collected: 5/1/2021 6:47:00 AM
Lab ID: 012104987-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.63	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:26

Client Sample Description FE-157
 Room 21 Classroom Sink
Collected: 5/1/2021 6:48:00 AM
Lab ID: 012104987-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.05	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:27

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104987
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-159 Room 18 Classroom Sink **Collected:** 5/1/2021 6:50:00 AM **Lab ID:** 012104987-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.53	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:23

Client Sample Description FE-162 Room 19 Classroom Sink **Collected:** 5/1/2021 6:51:00 AM **Lab ID:** 012104987-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.1	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:27

Client Sample Description FE-164 Room 16 Classroom Sink **Collected:** 5/1/2021 6:53:00 AM **Lab ID:** 012104987-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.70	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:28

Client Sample Description FE-165 Room 14 Classroom Sink **Collected:** 5/1/2021 6:55:00 AM **Lab ID:** 012104987-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.98	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:30

Client Sample Description FE-167 Room 17 Classroom Sink **Collected:** 5/1/2021 6:57:00 AM **Lab ID:** 012104987-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.74	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:33

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-169
Room 15 Kitchen Sink
Collected: 5/1/2021 6:57:00 AM
Lab ID: 012104987-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.76	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:35

Client Sample Description FE-170
Girls Lav by Room 13 Sink #1
Collected: 5/1/2021 7:00:00 AM
Lab ID: 012104987-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.93	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:36

Client Sample Description FE-171
Girls Lav by Room 13 Sink #2
Collected: 5/1/2021 7:00:00 AM
Lab ID: 012104987-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.25	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:37

Client Sample Description FE-172
Boys Lav by Room 13 Sink #1
Collected: 5/1/2021 7:00:00 AM
Lab ID: 012104987-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.83	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:39

Client Sample Description FE-174
Room 12 Classroom Sink
Collected: 5/1/2021 7:02:00 AM
Lab ID: 012104987-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	21.6	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:40

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	012104987
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-175
Room 12 Bathroom Sink
Collected: 5/1/2021 7:03:00 AM
Lab ID: 012104987-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.7	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:41

Client Sample Description FE-177
Room 11 Classroom Sink
Collected: 5/1/2021 7:05:00 AM
Lab ID: 012104987-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.5	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:45

Client Sample Description FE-178
Room 11 Bathroom Sink
Collected: 5/1/2021 7:05:00 AM
Lab ID: 012104987-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.4	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:49

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results