



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Keith Langlotz
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

5/25/2021

Phone: (716) 626-8860
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/14/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012105071. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012105071
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-180
 Room 12 Bathroom Sink
Collected: 5/1/2021 7:48:00 AM
Lab ID: 012105071-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.06	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:06

Client Sample Description ME-181
 Hallway Fountain by Room 13
Collected: 5/1/2021 7:51:00 AM
Lab ID: 012105071-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:10

Client Sample Description ME-182
 Room 10 Classroom Sink
Collected: 5/1/2021 7:55:00 AM
Lab ID: 012105071-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.45	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:12

Client Sample Description ME-184
 Room 10 Bathroom Sink
Collected: 5/1/2021 7:56:00 AM
Lab ID: 012105071-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.44	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:13

Client Sample Description ME-185
 Room 11 Classroom Sink
Collected: 5/1/2021 7:53:00 AM
Lab ID: 012105071-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.94	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:15

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105071

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-187
Room 11 Bathroom Sink
Collected: 5/1/2021 7:54:00 AM
Lab ID: 012105071-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.44	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:17

Client Sample Description ME-188
Room 9 Classroom Sink
Collected: 5/1/2021 7:58:00 AM
Lab ID: 012105071-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.67	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:18

Client Sample Description ME-190
Room 9 Bathroom Sink
Collected: 5/1/2021 7:57:00 AM
Lab ID: 012105071-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.31	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:23

Client Sample Description ME-191
Room 8 Classroom Sink
Collected: 5/1/2021
Lab ID: 012105071-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.6	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:24

Client Sample Description ME-193
Room 8 Bathroom Sink
Collected: 5/1/2021
Lab ID: 012105071-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.57	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012105071
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-194
 Room 6 Classroom Sink
Collected: 5/1/2021 8:07:00 AM
Lab ID: 012105071-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.36	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:27

Client Sample Description ME-196
 Room 6 Bathroom Sink
Collected: 5/1/2021 8:06:00 AM
Lab ID: 012105071-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.14	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:32

Client Sample Description ME-197
 Room 5 Classroom Sink
Collected: 5/1/2021 8:16:00 AM
Lab ID: 012105071-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.96	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:34

Client Sample Description ME-199
 Room 5 Bathroom Sink
Collected: 5/1/2021 8:17:00 AM
Lab ID: 012105071-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.94	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:35

Client Sample Description ME-201
 Room 4 Classroom Sink
Collected: 5/1/2021 8:20:00 AM
Lab ID: 012105071-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.96	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:37

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105071

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-203
Room 4 Bathroom Sink
Collected: 5/1/2021 8:21:00 AM
Lab ID: 012105071-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.64	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:41

Client Sample Description ME-204
Room 3 Classroom Sink
Collected: 5/1/2021 8:18:00 AM
Lab ID: 012105071-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.43	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:43

Client Sample Description ME-206
Room 3 Bathroom Sink
Collected: 5/1/2021 8:19:00 AM
Lab ID: 012105071-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.77	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:45

Client Sample Description ME-207
Room 2 Classroom Sink
Collected: 5/1/2021 8:22:00 AM
Lab ID: 012105071-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.77	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:46

Client Sample Description ME-208
Room 2 Bathroom Sink
Collected: 5/1/2021 8:23:00 AM
Lab ID: 012105071-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.17	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:48

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012105071
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-209
 Room 1 Classroom Sink
Collected: 5/1/2021 8:24:00 AM
Lab ID: 012105071-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.04	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:54

Client Sample Description ME-211
 Room 1 Bathroom Sink
Collected: 5/1/2021 8:25:00 AM
Lab ID: 012105071-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.00	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:02

Client Sample Description ME-212
 Clinic Sink #1
Collected: 5/1/2021 8:30:00 AM
Lab ID: 012105071-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:03

Client Sample Description ME-213
 Clinic Sink #2
Collected: 5/1/2021 8:31:00 AM
Lab ID: 012105071-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.04	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:05

Client Sample Description ME-214
 Room 69 Sink
Collected: 5/1/2021 8:31:00 AM
Lab ID: 012105071-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105071

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-215
Room 70 Sink
Collected: 5/1/2021 8:33:00 AM
Lab ID: 012105071-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.77	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:08

Client Sample Description ME-216
Library Office Sink
Collected: 5/1/2021 8:34:00 AM
Lab ID: 012105071-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	22.3	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:09

Client Sample Description ME-218
Room 61 Sink
Collected: 5/1/2021 8:36:00 AM
Lab ID: 012105071-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.08	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:11

Client Sample Description ME-219
Room 57 Sink #1
Collected: 5/1/2021 8:37:00 AM
Lab ID: 012105071-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.79	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:12

Client Sample Description ME-220
Café Sink
Collected: 5/1/2021 8:40:00 AM
Lab ID: 012105071-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.50	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:14

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105071

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-221
Café Fountain
Collected: 5/1/2021 8:41:00 AM
Lab ID: 012105071-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:19

Client Sample Description ME-222
Kitchen Bathroom Sink
Collected: 5/1/2021 8:45:00 AM
Lab ID: 012105071-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.61	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:23

Client Sample Description ME-223
Kitchen Sink #1
Collected: 5/1/2021 8:46:00 AM
Lab ID: 012105071-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.78	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:25

Client Sample Description ME-224
Kitchen Sink #2
Collected: 5/1/2021 8:47:00 AM
Lab ID: 012105071-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.66	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:26

Client Sample Description ME-225
Kitchen Sink #3
Collected: 5/1/2021 8:48:00 AM
Lab ID: 012105071-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.82	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:28

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012105071
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-226
 Kitchen Sink #4
Collected: 5/1/2021 8:48:00 AM
Lab ID: 012105071-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.37	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:30

Client Sample Description ME-227
 Kitchen Sink #5
Collected: 5/1/2021 8:45:00 AM
Lab ID: 012105071-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.48	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:31

Client Sample Description ME-229
 Room 57 Classroom Sink #2
Collected: 5/1/2021 8:38:00 AM
Lab ID: 012105071-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.91	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:33

Client Sample Description ME-230
 Room 56C Sink
Collected: 5/1/2021 8:42:00 AM
Lab ID: 012105071-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.66	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:37

Client Sample Description ME-231
 Girls Bathroom by Room 50 Sink
Collected: 5/1/2021 6:31:00 AM
Lab ID: 012105071-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:39

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105071

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860

Fax:

Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-232 **Collected:** 5/1/2021 **Lab ID:** 012105071-0041
Hallway Fountain Across from Room 26 7:11:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 10:04

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results