



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

---

Attn:

**Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**490 Lawrence Bell Dr**  
**Williamsville, NY 14221**

5/24/2021

Phone: (716) 626-8860

Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/11/2021. The results are tabulated on the attached data pages for the following client designated project:

**2021 Lead in Water Testing**

The reference number for these samples is EMSL Order #012104883. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104883  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**490 Lawrence Bell Dr**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 5/11/2021 09:30 AM

Project: **2021 Lead in Water Testing**

**Analytical Results**

**Client Sample Description** MW-190  
 Room 106 Classroom Sink  
**Collected:** 5/1/2021 7:26:00 AM  
**Lab ID:** 012104883-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.46	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:44

**Client Sample Description** MW-192  
 Room 108 Classroom Sink  
**Collected:** 5/1/2021 7:28:00 AM  
**Lab ID:** 012104883-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.88	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:47

**Client Sample Description** MW-194  
 Room 105 Classroom Sink  
**Collected:** 5/1/2021 7:28:00 AM  
**Lab ID:** 012104883-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	5.15	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:49

**Client Sample Description** MW-196  
 Room 104 Classroom Sink  
**Collected:** 5/1/2021 7:30:00 AM  
**Lab ID:** 012104883-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.42	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:50

**Client Sample Description** MW-198  
 Room 103 Classroom Sink  
**Collected:** 5/1/2021 7:32:00 AM  
**Lab ID:** 012104883-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.80	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:51

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104883

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**490 Lawrence Bell Dr**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** MW-200  
Room 102 Classroom Sink  
**Collected:** 5/1/2021 7:34:00 AM  
**Lab ID:** 012104883-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	16.2	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:53

**Client Sample Description** MW-202  
Room 101 Classroom Sink  
**Collected:** 5/1/2021 7:36:00 AM  
**Lab ID:** 012104883-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	11.8	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:54

**Client Sample Description** MW-204  
Room 100 Classroom Sink  
**Collected:** 5/1/2021 7:37:00 AM  
**Lab ID:** 012104883-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.81	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:55

**Client Sample Description** MW-206  
Main Office Sink  
**Collected:** 5/1/2021 7:39:00 AM  
**Lab ID:** 012104883-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	7.84	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:59

**Client Sample Description** MW-207  
Clinic Sink  
**Collected:** 5/1/2021 7:40:00 AM  
**Lab ID:** 012104883-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.00	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:01

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104883  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**490 Lawrence Bell Dr**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** MW-208  
 Clinic Bathroom Sink  
**Collected:** 5/1/2021 7:41:00 AM  
**Lab ID:** 012104883-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.44	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:02

**Client Sample Description** MW-209  
 Girls Shower Bathroom Sink #1  
**Collected:** 5/1/2021 7:45:00 AM  
**Lab ID:** 012104883-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:06

**Client Sample Description** MW-210  
 Girls Shower Bathroom Sink #2  
**Collected:** 5/1/2021 7:45:00 AM  
**Lab ID:** 012104883-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:07

**Client Sample Description** MW-211  
 Boys Shower Bathroom Sink  
**Collected:** 5/1/2021 7:48:00 AM  
**Lab ID:** 012104883-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:08

**Client Sample Description** MW-212  
 Boiler Room Eye Wash  
**Collected:** 5/1/2021 7:50:00 AM  
**Lab ID:** 012104883-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	200 D	5.00 µg/L	5/14/2021 JD	5/17/2021 JW 18:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104883  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**490 Lawrence Bell Dr**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** MW-213  
 Boiler Room Source Sample  
**Collected:** 5/1/2021 8:03:00 AM  
**Lab ID:** 012104883-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	15.8	1.00 µg/L	5/14/2021 JD	5/17/2021 JW 17:33

**Client Sample Description** MW-214  
 Room 102 Sink #2  
**Collected:** 5/1/2021 7:35:00 AM  
**Lab ID:** 012104883-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	22.4	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:10

**Client Sample Description** MW-215  
 Room 101 Sink #2  
**Collected:** 5/1/2021 7:36:00 AM  
**Lab ID:** 012104883-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	76.0	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:11

**Client Sample Description** MW-217  
 Hallway Fountain by Café  
**Collected:** 5/1/2021 6:58:00 AM  
**Lab ID:** 012104883-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:15

**Client Sample Description** MW-218  
 Handicapped Bathroom Sink Custodial Hallway  
**Collected:** 5/1/2021 7:47:00 AM  
**Lab ID:** 012104883-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:16

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104883  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**490 Lawrence Bell Dr**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** MW-219  
Café Stage Sink  
**Collected:** 5/1/2021 7:00:00 AM  
**Lab ID:** 012104883-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.76	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:18

**Client Sample Description** MW-220  
Boys Lav Sink Sink #4  
**Collected:** 5/1/2021 6:54:00 AM  
**Lab ID:** 012104883-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	6.88	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:19

**Client Sample Description** MW-222  
Kitchen Sink #2  
**Collected:** 5/1/2021 7:58:00 AM  
**Lab ID:** 012104883-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.75	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:24

**Client Sample Description** MW-223  
Kitchen Pot Filler  
**Collected:** 5/1/2021  
**Lab ID:** 012104883-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	28.3	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:31

**Client Sample Description** MW-224  
Kitchen Steamer  
**Collected:** 5/1/2021 8:05:00 AM  
**Lab ID:** 012104883-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.43	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:32

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104883

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**490 Lawrence Bell Dr**  
**Williamsville, NY 14221**

Phone: (716) 626-8860

Fax:

Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** MW-225 **Collected:** 5/1/2021 **Lab ID:** 012104883-0026  
 Boys Lav by Gym Sink #3 6:56:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.61	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:33

**Definitions:**

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results