



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

7/19/2021

Phone: (716) 626-8860  
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

**2021 Lead in Water Testing**

The reference number for these samples is EMSL Order #012107300. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107300  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** CM-102 Teachers Conference Room Sink **Collected:** 6/5/2021 8:54:00 AM **Lab ID:** 012107300-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:44

**Client Sample Description** CM-103 Teachers Conference Room Mens Bathroom Sink **Collected:** 6/5/2021 8:55:00 AM **Lab ID:** 012107300-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:51

**Client Sample Description** CM-104 Teachers Conference Room Womens Bathroom Sink **Collected:** 6/5/2021 8:55:00 AM **Lab ID:** 012107300-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.69	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:52

**Client Sample Description** CM-105 Hallways Fountain Across from Room 221 **Collected:** 6/5/2021 8:54:00 AM **Lab ID:** 012107300-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:54

**Client Sample Description** CM-106 Boys Lav by Room 221 Sink #1 **Collected:** 6/5/2021 8:57:00 AM **Lab ID:** 012107300-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.49	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:55

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107300  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** CM-107  
 Boys Lav by Room 221 Sink #2  
**Collected:** 6/5/2021 8:57:00 AM  
**Lab ID:** 012107300-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:56

**Client Sample Description** CM-108  
 Boys Lav by Room 221 Sink #3  
**Collected:** 6/5/2021 8:57:00 AM  
**Lab ID:** 012107300-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:57

**Client Sample Description** CM-109  
 Boys Lav by Room 221 Sink #4  
**Collected:** 6/5/2021 9:00:00 AM  
**Lab ID:** 012107300-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:59

**Client Sample Description** CM-110  
 Girls Lav by Room 221 Sink #1  
**Collected:** 6/5/2021 9:00:00 AM  
**Lab ID:** 012107300-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:00

**Client Sample Description** CM-111  
 Girls Lav by Room 221 Sink #2  
**Collected:** 6/5/2021 9:00:00 AM  
**Lab ID:** 012107300-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:01

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107300

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860

Fax:

Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** CM-112  
Girls Lav by Room 221 Sink #3  
**Collected:** 6/5/2021 9:00:00 AM  
**Lab ID:** 012107300-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:05

**Client Sample Description** CM-113  
Girls Lav by Room 221 Sink #4  
**Collected:** 6/5/2021 9:00:00 AM  
**Lab ID:** 012107300-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:09

**Client Sample Description** CM-117  
Room 201 Classroom Sink  
**Collected:** 6/5/2021 9:01:00 AM  
**Lab ID:** 012107300-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:10

**Client Sample Description** CM-118  
Hallway Fountain Across from Room 119  
**Collected:** 6/5/2021 8:41:00 AM  
**Lab ID:** 012107300-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:12

**Client Sample Description** CM-119  
Room 120 Classroom Sink  
**Collected:** 6/5/2021 8:45:00 AM  
**Lab ID:** 012107300-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:13

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107300  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** CM-120  
 Room 121 Classroom Sink  
**Collected:** 6/5/2021 8:45:00 AM  
**Lab ID:** 012107300-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.16	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:14

**Client Sample Description** CM-121  
 Room 122 Classroom Sink  
**Collected:** 6/5/2021 8:45:00 AM  
**Lab ID:** 012107300-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:16

**Client Sample Description** CM-122  
 Boys Lav across from Attendance Sink #1  
**Collected:** 6/5/2021 8:27:00 AM  
**Lab ID:** 012107300-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:17

**Client Sample Description** CM-123  
 Boys Lav across from Attendance Sink #2  
**Collected:** 6/5/2021 8:27:00 AM  
**Lab ID:** 012107300-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.82	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:21

**Client Sample Description** CM-124  
 Boys Lav across from Attendance Sink #3  
**Collected:** 6/5/2021 8:27:00 AM  
**Lab ID:** 012107300-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:22

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107300  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** CM-125  
 Boys Lav across from Attendance Sink #4  
**Collected:** 6/5/2021 8:27:00 AM  
**Lab ID:** 012107300-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:27

**Client Sample Description** CM-126  
 Girls Lav across from Attendance Sink #1  
**Collected:** 6/5/2021 8:30:00 AM  
**Lab ID:** 012107300-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:31

**Client Sample Description** CM-127  
 Girls Lav across from Attendance Sink #2  
**Collected:** 6/5/2021 8:30:00 AM  
**Lab ID:** 012107300-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:32

**Client Sample Description** CM-128  
 Girls Lav across from Attendance Sink #3  
**Collected:** 6/5/2021 8:30:00 AM  
**Lab ID:** 012107300-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.04	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:36

**Client Sample Description** CM-129  
 Girls Lav across from Attendance Sink #4  
**Collected:** 6/5/2021 8:30:00 AM  
**Lab ID:** 012107300-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:38

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012107300
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

<b>Client Sample Description</b>	CM-130 Room 114 Classroom Sink	<b>Collected:</b>	6/5/2021 8:35:00 AM	<b>Lab ID:</b>	012107300-0026
----------------------------------	-----------------------------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	22.2	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:39

<b>Client Sample Description</b>	CM-131 Faculty Bathroom Across from Room 113 Sink	<b>Collected:</b>	6/5/2021 8:33:00 AM	<b>Lab ID:</b>	012107300-0027
----------------------------------	--	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:40

<b>Client Sample Description</b>	CM-132 Room 113 Classroom Sink	<b>Collected:</b>	6/5/2021 8:34:00 AM	<b>Lab ID:</b>	012107300-0028
----------------------------------	-----------------------------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:42

<b>Client Sample Description</b>	CM-133 Room 112 Classroom Sink	<b>Collected:</b>	6/5/2021 8:34:00 AM	<b>Lab ID:</b>	012107300-0029
----------------------------------	-----------------------------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:43

<b>Client Sample Description</b>	CM-134 Clinic Sink	<b>Collected:</b>	6/5/2021 8:36:00 AM	<b>Lab ID:</b>	012107300-0030
----------------------------------	-----------------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:44

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012107300
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** CM-135  
Clinic Bathroom Sink #1  
**Collected:** 6/5/2021 8:36:00 AM  
**Lab ID:** 012107300-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:45

**Client Sample Description** CM-136  
Clinic Med Room Sink #2  
**Collected:** 6/5/2021 8:36:00 AM  
**Lab ID:** 012107300-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:52

**Client Sample Description** CM-137  
Room 11 Classroom Sink  
**Collected:** 6/5/2021 8:39:00 AM  
**Lab ID:** 012107300-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:53

**Client Sample Description** CM-138  
IMC Sink  
**Collected:** 6/5/2021 8:39:00 AM  
**Lab ID:** 012107300-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:55

**Client Sample Description** CM-139  
Main Office Sink  
**Collected:** 6/5/2021 8:25:00 AM  
**Lab ID:** 012107300-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.45	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:56



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107300

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860

Fax:

Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** CM-140  
Library Sink  
**Collected:** 6/5/2021 8:24:00 AM  
**Lab ID:** 012107300-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.16	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:57

**Client Sample Description** CM-141  
Room 129 Classroom Sink  
**Collected:** 6/5/2021 8:23:00 AM  
**Lab ID:** 012107300-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	20.5	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:58

**Client Sample Description** CM-142  
Room 130 Classroom Sink  
**Collected:** 6/5/2021 8:22:00 AM  
**Lab ID:** 012107300-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	23.9	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:00

**Client Sample Description** CM-143  
Boys Locker Room Bathroom Sink #1  
**Collected:** 6/5/2021 8:19:00 AM  
**Lab ID:** 012107300-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.47	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:01

**Client Sample Description** CM-144  
Boys Locker Room Bathroom Sink #2  
**Collected:** 6/5/2021 8:20:00 AM  
**Lab ID:** 012107300-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:02

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107300  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** CM-147  
 Hallway Fountain across from Room 131  
**Collected:** 6/5/2021 8:16:00 AM  
**Lab ID:** 012107300-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:36

**Client Sample Description** CM-148  
 Room 132 Classroom Sink #1  
**Collected:** 6/5/2021 8:11:00 AM  
**Lab ID:** 012107300-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	9.66	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:43

**Client Sample Description** CM-149  
 Room 132 Classroom Sink #2  
**Collected:** 6/5/2021 8:11:00 AM  
**Lab ID:** 012107300-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	15.6	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:44

**Client Sample Description** CM-150  
 Room 132 Classroom Sink #3  
**Collected:** 6/5/2021 8:11:00 AM  
**Lab ID:** 012107300-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.23	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:46

**Client Sample Description** CM-151  
 Room 132 Classroom Sink #4  
**Collected:** 6/5/2021 8:11:00 AM  
**Lab ID:** 012107300-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	13.9	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:47

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107300  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** CM-152  
 Room 132 Classroom Sink #5  
**Collected:** 6/5/2021 8:11:00 AM  
**Lab ID:** 012107300-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	17.8	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:48

**Client Sample Description** CM-153  
 Room 133 Classroom Sink #1  
**Collected:** 6/5/2021 8:07:00 AM  
**Lab ID:** 012107300-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	5.35	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:49

**Client Sample Description** CM-154  
 Room 133 Classroom Sink #2  
**Collected:** 6/5/2021 8:07:00 AM  
**Lab ID:** 012107300-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.68	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:51

**Client Sample Description** CM-155  
 Room 133 Classroom Sink #3  
**Collected:** 6/5/2021 8:07:00 AM  
**Lab ID:** 012107300-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.69	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:52

**Client Sample Description** CM-156  
 Room 133 Classroom Sink #4  
**Collected:** 6/5/2021 8:07:00 AM  
**Lab ID:** 012107300-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.86	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:36

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107300  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** CM-157 Stage Sink **Collected:** 6/5/2021 7:50:00 AM **Lab ID:** 012107300-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	96.8	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:56

**Client Sample Description** CM-158 Hallway Fountain Across from OT/PT **Collected:** 6/5/2021 7:40:00 AM **Lab ID:** 012107300-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:57

**Client Sample Description** CM-159 Room 138 Classroom Sink **Collected:** 6/5/2021 7:37:00 AM **Lab ID:** 012107300-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.93	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:01

**Client Sample Description** CM-161 Room 139 Classroom Sink #1 **Collected:** 6/5/2021 7:03:03 AM **Lab ID:** 012107300-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	21.3	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:02

**Client Sample Description** CM-164 Room 140 Classroom Sink **Collected:** 6/5/2021 7:29:00 AM **Lab ID:** 012107300-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.94	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107300  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** CM-165  
 Room 141 Classroom Sink  
**Collected:** 6/5/2021 7:27:00 AM  
**Lab ID:** 012107300-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	13.3	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:05

**Client Sample Description** CM-166  
 Room 144 Classroom Sink  
**Collected:** 6/5/2021 7:25:00 AM  
**Lab ID:** 012107300-0057

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:06

**Client Sample Description** CM-167  
 Room 145 Classroom Sink  
**Collected:** 6/5/2021 7:23:00 AM  
**Lab ID:** 012107300-0058

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.21	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:08

**Client Sample Description** CM-168  
 Room 147 Classroom Sink  
**Collected:** 6/5/2021 7:22:00 AM  
**Lab ID:** 012107300-0059

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.89	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:14

**Client Sample Description** CM-169  
 Boys Lav by Room 147 Sink  
**Collected:** 6/5/2021 7:20:00 AM  
**Lab ID:** 012107300-0060

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.20	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:16

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107300  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** CM-170  
 Girls Lav by Room 147 Sink  
**Collected:** 6/5/2021 7:21:00 AM  
**Lab ID:** 012107300-0061

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.17	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:17

**Client Sample Description** CM-171  
 Staff Lav by Room 152 Sink  
**Collected:** 6/5/2021 7:19:00 AM  
**Lab ID:** 012107300-0062

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/13/2021 VD	7/13/2021 KB 21:45

**Client Sample Description** CM-172  
 Faculty Lounge Sink  
**Collected:** 6/5/2021 7:13:00 AM  
**Lab ID:** 012107300-0063

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	12.9	1.00 µg/L	7/13/2021 VD	7/13/2021 KB 21:47

**Client Sample Description** CM-173  
 Faculty Bathroom Sink #1  
**Collected:** 6/5/2021 7:15:00 AM  
**Lab ID:** 012107300-0064

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	37.8	1.00 µg/L	7/13/2021 VD	7/13/2021 KB 21:48

**Client Sample Description** CM-174  
 Faculty Bathroom Sink #2  
**Collected:** 6/5/2021 7:15:00 AM  
**Lab ID:** 012107300-0065

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.38	1.00 µg/L	7/13/2021 VD	7/13/2021 KB 21:52



## EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012107300
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

### Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results