

7/19/2021

Keith Langlotz Williamsville CSD - Facilities Dept 480 Lawrence Bell Dr. Williamsville, NY 14221

Phone: (716) 626-8860 Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107275. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

M. Unly

Phillip Worby, Environmental Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted. NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.



onem oumple Description	Lav by Central Printing			00 AM	012101210 0001	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS						
200.8	Lead	1.95	1.00 μg/L	7/14/2021 KE	3 7/16/2021 VD 15:49	
Client Sample Description	n DO-101 Central Printing Sink			5/2021 Lab ID: 00 AM	012107275-0002	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS						
200.8	Lead	10.1	1.00 μg/L	7/14/2021 KE	3 7/16/2021 VD 15:54	
Client Sample Description	 n DO-102 Staff Lounge Sink 			5/2021 Lab ID: 00 AM	012107275-0003	
Method	Parameter	Result	Prep RL Units Date & Ana		Analysis Date & Analyst	
METALS						
200.8	Lead	3.61	1.00 μg/L	7/14/2021 KE	3 7/16/2021 VD 15:56	
Client Sample Description	n DO-103 Womens Lav by Confere	ence Room Sink # 1		5/2021 Lab ID: 00 AM	012107275-0004	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS						
200.8	Lead	3.75	1.00 μg/L	7/14/2021 KE	3 7/16/2021 VD 15:58	
Client Sample Description	n DO-104 Womens Lav by Confere	ence Room Sink # 2		5/2021 Lab ID: 00 AM	012107275-0005	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS						
200.8	Lead	2.71	1.00 µg/L	7/14/2021 KE	8 7/16/2021 VD 16:04	



Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8 I	Lead	ND	1.00 μg/L	7/14/2021 KB	7/16/2021 VD 16:06
Client Sample Description	DO-106 Lav by Conference Room C Sink		Collected: 6/5/2 7:01:00		012107275-0007
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8 I	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:08
Client Sample Description DO-107 Male Lav across from Broad Room Sink # 1		m Sink # 1	Collected: 6/5/2 7:03:00		
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8 I	Lead	1.23	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:10
Client Sample Description	DO-108 Male Lav across from Broad Roo	m Sink # 2	Collected: 6/5/2 7:03:00		012107275-0009
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8 I	Lead	1.74	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:11
Client Sample Description	DO-109 Female Lav across from Broad R	oom Sink # 1	Collected: 6/5/2 7:06:00		012107275-0010
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8 I	Lead	ND	1.00 μg/L	7/14/2021 KB	7/16/2021 VD 16:13

EMSL	EMSL Analytical, Inc. 200 Route 130 North, Cinnaminson, N. Phone/Fax: (856) 303-2500 / (856) 85 http://www.EMSL.com			EMSL Order: CustomerID: CustomerPO: ProjectID:	012107275 WCSD21A 20-04919			
480 Lawre	iglotz /ille CSD - Facilities Dept ence Bell Dr. /ille, NY 14221	Phone: Fax: Received:	(716) 626-8860 7/5/2021 11:15 A	M				
Project: 2021 Lead in Water Testing								
Analytical Results								
Client Sample Desci	ription DO-110	Collected	I : 6/5/2021	Lab ID:	012107275-0011			

•	Female Lav across from	Broad Room Sink # 2	7:06:0			
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS						
200.8	Lead	ND	1.00 μg/L	7/14/2021 KB	7/16/2021 16:15	VD
Client Sample Description DO-111 Hallwat Fountain by HR			Collected: 6/5/2021 Lab ID: 7:08:00 AM		012107275-0012	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analys Date & Ar	
METALS						
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 16:21	VD

Definitions:

MDL - method detection limit J - Result was below the reporting limit, but at or above the MDL ND - indicates that the analyte was not detected at the reporting limit RL - Reporting Limit (Analytical) D - Dilution Sample required a dilution which was used to calculate final results