



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Keith Langlotz
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107278. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107278
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 101
 Lav Across from café sink
Collected: 6/30/2021 6:07:00 AM
Lab ID: 012107278-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.33	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:05

Client Sample Description MM - 102
 Womens Bathroom across from main entrance sink #1
Collected: 6/30/2021 6:09:00 AM
Lab ID: 012107278-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.63	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:10

Client Sample Description MM - 103
 Womens Bathroom across from main entrance sink #2
Collected: 6/30/2021 6:10:00 AM
Lab ID: 012107278-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.56	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:12

Client Sample Description MM - 104
 Main Office Sink
Collected: 6/30/2021 6:11:00 AM
Lab ID: 012107278-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.47	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:14

Client Sample Description MM - 105
 Principles Office Lav Sink
Collected: 6/30/2021 6:12:00 AM
Lab ID: 012107278-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	30.3	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:20

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107278
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 106
 Storage Room next to Assistance Principals Sink
Collected: 6/30/2021 6:14:00 AM
Lab ID: 012107278-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	202 D	10.0 µg/L	7/16/2021 KB	7/19/2021 KB 15:40

Client Sample Description MM - 107
 Clinic Office Sink
Collected: 6/30/2021 6:16:00 AM
Lab ID: 012107278-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.0	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:23

Client Sample Description MM - 108
 Slinic Bathroom Sink
Collected: 6/30/2021 6:17:00 AM
Lab ID: 012107278-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	26.4	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:25

Client Sample Description MM - 109
 Clinic Eye Wash
Collected: 6/30/2021 6:18:00 AM
Lab ID: 012107278-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.51	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:27

Client Sample Description MM - 110
 Room A-1 Sink
Collected: 6/30/2021 6:20:00 AM
Lab ID: 012107278-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	36.2	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107278
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 111
Room A-6 Sink
Collected: 6/30/2021 6:22:00 AM
Lab ID: 012107278-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	40.2	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:31

Client Sample Description MM - 112
Room A-8 Sink
Collected: 6/30/2021 6:22:00 AM
Lab ID: 012107278-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	56.8	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:37

Client Sample Description MM - 113
Room A-9 Sink
Collected: 6/30/2021 6:23:00 AM
Lab ID: 012107278-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.8	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:42

Client Sample Description MM - 114
Boys Lav Across from A-11 Sink #1
Collected: 6/30/2021 6:28:00 AM
Lab ID: 012107278-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.68	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:44

Client Sample Description MM - 115
Boys Lav Across from A-11 Sink #2
Collected: 6/30/2021 6:28:00 AM
Lab ID: 012107278-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.35	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:46

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107278
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 117
 Hallway fountain across from room A-11 #1
Collected: 6/30/2021 6:32:00 AM
Lab ID: 012107278-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:48

Client Sample Description MM - 119
 Girls Lav across from Room A-11 Sink #1
Collected: 6/30/2021 6:34:00 AM
Lab ID: 012107278-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	22.3	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:50

Client Sample Description MM - 120
 Girls Lav across from Room A-11 Sink #2
Collected: 6/30/2021 6:34:00 AM
Lab ID: 012107278-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.06	1.00 µg/L	7/12/2021 KB	7/13/2021 KB 05:03

Client Sample Description MM - 121
 Girls Lav across from Room A-11 Sink #3
Collected: 6/30/2021 6:34:00 AM
Lab ID: 012107278-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.34	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:52

Client Sample Description MM - 122
 Girls Lav across from Room A-11 Sink #4
Collected: 6/30/2021 6:34:00 AM
Lab ID: 012107278-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.69	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:54

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107278
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 123
 Room A-11 Classroom Sink
Collected: 6/30/2021 6:37:00 AM
Lab ID: 012107278-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	48.4	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:56

Client Sample Description MM - 124
 Room A-10 Classroom Sink
Collected: 6/30/2021 6:38:00 AM
Lab ID: 012107278-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	45.2	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 16:46

Client Sample Description MM - 125
 Room A-13 Classroom Sink
Collected: 6/30/2021 6:39:00 AM
Lab ID: 012107278-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	27.9	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 16:50

Client Sample Description MM - 126
 Library Office Sink
Collected: 6/30/2021 6:42:00 AM
Lab ID: 012107278-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.1	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 16:51

Client Sample Description MM - 127
 Faculty Lav Near Library Sink
Collected: 6/30/2021 6:45:00 AM
Lab ID: 012107278-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.79	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 16:52

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107278
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 128
 Handicapped Lav Across from Library Sink
Collected: 6/30/2021 6:43:00 AM
Lab ID: 012107278-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	26.1	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 16:54

Client Sample Description MM - 129
 Hallway fountain Near Library
Collected: 6/30/2021 6:48:00 AM
Lab ID: 012107278-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 16:59

Client Sample Description MM - 130
 Room 8 Classroom Sink
Collected: 6/30/2021 6:50:00 AM
Lab ID: 012107278-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.2	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:00

Client Sample Description MM - 131
 Room B-6 Classroom Sink
Collected: 6/30/2021 6:51:00 AM
Lab ID: 012107278-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.1	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:01

Client Sample Description MM - 132
 Storage Room next to Assistance Principals Sink
Collected: 6/30/2021 6:57:00 AM
Lab ID: 012107278-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	28.0	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:03

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107278
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 133
 Clinic Office Sink **Collected:** 6/30/2021 6:54:00 AM **Lab ID:** 012107278-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.45	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:04

Client Sample Description MM - 134
 Slinic Bathroom Sink **Collected:** 6/30/2021 6:54:00 AM **Lab ID:** 012107278-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.34	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:05

Client Sample Description MM - 135
 Clinic Eye Wash **Collected:** 6/30/2021 6:56:00 AM **Lab ID:** 012107278-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.11	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:09

Client Sample Description MM - 136
 Room A-1 Sink **Collected:** 6/30/2021 6:56:00 AM **Lab ID:** 012107278-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.42	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:11

Client Sample Description MM - 137
 Room A-6 Sink **Collected:** 6/30/2021 6:56:00 AM **Lab ID:** 012107278-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.22	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:14

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107278

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860

Fax:

Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 138
Room A-8 Sink
Collected: 6/30/2021 6:56:00 AM
Lab ID: 012107278-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.70	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:16

Client Sample Description MM - 139
Room A-9 Sink
Collected: 6/30/2021 6:59:00 AM
Lab ID: 012107278-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:17

Client Sample Description MM - 140
Boys Lav across from A-11 Sink #1
Collected: 6/30/2021 7:00:00 AM
Lab ID: 012107278-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	49.2	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:18

Client Sample Description MM - 141
Boys Lav across from A-11 Sink #2
Collected: 6/30/2021 7:01:00 AM
Lab ID: 012107278-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.3	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:20

Client Sample Description MM - 142
Hallway fountain across from room A-11 #1
Collected: 6/30/2021 7:14:00 AM
Lab ID: 012107278-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	42.3	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:21

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107278
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 143
 Girls Lav Across from Room A-11 Sink #1
Collected: 6/30/2021 7:16:00 AM
Lab ID: 012107278-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.5	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:22

Client Sample Description MM - 144
 Girls Lav Across from Room A-11 Sink #2
Collected: 6/30/2021 7:16:00 AM
Lab ID: 012107278-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.14	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:20

Client Sample Description MM - 145
 Girls Lav Across from Room A-11 Sink #3
Collected: 6/30/2021 7:16:00 AM
Lab ID: 012107278-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.7	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:29

Client Sample Description MM - 146
 Girls Lav Across from Room A-11 Sink #4
Collected: 6/30/2021 7:21:00 AM
Lab ID: 012107278-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.40	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:30

Client Sample Description MM - 149
 Room A-11 Classroom Sink
Collected: 6/30/2021 7:22:00 AM
Lab ID: 012107278-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	36.8	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:31

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107278
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 150
 Room A-10 Classroom Sink
Collected: 6/30/2021 7:23:00 AM
Lab ID: 012107278-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	53.0	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:33

Client Sample Description MM - 151
 Room A-13 Classroom Sink
Collected: 6/30/2021 7:23:00 AM
Lab ID: 012107278-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.00	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:34

Client Sample Description MM - 152
 Library Office Sink
Collected: 6/30/2021 7:27:00 AM
Lab ID: 012107278-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.55	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:35

Client Sample Description MM - 153
 Faculty Lav Near Library Sink
Collected: 6/30/2021 7:27:00 AM
Lab ID: 012107278-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.16	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:39

Client Sample Description MM - 154
 Handicapped Lav Across from Library Sink
Collected: 6/30/2021 7:27:00 AM
Lab ID: 012107278-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.73	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:41

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107278
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 155
 Hallway fountain near library
Collected: 6/30/2021 7:27:00 AM
Lab ID: 012107278-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.35	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:42

Client Sample Description MM - 156
 Room 8 Classroom Sink
Collected: 6/30/2021 7:25:00 AM
Lab ID: 012107278-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.55	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:43

Client Sample Description MM - 157
 Room B-6 Classroom Sink
Collected: 6/30/2021 7:22:00 AM
Lab ID: 012107278-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:47

Client Sample Description MM - 159
 Room C-11 Classroom Sink
Collected: 6/30/2021 7:25:00 AM
Lab ID: 012107278-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	63.9	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:48

Client Sample Description MM - 160
 Room C-10 Classroom Sink
Collected: 6/30/2021 7:26:00 AM
Lab ID: 012107278-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	41.4	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:50

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107278

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860

Fax:

Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 161 **Collected:** 6/30/2021 **Lab ID:** 012107278-0056
Room C-13 Classroom Sink 7:26:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	56.4	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:51

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results