



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Keith Langlotz
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/20/2021

Phone: (716) 626-8860
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107306. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107306
 CustomerID: WCSD21A
 CustomerPO: 20-4919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-102
 Hallway Fountain by E2
Collected: 6/12/2021 6:20:00 AM
Lab ID: 012107306-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:42

Client Sample Description SH-103
 Mens Room by E2 Sink # 1
Collected: 6/12/2021 6:21:00 AM
Lab ID: 012107306-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.22	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:51

Client Sample Description SH-104
 Womens Room by E3 Sink # 1
Collected: 6/12/2021 6:22:00 AM
Lab ID: 012107306-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.14	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:53

Client Sample Description SH-110
 Room E-7 Shower
Collected: 6/12/2021 6:22:00 AM
Lab ID: 012107306-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.29	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 19:30

Client Sample Description SH-112
 Room E-8 Vacuum Cabinet Sink
Collected: 6/12/2021 6:23:00 AM
Lab ID: 012107306-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.6	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:55

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107306

CustomerID: WCSD21A

CustomerPO: 20-4919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-113
Old Girls Squad Room Sink # 1
Collected: 6/12/2021 6:24:00 AM
Lab ID: 012107306-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.20	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:57

Client Sample Description SH-114
Old Girls Squad Room Sink # 2
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107306-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.06	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:59

Client Sample Description SH-115
Girls Coach Office Sink
Collected: 6/12/2021 6:26:00 AM
Lab ID: 012107306-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.65	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:01

Client Sample Description SH-117
Boys Lav by Room 107 Sink # 1
Collected: 6/12/2021 6:27:00 AM
Lab ID: 012107306-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.82	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:03

Client Sample Description SH-118
Boys Lav by Room 107 Sink # 2
Collected: 6/12/2021 6:28:00 AM
Lab ID: 012107306-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.79	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107306
 CustomerID: WCSD21A
 CustomerPO: 20-4919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-119 **Collected:** 6/12/2021 **Lab ID:** 012107306-0011
 Hallwy Fountain/Main Entr 6:29:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:06

Client Sample Description SH-121 **Collected:** 6/12/2021 **Lab ID:** 012107306-0012
 Room 135 Sink # 1 6:30:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:08

Client Sample Description SH-122 **Collected:** 6/12/2021 **Lab ID:** 012107306-0013
 Room 135 Sink # 2 6:31:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:18

Client Sample Description SH-123 **Collected:** 6/12/2021 **Lab ID:** 012107306-0014
 Room 135 Sink # 3 6:32:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.84	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:20

Client Sample Description SH-124 **Collected:** 6/12/2021 **Lab ID:** 012107306-0015
 Room 135 Sink # 4 6:34:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:21

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107306

CustomerID: WCSD21A

CustomerPO: 20-4919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-125
Room 135 Sink # 5
Collected: 6/12/2021 6:35:00 AM
Lab ID: 012107306-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:23

Client Sample Description SH-126
Room 133 Sink # 1
Collected: 6/12/2021 6:35:00 AM
Lab ID: 012107306-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.31	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:25

Client Sample Description SH-127
Room 133 Sink # 2
Collected: 6/12/2021 6:37:00 AM
Lab ID: 012107306-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.45	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:27

Client Sample Description SH-128
Room 133 Sink # 3
Collected: 6/12/2021 6:38:00 AM
Lab ID: 012107306-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.44	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:29

Client Sample Description SH-129
Room 133 Sink # 4
Collected: 6/12/2021 6:39:00 AM
Lab ID: 012107306-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.66	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:31

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107306
 CustomerID: WCSD21A
 CustomerPO: 20-4919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-130 Room 133 Sink # 5 **Collected:** 6/12/2021 6:40:00 AM **Lab ID:** 012107306-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.88	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:37

Client Sample Description SH-131 Mens Coaches Office (corner) Lav Sink **Collected:** 6/12/2021 6:41:00 AM **Lab ID:** 012107306-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.15	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:52

Client Sample Description SH-132 Mens Coach officie Sink **Collected:** 6/12/2021 6:42:00 AM **Lab ID:** 012107306-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.77	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:57

Client Sample Description SH-133 Fountain Boys Locker Room **Collected:** 6/12/2021 6:43:00 AM **Lab ID:** 012107306-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:59

Client Sample Description SH-134 Old Boys Locker Room Sink # 1 **Collected:** 6/12/2021 6:44:00 AM **Lab ID:** 012107306-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.67	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:01

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107306
 CustomerID: WCSD21A
 CustomerPO: 20-4919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-135 **Collected:** 6/12/2021 **Lab ID:** 012107306-0026
 Old Boys Locker Room Sink # 2 6:45:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.57	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:03

Client Sample Description SH-136 **Collected:** 6/12/2021 **Lab ID:** 012107306-0027
 Room 129 P Dark Room Sink 6:46:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.8	1.00 µg/L	7/16/2021 KB	7/19/2021 KB 21:14

Client Sample Description SH-137 **Collected:** 6/12/2021 **Lab ID:** 012107306-0028
 Room 129 P Sink # 1 6:47:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.69	1.00 µg/L	7/16/2021 KB	7/19/2021 KB 21:15

Client Sample Description SH-138 **Collected:** 6/12/2021 **Lab ID:** 012107306-0029
 Room 129 P Sink # 2 6:48:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.94	1.00 µg/L	7/16/2021 KB	7/19/2021 KB 21:17

Client Sample Description SH-139 **Collected:** 6/12/2021 **Lab ID:** 012107306-0030
 Room 129 Sink 6:29:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.93	1.00 µg/L	7/16/2021 KB	7/19/2021 KB 21:18

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107306
 CustomerID: WCSD21A
 CustomerPO: 20-4919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-140
 Room 129 D Sink # 1
Collected: 6/12/2021 6:50:00 AM
Lab ID: 012107306-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	59.4	1.00 µg/L	7/16/2021 KB	7/19/2021 KB 21:19

Client Sample Description SH-141
 Room 129 D Sink # 2
Collected: 6/12/2021 6:51:00 AM
Lab ID: 012107306-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.1	1.00 µg/L	7/16/2021 KB	7/19/2021 KB 21:21

Client Sample Description SH-142
 Room 129 D Sink # 3
Collected: 6/12/2021 6:52:00 AM
Lab ID: 012107306-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.8	1.00 µg/L	7/16/2021 KB	7/19/2021 KB 21:25

Client Sample Description SH-143
 Room 129 D Sink # 4
Collected: 6/12/2021 6:53:00 AM
Lab ID: 012107306-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	34.0	1.00 µg/L	7/16/2021 KB	7/19/2021 KB 21:26

Client Sample Description SH-144
 Unisex Bathroom by 129T Sink
Collected: 6/12/2021 6:54:00 AM
Lab ID: 012107306-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.82	1.00 µg/L	7/16/2021 KB	7/19/2021 KB 21:30

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107306
 CustomerID: WCSD21A
 CustomerPO: 20-4919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-145 Room 129 W sink # 1 **Collected:** 6/12/2021 6:55:00 AM **Lab ID:** 012107306-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.42	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:33

Client Sample Description SH-146 Room 129 W sink # 2 **Collected:** 6/12/2021 6:56:00 AM **Lab ID:** 012107306-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.94	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:35

Client Sample Description SH-147 Room 129 T Sink # 1 **Collected:** 6/12/2021 6:57:00 AM **Lab ID:** 012107306-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.4	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:37

Client Sample Description SH-150 Women lav/New Gym Sink # 1 **Collected:** 6/12/2021 6:58:00 AM **Lab ID:** 012107306-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.54	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:39

Client Sample Description SH-151 Women lav/New Gym Sink # 2 **Collected:** 6/12/2021 6:59:00 AM **Lab ID:** 012107306-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.90	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:41

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	012107306
CustomerID:	WCSD21A
CustomerPO:	20-4919
ProjectID:	

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-152
Men lav by New Gym Sink # 1
Collected: 6/12/2021 7:00:00 AM
Lab ID: 012107306-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.61	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:43

Client Sample Description SH-153
Men lav by New Gym Sink # 2
Collected: 6/12/2021 7:01:00 AM
Lab ID: 012107306-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.66	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:22

Client Sample Description SH-155
New Gym Boy Locker Rm Sink
Collected: 6/12/2021 7:02:00 AM
Lab ID: 012107306-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.96	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 19:42

Client Sample Description SH-156
New Boys Coaches Office Sink
Collected: 6/12/2021 7:03:00 AM
Lab ID: 012107306-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:29

Client Sample Description SH-157
New Boys Coaches Off Shower
Collected: 6/12/2021 7:04:00 AM
Lab ID: 012107306-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.69	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:30

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107306
 CustomerID: WCSD21A
 CustomerPO: 20-4919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-159 **Collected:** 6/12/2021 **Lab ID:** 012107306-0046
 New Gym Girl Locker Rm Sink 7:05:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.60	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:31

Client Sample Description SH-160 **Collected:** 6/12/2021 **Lab ID:** 012107306-0047
 New Gym Girl Locker Rm Sink # 2 7:06:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:32

Client Sample Description SH-161 **Collected:** 6/12/2021 **Lab ID:** 012107306-0048
 New Girls Coaches Office Sink 7:07:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.65	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:34

Client Sample Description SH-162 **Collected:** 6/12/2021 **Lab ID:** 012107306-0049
 New Girls Coaches Off Shower 7:08:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	193 D	10.0 µg/L	7/16/2021 KB	7/19/2021 KB 15:37

Client Sample Description SH-165 **Collected:** 6/12/2021 **Lab ID:** 012107306-0050
 New Gym Foyer Girl Lav Sink # 1 6:18:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/19/2021 KB 15:39

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107306
 CustomerID: WCSD21A
 CustomerPO: 20-4919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-166
 New Gym Foyer Girl Lav Sink # 2
Collected: 6/12/2021 6:18:00 AM
Lab ID: 012107306-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:38

Client Sample Description SH-167
 New Gym Foyer Girl Lav Sink # 3
Collected: 6/12/2021 6:18:00 AM
Lab ID: 012107306-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:39

Client Sample Description SH-168
 New Gym Foyer Girl Lav Sink # 4
Collected: 6/12/2021 6:18:00 AM
Lab ID: 012107306-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:43

Client Sample Description SH-169
 New Gym Foyer Girl Lav Sink # 5
Collected: 6/12/2021 6:18:00 AM
Lab ID: 012107306-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:47

Client Sample Description SH-170
 New Gym Foyer Girl Lav Sink # 6
Collected: 6/12/2021 6:18:00 AM
Lab ID: 012107306-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:48

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	012107306
CustomerID:	WCSD21A
CustomerPO:	20-4919
ProjectID:	

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-171 **Collected:** 6/12/2021 **Lab ID:** 012107306-0056
 New Gym Foyer Boy Lav Sink # 1 6:25:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:49

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results