



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

---

Attn:

**Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

7/19/2021

Phone: (716) 626-8860  
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

**2021 Lead in Water Testing**

The reference number for these samples is EMSL Order #012107277. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107277  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** TM-100  
 Source Sample Boiler Room  
**Collected:** 6/5/2021 8:10:00 AM  
**Lab ID:** 012107277-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	39.9	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 18:46

**Client Sample Description** TM-101  
 Boiler Room Sink  
**Collected:** 6/5/2021 8:06:00 AM  
**Lab ID:** 012107277-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:14

**Client Sample Description** TM-102  
 Water Fountain in Café A/B  
**Collected:** 6/5/2021 6:13:00 AM  
**Lab ID:** 012107277-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:20

**Client Sample Description** TM-103  
 Kitchen Sink #1  
**Collected:** 6/5/2021 6:20:00 AM  
**Lab ID:** 012107277-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.29	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:22

**Client Sample Description** TM-104  
 Kitchen Sink #2  
**Collected:** 6/5/2021 6:32:00 AM  
**Lab ID:** 012107277-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:23

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107277  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** TM-105  
 Kitchen Sink #3  
**Collected:** 6/5/2021 6:18:00 AM  
**Lab ID:** 012107277-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.47	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:24

**Client Sample Description** TM-106  
 Kitchen Sink #4  
**Collected:** 6/5/2021 6:30:00 AM  
**Lab ID:** 012107277-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:25

**Client Sample Description** TM-107  
 Kitchen Sink #5  
**Collected:** 6/5/2021 6:22:00 AM  
**Lab ID:** 012107277-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.13	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:27

**Client Sample Description** TM-108  
 Kitchen Sink #6  
**Collected:** 6/5/2021 6:26:00 AM  
**Lab ID:** 012107277-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.73	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:28

**Client Sample Description** TM-109  
 Kitchen Sink #7  
**Collected:** 6/5/2021 6:25:00 AM  
**Lab ID:** 012107277-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.59	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107277  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** TM-110  
 Kitchen Sink #8 **Collected:** 6/5/2021 6:26:00 AM **Lab ID:** 012107277-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.51	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:31

**Client Sample Description** TM-111  
 Kitchen Sink #9 **Collected:** 6/5/2021 6:28:00 AM **Lab ID:** 012107277-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	10.3	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:35

**Client Sample Description** TM-112  
 Kitchen Sink #10 **Collected:** 6/5/2021 6:28:00 AM **Lab ID:** 012107277-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.03	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:38

**Client Sample Description** TM-113  
 Kitchen Bathroom Sink **Collected:** 6/5/2021 6:35:00 AM **Lab ID:** 012107277-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:40

**Client Sample Description** TM-114  
 Water Fountain in Café C/D **Collected:** 6/5/2021 6:37:00 AM **Lab ID:** 012107277-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:41

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107277  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** TM-115  
 Hallway Fountain Across from Gym  
**Collected:** 6/5/2021 6:38:00 AM  
**Lab ID:** 012107277-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:42

**Client Sample Description** TM-116  
 Boys Locker Room Coaches Sink  
**Collected:** 6/5/2021 6:39:00 AM  
**Lab ID:** 012107277-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.52	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:44

**Client Sample Description** TM-117  
 Boys Locker Room Coaches Shower  
**Collected:** 6/5/2021 6:40:00 AM  
**Lab ID:** 012107277-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	69.4	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:45

**Client Sample Description** TM-118  
 Boys Locker Room Sink #1  
**Collected:** 6/5/2021 6:42:00 AM  
**Lab ID:** 012107277-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:46

**Client Sample Description** TM-119  
 Boys Locker Room Sink#2  
**Collected:** 6/5/2021 6:43:00 AM  
**Lab ID:** 012107277-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:50

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107277

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** TM-120  
Boys Locker Room Sink #3  
**Collected:** 6/5/2021 6:43:00 AM  
**Lab ID:** 012107277-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:51

**Client Sample Description** TM-122  
Boys Bathroom Sports Hallway Sink #1  
**Collected:** 6/5/2021 6:51:00 AM  
**Lab ID:** 012107277-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:57

**Client Sample Description** TM-123  
Boys Bathroom Sports Hallway Sink #2  
**Collected:** 6/5/2021 6:49:00 AM  
**Lab ID:** 012107277-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.18	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:00

**Client Sample Description** TM-124  
Girls Bathroom Sports Hallway Sink #1  
**Collected:** 6/5/2021 6:53:00 AM  
**Lab ID:** 012107277-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:02

**Client Sample Description** TM-125  
Girls Bathroom Sports Hallway Sink #2  
**Collected:** 6/5/2021 6:53:00 AM  
**Lab ID:** 012107277-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107277  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** TM-126  
 Girls Locker Room Coaches Sink  
**Collected:** 6/5/2021 6:54:00 AM  
**Lab ID:** 012107277-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:07

**Client Sample Description** TM-127  
 Girls Locker Room Sink#1  
**Collected:** 6/5/2021 6:54:00 AM  
**Lab ID:** 012107277-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:08

**Client Sample Description** TM-128  
 Girls Locker Room Sink#2  
**Collected:** 6/5/2021 6:54:00 AM  
**Lab ID:** 012107277-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:10

**Client Sample Description** TM-129  
 Girls Locker Room Sink#3  
**Collected:** 6/5/2021 6:55:00 AM  
**Lab ID:** 012107277-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:11

**Client Sample Description** TM-131  
 Pool Chem Eye Wash  
**Collected:** 6/5/2021 7:03:00 AM  
**Lab ID:** 012107277-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:12

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107277  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** TM-133  
Ice Machine Sports Hallway  
**Collected:** 6/5/2021 7:06:00 AM  
**Lab ID:** 012107277-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 18:48

**Client Sample Description** TM-141  
Room D108 Classroom Sink #8  
**Collected:** 6/5/2021 7:11:00 AM  
**Lab ID:** 012107277-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:13

**Client Sample Description** TM-142  
Room D106 Classroom Sink  
**Collected:** 6/5/2021 7:14:00 AM  
**Lab ID:** 012107277-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:15

**Client Sample Description** TM-143  
Room D104 Classroom Sink  
**Collected:** 6/5/2021 7:17:00 AM  
**Lab ID:** 012107277-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.07	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:21

**Client Sample Description** TM-144  
Room D104 Classroom Bubbler  
**Collected:** 6/5/2021 7:17:00 AM  
**Lab ID:** 012107277-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.48	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:23



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107277  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** TM-145  
 Room C103 (IMC) Sink **Collected:** 6/5/2021 7:21:00 AM **Lab ID:** 012107277-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.24	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:24

**Client Sample Description** TM-146  
 Room C106 (Clinic) Classroom Sink #1 **Collected:** 6/5/2021 7:24:00 AM **Lab ID:** 012107277-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:25

**Client Sample Description** TM-147  
 Room C106 (Clinic) Classroom Sink #2 **Collected:** 6/5/2021 7:26:00 AM **Lab ID:** 012107277-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.43	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:26

**Client Sample Description** TM-148  
 Room C106 (Clinic) Bathroom Sink **Collected:** 6/5/2021 7:27:00 AM **Lab ID:** 012107277-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:28

**Client Sample Description** TM-149  
 Room B114 Classroom Sink **Collected:** 6/5/2021 7:30:00 AM **Lab ID:** 012107277-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.65	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107277  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** TM-150  
 Room B115 Classroom Sink **Collected:** 6/5/2021 7:32:00 AM **Lab ID:** 012107277-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.88	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:30

**Client Sample Description** TM-151  
 Room B123 Classroom Sink#1 **Collected:** 6/5/2021 7:34:00 AM **Lab ID:** 012107277-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	15.5	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:32

**Client Sample Description** TM-153  
 Room B123 Classroom Sink#3 **Collected:** 6/5/2021 7:34:00 AM **Lab ID:** 012107277-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	25.2	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:16

**Client Sample Description** TM-154  
 Room B123 Classroom Sink#4 **Collected:** 6/5/2021 7:34:00 AM **Lab ID:** 012107277-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	17.6	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:22

**Client Sample Description** TM-155  
 Room B123 Classroom Sink#5 **Collected:** 6/5/2021 7:36:00 AM **Lab ID:** 012107277-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	168 D	5.00 µg/L	7/9/2021 JD	7/12/2021 JW 20:18

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107277  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** TM-160 C104 Left Bathroom Sink **Collected:** 6/5/2021 7:56:00 AM **Lab ID:** 012107277-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:24

**Client Sample Description** TM-161 C104 Right Bathroom Sink **Collected:** 6/5/2021 7:56:00 AM **Lab ID:** 012107277-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:25

**Client Sample Description** TM-162 C104 Classroom Sink **Collected:** 6/5/2021 7:57:00 AM **Lab ID:** 012107277-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:26

**Client Sample Description** TM-163 Girls Lav by C102 Sink #1 **Collected:** 6/5/2021 7:54:00 AM **Lab ID:** 012107277-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:28

**Client Sample Description** TM-164 Girls Lav by C102 Sink #2 **Collected:** 6/5/2021 7:54:00 AM **Lab ID:** 012107277-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107277  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** TM-165  
 Girls Lav by C102 Sink #3  
**Collected:** 6/5/2021 7:55:00 AM  
**Lab ID:** 012107277-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:30

**Client Sample Description** TM-166  
 Girls Lav by C102 Sink #4  
**Collected:** 6/5/2021 7:55:00 AM  
**Lab ID:** 012107277-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:31

**Client Sample Description** TM-167  
 Boys Lav by C102 Sink#1  
**Collected:** 6/5/2021 7:58:00 AM  
**Lab ID:** 012107277-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:33

**Client Sample Description** TM-168  
 Boys Lav by C102 Sink#2  
**Collected:** 6/5/2021 7:58:00 AM  
**Lab ID:** 012107277-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:34

**Client Sample Description** TM-169  
 Boys Lav by C102 Sink#3  
**Collected:** 6/5/2021 7:58:00 AM  
**Lab ID:** 012107277-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:41

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107277

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860

Fax:

Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** TM-171 **Collected:** 6/5/2021 **Lab ID:** 012107277-0056  
Hallway Fountain by C102 7:59:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:42

**Definitions:**

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results