



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Keith Langlotz
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860

Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107290. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-172
Room A102 Classroom Sink
Collected: 6/5/2021 7:50:00 AM
Lab ID: 012107290-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.34	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:48

Client Sample Description TM-173
Room A108 Classroom Sink
Collected: 6/5/2021 7:50:00 AM
Lab ID: 012107290-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.37	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:52

Client Sample Description TM-174
Room A110 Classroom Sink
Collected: 6/5/2021 7:48:00 AM
Lab ID: 012107290-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.3	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:53

Client Sample Description TM-179
Library Office Sink
Collected: 6/5/2021 8:03:00 AM
Lab ID: 012107290-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.95	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:55

Client Sample Description TM-180
Main Office Bathroom Sink
Collected: 6/5/2021 7:48:00 AM
Lab ID: 012107290-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:56

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107290
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-181
 Main Office Kitchen Sink
Collected: 6/5/2021 7:38:00 AM
Lab ID: 012107290-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:57

Client Sample Description TM-182
 C117 Handicapped bathroom Sink
Collected: 6/5/2021 7:37:00 AM
Lab ID: 012107290-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:01

Client Sample Description TM-183
 C Wing Music Breakroom Sink
Collected: 6/5/2021 7:46:00 AM
Lab ID: 012107290-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:02

Client Sample Description TM-186
 Girls Bathroom near Music Sink # 1
Collected: 6/5/2021 7:34:00 AM
Lab ID: 012107290-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:04

Client Sample Description TM-187
 Girls Bathroom near Music Sink # 2
Collected: 6/5/2021 7:34:00 AM
Lab ID: 012107290-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.18	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:05

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107290
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-188
 Girls Bathroom near Music Sink # 3
Collected: 6/5/2021 7:34:00 AM
Lab ID: 012107290-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.49	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 18:54

Client Sample Description TM-189
 Girls Bathroom near Music Sink # 4
Collected: 6/5/2021 7:34:00 AM
Lab ID: 012107290-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:06

Client Sample Description TM-190
 Boys Bathroom near Music Sink # 1
Collected: 6/5/2021 7:32:00 AM
Lab ID: 012107290-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.48	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:10

Client Sample Description TM-191
 Boys Bathroom near Music Sink # 2
Collected: 6/5/2021 7:32:00 AM
Lab ID: 012107290-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:11

Client Sample Description TM-192
 Boys Bathroom near Music Sink # 3
Collected: 6/5/2021 7:32:00 AM
Lab ID: 012107290-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.09	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:13

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-193
Boys Bathroom near Music Sink # 4
Collected: 6/5/2021 7:32:00 AM
Lab ID: 012107290-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:17

Client Sample Description TM-199
Room B229 Sink # 6
Collected: 6/5/2021 7:14:00 AM
Lab ID: 012107290-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.2	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:18

Client Sample Description TM-200
Room B229 Sink # 7
Collected: 6/5/2021 7:14:00 AM
Lab ID: 012107290-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	76.4	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:19

Client Sample Description TM-206
Room B229 Teachers Office Sink
Collected: 6/5/2021 7:11:00 AM
Lab ID: 012107290-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.52	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:21

Client Sample Description TM-208
Room B227 Sink # 1
Collected: 6/5/2021 7:10:00 AM
Lab ID: 012107290-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.1	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:22

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-209
Room B227 Sink # 2
Collected: 6/5/2021 7:10:00 AM
Lab ID: 012107290-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	73.2	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:23

Client Sample Description TM-213
Room B221 Sink
Collected: 6/5/2021 7:08:00 AM
Lab ID: 012107290-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:28

Client Sample Description TM-214
Room B218 Sink
Collected: 6/5/2021 7:05:00 AM
Lab ID: 012107290-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:35

Client Sample Description TM-215
Room B219 Sink
Collected: 6/5/2021 6:59:00 AM
Lab ID: 012107290-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:36

Client Sample Description TM-216
Room B217 Sink # 1
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107290-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.67	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:37

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-217
Room B217 Sink # 2
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107290-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:39

Client Sample Description TM-218
Room B217 Sink # 3
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107290-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:40

Client Sample Description TM-219
Room B217 Sink # 4
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107290-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.94	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:41

Client Sample Description TM-220
Room B217 Sink # 5
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107290-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.02	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:43

Client Sample Description TM-221
Room B215 Sink # 1
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107290-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.80	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:44

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107290
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-222
 Room B215 Sink # 2 **Collected:** 6/5/2021 6:44:00 AM **Lab ID:** 012107290-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.7	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 19:19

Client Sample Description TM-223
 Hallway Fountain Near B215 **Collected:** 6/5/2021 6:50:00 AM **Lab ID:** 012107290-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:50

Client Sample Description TM-224
 Girls bathroom by B215 Sink # 1 **Collected:** 6/5/2021 6:50:00 AM **Lab ID:** 012107290-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:52

Client Sample Description TM-225
 Girls bathroom by B215 Sink # 2 **Collected:** 6/5/2021 6:50:00 AM **Lab ID:** 012107290-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:56

Client Sample Description TM-226
 Girls bathroom by B215 Sink # 3 **Collected:** 6/5/2021 6:50:00 AM **Lab ID:** 012107290-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:57

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107290
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-227
 Girls bathroom by B215 Sink # 4
Collected: 6/5/2021 6:50:00 AM
Lab ID: 012107290-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:58

Client Sample Description TM-228
 Boys bathroom by B215 Sink # 1
Collected: 6/5/2021 6:53:00 AM
Lab ID: 012107290-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:59

Client Sample Description TM-229
 Boys bathroom by B215 Sink # 2
Collected: 6/5/2021 6:53:00 AM
Lab ID: 012107290-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:03

Client Sample Description TM-230
 Boys bathroom by B215 Sink # 3
Collected: 6/5/2021 6:53:00 AM
Lab ID: 012107290-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:05

Client Sample Description TM-231
 Room A202 Sink # 1
Collected: 6/5/2021 6:16:00 AM
Lab ID: 012107290-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-232
Room A202 Sink # 2
Collected: 6/5/2021 6:16:00 AM
Lab ID: 012107290-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:07

Client Sample Description TM-233
Room A204 Sink # 1
Collected: 6/5/2021 6:45:00 AM
Lab ID: 012107290-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:09

Client Sample Description TM-234
Room A204 Sink # 2
Collected: 6/5/2021 6:45:00 AM
Lab ID: 012107290-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:41

Client Sample Description TM-235
Room A206 Sink
Collected: 6/5/2021 6:25:00 AM
Lab ID: 012107290-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:45

Client Sample Description TM-236
Room A212 Sink # 1
Collected: 6/5/2021 6:27:00 AM
Lab ID: 012107290-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	21.6	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:46

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107290
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-237 Room A212 Sink # 2 **Collected:** 6/5/2021 6:27:00 AM **Lab ID:** 012107290-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	29.3	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:47

Client Sample Description TM-238 Room A212 Sink # 3 **Collected:** 6/5/2021 6:27:00 AM **Lab ID:** 012107290-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	46.7	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:51

Client Sample Description TM-240 Room A214 Sink # 1 **Collected:** 6/5/2021 6:30:00 AM **Lab ID:** 012107290-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	79.7	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:52

Client Sample Description TM-241 Room A214 Sink # 2 **Collected:** 6/5/2021 6:30:00 AM **Lab ID:** 012107290-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	47.9	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:54

Client Sample Description TM-242 Room A214 Sink # 3 **Collected:** 6/5/2021 6:30:00 AM **Lab ID:** 012107290-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	78.4	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 19:22

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107290
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-243
 Room A214 Sink # 4 **Collected:** 6/5/2021 6:30:00 AM **Lab ID:** 012107290-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	56.3	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 19:25

Client Sample Description TM-244
 Room A214 Sink # 5 **Collected:** 6/5/2021 6:30:00 AM **Lab ID:** 012107290-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	47.5	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:55

Client Sample Description TM-245
 Room A214 Sink # 6 **Collected:** 6/5/2021 6:30:00 AM **Lab ID:** 012107290-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	33.4	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:56

Client Sample Description TM-246
 Room 214 Sink # 7 **Collected:** 6/5/2021 6:30:00 AM **Lab ID:** 012107290-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	44.8	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 18:37

Client Sample Description TM-247
 Room 214 Sink # 8 **Collected:** 6/5/2021 6:30:00 AM **Lab ID:** 012107290-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	43.1	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:58

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-248
Room 214 Sink # 9
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107290-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	29.4	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:59

Client Sample Description TM-249
Room 214 Sink # 10
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107290-0057

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.5	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:03

Client Sample Description TM-250
Room 214 Sink # 11
Collected: 6/5/2021 6:31:00 AM
Lab ID: 012107290-0058

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	63.5	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 19:28

Client Sample Description TM-252
Room A214 Teachers Office Sink
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107290-0059

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.12	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:07

Client Sample Description TM-253
Custodial Break Room Sink
Collected: 6/5/2021 8:05:00 AM
Lab ID: 012107290-0060

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:08

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107290
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-254 **Collected:** 6/5/2021 **Lab ID:** 012107290-0061
 Room B219 Bathroom Sink # 1 8:07:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:09

Client Sample Description TM-255 **Collected:** 6/5/2021 **Lab ID:** 012107290-0062
 Room B219 Bathroom Sink # 2 8:07:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:11

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results