



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Keith Langlotz
Williamsville CSD
PO Box 5000
105 Casey Rd.
East Amherst, NY 14051**

10/18/2016

Phone: (716) 626-8070
Fax: (716) 626-8089

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 10/7/2016. The results are tabulated on the attached data pages for the following client designated project:

**Project ID: PO # 17-01867 NY State Components School Dist.
Forest Elementary Water Testing**

The reference number for these samples is EMSL Order #011606603. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

| | |
|-------------|------------------|
| EMSL Order: | 011606603 |
| CustomerID: | WCSD21 |
| CustomerPO: | 17-01867 |
| ProjectID: | PO # 17-01867 NY |

Attn: **Keith Langlotz**
Williamsville CSD
PO Box 5000
105 Casey Rd.
East Amherst, NY 14051

Phone: (716) 626-8070
 Fax: (716) 626-8089
 Received: 10/07/16 9:30 AM

Project: Forest Elementary Water Testing

Analytical Results

Client Sample Description FE-147 **Collected:** 9/24/2016 **Lab ID:** 0001

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | ND | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-148 **Collected:** 9/24/2016 **Lab ID:** 0002

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | ND | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-149 **Collected:** 9/24/2016 **Lab ID:** 0003

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 36.1 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-150 **Collected:** 9/24/2016 **Lab ID:** 0004

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 2.16 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-151 **Collected:** 9/24/2016 **Lab ID:** 0005

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | ND | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-152 **Collected:** 9/24/2016 **Lab ID:** 0006

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | ND | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-153 **Collected:** 9/24/2016 **Lab ID:** 0007

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | ND | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

| | |
|-------------|------------------|
| EMSL Order: | 011606603 |
| CustomerID: | WCSD21 |
| CustomerPO: | 17-01867 |
| ProjectID: | PO # 17-01867 NY |

Attn: **Keith Langlotz**
Williamsville CSD
PO Box 5000
105 Casey Rd.
East Amherst, NY 14051

Phone: (716) 626-8070
 Fax: (716) 626-8089
 Received: 10/07/16 9:30 AM

Project: **Forest Elementary Water Testing****Analytical Results**

Client Sample Description FE-154 **Collected:** 9/24/2016 **Lab ID:** 0008

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | ND | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-155 **Collected:** 9/24/2016 **Lab ID:** 0009

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 4.06 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-156 **Collected:** 9/24/2016 **Lab ID:** 0010

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 1.20 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-157 **Collected:** 9/24/2016 **Lab ID:** 0011

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 7.72 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-158 **Collected:** 9/24/2016 **Lab ID:** 0012

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 4.78 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-159 **Collected:** 9/24/2016 **Lab ID:** 0013

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 6.02 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-160 **Collected:** 9/24/2016 **Lab ID:** 0014

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 4.55 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

| | |
|-------------|------------------|
| EMSL Order: | 011606603 |
| CustomerID: | WCSD21 |
| CustomerPO: | 17-01867 |
| ProjectID: | PO # 17-01867 NY |

Attn: **Keith Langlotz**
Williamsville CSD
PO Box 5000
105 Casey Rd.
East Amherst, NY 14051

Phone: (716) 626-8070
 Fax: (716) 626-8089
 Received: 10/07/16 9:30 AM

Project: **Forest Elementary Water Testing****Analytical Results**

Client Sample Description FE-161 **Collected:** 9/24/2016 **Lab ID:** 0015

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 11.0 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-162 **Collected:** 9/24/2016 **Lab ID:** 0016

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 5.05 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-163 **Collected:** 9/24/2016 **Lab ID:** 0017

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 4.16 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-164 **Collected:** 9/24/2016 **Lab ID:** 0018

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 4.59 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-165 **Collected:** 9/24/2016 **Lab ID:** 0019

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 1.74 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-166 **Collected:** 9/24/2016 **Lab ID:** 0020

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 1.70 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-167 **Collected:** 9/24/2016 **Lab ID:** 0021

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 6.26 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

| | |
|-------------|------------------|
| EMSL Order: | 011606603 |
| CustomerID: | WCSD21 |
| CustomerPO: | 17-01867 |
| ProjectID: | PO # 17-01867 NY |

Attn: **Keith Langlotz**
Williamsville CSD
PO Box 5000
105 Casey Rd.
East Amherst, NY 14051

Phone: (716) 626-8070
 Fax: (716) 626-8089
 Received: 10/07/16 9:30 AM

Project: Forest Elementary Water Testing

Analytical Results

Client Sample Description FE-168 **Collected:** 9/24/2016 **Lab ID:** 0022

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 1.61 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-169 **Collected:** 9/24/2016 **Lab ID:** 0023

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 4.23 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-170 **Collected:** 9/24/2016 **Lab ID:** 0024

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 9.70 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-171 **Collected:** 9/24/2016 **Lab ID:** 0025

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 3.71 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-172 **Collected:** 9/24/2016 **Lab ID:** 0026

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 7.75 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-173 **Collected:** 9/24/2016 **Lab ID:** 0027

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 3.38 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-174 **Collected:** 9/24/2016 **Lab ID:** 0028

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 1.67 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

| | |
|-------------|------------------|
| EMSL Order: | 011606603 |
| CustomerID: | WCSD21 |
| CustomerPO: | 17-01867 |
| ProjectID: | PO # 17-01867 NY |

Attn: **Keith Langlotz**
Williamsville CSD
PO Box 5000
105 Casey Rd.
East Amherst, NY 14051

Phone: (716) 626-8070
 Fax: (716) 626-8089
 Received: 10/07/16 9:30 AM

Project: Forest Elementary Water Testing

Analytical Results

Client Sample Description FE-175 **Collected:** 9/24/2016 **Lab ID:** 0029

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 13.4 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-176 **Collected:** 9/24/2016 **Lab ID:** 0030

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 3.94 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-177 **Collected:** 9/24/2016 **Lab ID:** 0031

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 10.1 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-178 **Collected:** 9/24/2016 **Lab ID:** 0032

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 14.7 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-179 **Collected:** 9/24/2016 **Lab ID:** 0033

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 11.8 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-180 **Collected:** 9/24/2016 **Lab ID:** 0034

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 3.25 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-181 **Collected:** 9/24/2016 **Lab ID:** 0035

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 7.02 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

| | |
|-------------|------------------|
| EMSL Order: | 011606603 |
| CustomerID: | WCSD21 |
| CustomerPO: | 17-01867 |
| ProjectID: | PO # 17-01867 NY |

Attn: **Keith Langlotz**
Williamsville CSD
PO Box 5000
105 Casey Rd.
East Amherst, NY 14051

Phone: (716) 626-8070
 Fax: (716) 626-8089
 Received: 10/07/16 9:30 AM

Project: Forest Elementary Water Testing

Analytical Results

Client Sample Description FE-182 **Collected:** 9/24/2016 **Lab ID:** 0036

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 10.6 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-183 **Collected:** 9/24/2016 **Lab ID:** 0037

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 7.69 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-184 **Collected:** 9/24/2016 **Lab ID:** 0038

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 17.8 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-185 **Collected:** 9/24/2016 **Lab ID:** 0039

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 10.1 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-186 **Collected:** 9/24/2016 **Lab ID:** 0040

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 5.53 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-187 **Collected:** 9/24/2016 **Lab ID:** 0041

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 9.44 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-188 **Collected:** 9/24/2016 **Lab ID:** 0042

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 8.57 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

| | |
|-------------|------------------|
| EMSL Order: | 011606603 |
| CustomerID: | WCSD21 |
| CustomerPO: | 17-01867 |
| ProjectID: | PO # 17-01867 NY |

Attn: **Keith Langlotz**
Williamsville CSD
PO Box 5000
105 Casey Rd.
East Amherst, NY 14051

Phone: (716) 626-8070
 Fax: (716) 626-8089
 Received: 10/07/16 9:30 AM

Project: Forest Elementary Water Testing

Analytical Results

Client Sample Description FE-189 **Collected:** 9/24/2016 **Lab ID:** 0043

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 5.66 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-190 **Collected:** 9/24/2016 **Lab ID:** 0044

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 6.96 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-191 **Collected:** 9/24/2016 **Lab ID:** 0045

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 8.47 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-192 **Collected:** 9/24/2016 **Lab ID:** 0046

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 6.88 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-193 **Collected:** 9/24/2016 **Lab ID:** 0047

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 3.01 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-194 **Collected:** 9/24/2016 **Lab ID:** 0048

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | ND | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-195 **Collected:** 9/24/2016 **Lab ID:** 0049

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 7.38 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

| | |
|-------------|------------------|
| EMSL Order: | 011606603 |
| CustomerID: | WCSD21 |
| CustomerPO: | 17-01867 |
| ProjectID: | PO # 17-01867 NY |

Attn: **Keith Langlotz**
Williamsville CSD
PO Box 5000
105 Casey Rd.
East Amherst, NY 14051

Phone: (716) 626-8070
 Fax: (716) 626-8089
 Received: 10/07/16 9:30 AM

Project: Forest Elementary Water Testing

Analytical Results

Client Sample Description FE-196 **Collected:** 9/24/2016 **Lab ID:** 0050

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 5.12 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-197 **Collected:** 9/24/2016 **Lab ID:** 0051

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 4.55 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-198 **Collected:** 9/24/2016 **Lab ID:** 0052

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 7.44 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-199 **Collected:** 9/24/2016 **Lab ID:** 0053

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 12.3 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-201 **Collected:** 9/24/2016 **Lab ID:** 0054

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 5.42 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-202 **Collected:** 9/24/2016 **Lab ID:** 0055

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 12.0 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-203 **Collected:** 9/24/2016 **Lab ID:** 0056

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 7.18 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

| | |
|-------------|------------------|
| EMSL Order: | 011606603 |
| CustomerID: | WCSD21 |
| CustomerPO: | 17-01867 |
| ProjectID: | PO # 17-01867 NY |

Attn: **Keith Langlotz**
Williamsville CSD
PO Box 5000
105 Casey Rd.
East Amherst, NY 14051

Phone: (716) 626-8070
 Fax: (716) 626-8089
 Received: 10/07/16 9:30 AM

Project: **Forest Elementary Water Testing****Analytical Results**

Client Sample Description FE-204 **Collected:** 9/24/2016 **Lab ID:** 0057

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 18.2 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-205 **Collected:** 9/24/2016 **Lab ID:** 0058

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 12.1 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-207 **Collected:** 9/24/2016 **Lab ID:** 0059

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 9.45 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Client Sample Description FE-208 **Collected:** 9/24/2016 **Lab ID:** 0060

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 9.56 | 1.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | JS |

Definitions:

ND - indicates that the analyte was not detected at the reporting limit
 RL - Reporting Limit (Analytical)