

Check list -BEFORE requesting Final inspection

It is the permit holders responsibility to perform their own punch list

The list below is intended as a tool to assist you in completing construction PRIOR to requesting a FINAL inspection. It is not a complete list of items that may be checked by inspectors at final inspection.

- final electrical inspection must be passed
- house number clearly identified at road
- all final exterior coverings properly installed, penetrations sealed
- grading complete
- gutters, splash blocks/extensions and drip edge properly installed
- lintels and other exposed corrosive metal painted
- hose bibb properly installed
- windows caulked
- drain trap present on package HVAC
- no wood forms left around concrete
- dryer is properly exhausted
- roof dwv vents correct height
- graspable handrail required with 3 steps (4 risers)
- does porch/deck walking surface height require guardrail
- under floor insulated, hot water lines in crawl space insulated
- duct work has 4" or greater ground clearance
- radon barrier laps sealed and sealed to wall and piers
- radon 'T' is under the plastic barrier
- foundation vents functioning properly
- if crawl is encapsulated- does crawl have required ventilation
- all penetrations in foundation walls properly sealed from pest entry
- smoke alarms and/or CO detectors interconnected and in proper locations
- stove anti-tip bracket installed
- proper egress from exterior doors
- proper loop on dishwasher drain
- all plumbing functioning properly, hot water turned on
- exhaust fans installed where required and functioning
- HVAC return and supply housings properly sealed, drain pan and shutoff in place
- window in each bedroom opens properly
- tempered glass is installed where required
- energy ratings posted in breaker box
- doors and deadbolts function properly
- garage door opener safety features functioning properly
- hot water heater has pan if needed, expansion tank and cut off installed
- ladder provided to inspect attic access hole, if pull down- are steps installed correctly
- blown insulation properly installed and access door insulated
- mechanical, metered, filtered fresh air ventilation installed
- blower door and duct leak test results