



Meuller Super Centurion 200
Clow Medallion
Waterous Pacer WB-67-250
Painted With Pennsbury Hydrant
Hide *9060 or Imron *7440

Project Name
 Hydrant
 Typical Installation

General Notes

1. PROVIDE CONCRETE BASE & THRUST BLOCKING AGAINST UNDISTURBED EARTH. CONCRETE BASE & BLOCKING SHALL NOT BLOCK NOR OBSTRUCT HYDRANT DRAIN.
2. THE NOZZLES SHALL NOT BE CLOSER THAN 2 FEET FROM THE BACK OF CURB OR SIDEWALK ROD THE AUXILIARY VALVE TO THE TEE AND THE HYDRANT TO THE AUXILIARY VALVE.
3. ALL BELOW GRADE BOLTS SHALL BE STAINLESS STEEL GRADE 304.

Date
 6-13-2008

Address
 Village of Burr Ridge
 Engineering Department
 451 Commerce St.
 Burr Ridge, IL 60527