



Project Name

Valve Vault

General Notes

1. PROVIDE SELECT GRANULAR BACKFILL CA-6 TO SUBGRADE WHEN IN PAVED AREAS.
2. ALL INTERIOR JOINTS SHALL BE DRESSED WITH NON-SHRINK MORTAR.
3. 4"-8" VALVES SHALL BE IN 4' DIAMETER VAULTS, 10" AND LARGER VALVES SHALL BE IN 5' VAULTS.

Date
6-3-2008

Address
Village of Burr Ridge
Engineering Department
451 Commerce St.
Burr Ridge, IL 60527