

Project Name
Water Main Trench
Cross-Section

General Notes

1. BEDDING SHALL CONSIST OF COMPACTED GRANULAR MATERIAL (CA-6 OR FA-6) FROM A MINIMUM OF 4 INCHES BELOW THE PIPE TO THE CENTERLINE OF THE PIPE. BEDDING SHALL BE COMPACTED TO A MINIMUM OF 90% OF MODIFIED PROCTOR DENSITY IN ACCORDANCE WITH ASTM D-2049.
2. INITIAL BACKFILL SHALL BE COMPACTED GRANULAR MATERIAL (CA-6 OR FA-6) WHEN THE PIPE TRENCH LIES UNDER OR WITHIN TWO FEET OF A CURB OR HARDSURFACED AREA. INITIAL BACKFILL SHALL BE COMPACTED TO A MINIMUM OF 90% OF MODIFIED PROCTOR DENSITY IN ACCORDANCE WITH ASTM D-2049.
3. FINAL BACKFILL UNDER HARDSURFACED AREAS OF WHERE THE TRENCH LIES WITHIN TWO FEET OF A CURB OR HARDSURFACED AREA SHALL BE IDOT CA-6 OR FA-6 (AG-LIME IS NOT PERMITTED) COMPACTED. MINIMUM DEPTH OF FIVE (5) FEET.

Date
5-30-2008

Address
Village of Burr Ridge
Engineering Department
451 Commerce St.
Burr Ridge, IL 60527

