


Dose Volume

Pump to Gravity:

- Industry standard (4" perf. Pipe):
 - Daily flow $\div 4$
(600 gpd $\div 4 = 150$ gal)
or
 - 80% pipe volume:
 - $3 \times 96 = 288$ lf
 - 288×0.65 gal./lf. = 187 gal.
 - $187 \times 80\%$ pipe vol. = 150 gal/dose
- Chambers:
 - Suggest: Daily flow $\div 4$
 - (Note: it's a hypothetical dose volume)




- Nothing wrong with more freq. dose (Timer is always best)

Dose Volume


Pressure Dose:

- Reg. 43 (Industry Std.):
 - 3 – 5 times pipe volume (1.5" pvc)
 - 3 laterals x 96' = 288lf
 - 10.5 gal. / 100lf (288/100 = 2.88)
 - 2.88 x 10.5 = 30.25 gal. (pipe vol.)
 - 30.25 x 4 = 121 gal. dose
 - or
 - 0.25 – 1.0 gal./orifice/dose
 - Orifices 4' c - c
 - $288 \div 4 = 72$ orifices
 - $72 \times 0.25 = 18$ gal/dose (???)
 - $72 \times 1.0 = 72$ gal./dose
 - *** $3 \times 30.25 = 90.75$ gal./dose ***



Drawdown and Dose Volume

- Drawdown (in) = Dose Volume (gallons) ÷ GPI (gallons per inch of drawdown)
- Where:
- GPI = Internal area of dosing chamber in square ft (L x W) x 0.083 ft x 7.5 gal/ft³
 - 1" = 0.083 ft (1 ÷ 12 = 0.083)
 - 7.5 gallons in 1 cubic foot



Calculating Drawdown

Internal tank surface area


- Rectangle: 4' x 7' tank

- $L \times W = \text{Area}$

- $4' \times 7' = \mathbf{28 \text{ ft}^2}$

Width = 4'

Length = 7'




- Round chamber: 4' diameter

- Radius is half of diameter $4 \div 2 = 2'$

- $\pi \times [\text{radius}]^2 = 3.14 \times r \times r$

- $3.14 \times 2 \times 2 = \mathbf{12.5 \text{ ft}^2}$





Top View

Gallons Per Inch


- $\text{Area} \times 0.083' \times 7.5 \text{ gal/ft}^3$
= gal/inch

- $28 \text{ ft}^2 \times 0.083' \times 7.5$
 $\text{gal/ft}^3 = \mathbf{17.5 \text{ gal/in}}$


- $12.5 \text{ ft}^2 \times 0.083' \times 7.5$
 $\text{gal/ft}^3 = \mathbf{7.8 \text{ gal/in}}$




Plan View



Square feet
L x W



Cubic feet
L x W x H
One cubic foot = 7.5 gal.




Calculating for gallons/inch


Dose Volume (DV)

- Drawdown (in) = Dose Vol. \div GPI
- Dose volume \sim 150 gal
- Drawdown =
150 gal \div 17.5 gal/in = 8.6"

8.6" = 150 gallons




With Check Valve



If a check valve is not installed:


- Calculate the gal./lf of forcemain
- Multiply by length of pipe
- Example
 - 2" forcemain = 17.4 gal./100lf
 - 50 lf ÷ 100 lf = 0.5
 - 0.5 x 17.4 = 8.7 gal.
- This number must be added to the calculated dose volume
- Thus: 8.7 + 150 = 158.7
- 159 ÷ 17.5 = 9.1" drawdown



If a check valve is not installed:


- 9.1" drawdown = 158.7 gal.

- $158.7 \div 7.5 = 21.16$ cu.ft.



Dose volume measurements:

- Measure the time of the dose
- 158.7 gal. dosed in 3 min. 45 sec.
- What is the gpm of our pump?



Determine gal./minute

- 159 gal. dosed in 3 min. 45 sec. [$45 \div 60 = 0.75$]
- $159 \div 3.75 = 42.4$ gal./minute

Determine gallons used/day

- Elapsed time meter reading 1/1/2018 = 152.35 hrs.
- Elapsed time meter reading 6/1/2018 = 167.5 hrs.
- $167.55 - 152.35 = 15.15$ hrs.
- 15.15 hrs. x 60 min. = 909 min.
- 909 min. x 42.4 gal./min. = 38,542 gal.
- $38,542$ gal. \div 150 days = 257 gal./day

Suggested dose modifications

- Current dose = 158 gal. [based on 600 gpd]
- $257 \text{ gal./day} \div 158 \text{ gal./dose} = 1.63 \text{ doses / day}$
- Design was looking for 4 doses / day
- $257 \text{ gal.} \times 1.33 (\sim \text{peaking factor}) = 342 \text{ gal.}$
- $342 \div 4 = 85 \text{ gal.}$ [set system to dose 85 gal.]

Float setting adjustments

- $85 \text{ gal.} + 8.7 = 93.7 \text{ gal.}$ [use 94]
- $94 \text{ gal.} \div 17.5 \text{ gal./inch} = 5.4''$ between floats
- If average use: $257 \div 85 \text{ gal./dose} = 3 \text{ doses/day}$





GOOD LUCK!!