

2022 City of Marysville Water Quality Report

Water Supply Serial Number: 4160

This report covers the drinking water quality for City of Marysville for the 2022 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2022. Included are details about where your water comes from, what it contains, and how it compares to United States Environmental Protection Agency (USEPA) and state standards.

Your water comes from the St. Clair River. The State performed an assessment of our source water to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based on geologic sensitivity, well construction, water chemistry and contamination sources. The susceptibility of our source is "highly susceptible."

There are no significant sources of contamination in our water supply.

If you would like to know more about this report, please contact: Bari Wrubel, 1535 River Rd., Marysville MI. 48040 or (810) 364-8460.

Contaminants and their presence in water: Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (800-426-4791).

Vulnerability of sub-populations: Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Center for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other

microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Sources of drinking water: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

To ensure that tap water is safe to drink, the USEPA prescribes regulations that limit the levels of certain contaminants in water provided by public water systems. Federal Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

Water Quality Data

The tables on Page 3 list all the drinking water contaminants that we detected during the 2022 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2022. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **N/A:** Not applicable
- **ND:** not detected at testing limit
- **ppm:** parts per million or milligrams per liter
- **ppb:** parts per billion or micrograms per liter
- **ppt:** parts per trillion or nanograms per liter
- **Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.
- **Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Information about lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Marysville is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you have a lead service line, it is recommended that you run your water for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the USEPA's Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Infants and children who drink water containing lead could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Our water supply has 23 lead service lines and 4 service lines of unknown material out of a total of 3389 service lines.

Monitoring and Reporting to the Michigan Department of Environment, Great Lakes, and Energy (EGLE) Requirements: The State of Michigan and the USEPA require us to test our water on a regular basis to ensure its safety. We met all the monitoring and reporting requirements for 2022.

We will update this report annually and will keep you informed of any problems that may occur throughout the year as they happen. Copies are available at Marysville City Hall, 1255 Delaware, Marysville MI or online at www.cityofmarysvillemi.com/waterquality This report will not be mailed to you.

We invite public participation in decisions that affect drinking water quality. City Council meets every second and fourth Monday evening each month. For more information about your water or the contents of this report, contact Bari Wrubel at (810) 364-8460. For more information about safe drinking water, visit the USEPA at <http://www.epa.gov/safewater>

City of Marysville Monitoring Data for Regulated Contaminants

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Barium (ppm)	2	2	0.01	0.01	2014	No	Discharge of drilling wastes; Discharge of metal refineries; Erosion of natural deposits
Nitrate (ppm)	10	10	0.28	0.28	2022	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Fluoride (ppm)	4	4	0.64	0.64	2022	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Sodium ¹ (ppm)	N/A	N/A	5.9	5.9	2022	No	Erosion of natural deposits
Chloride ¹ (ppm)	N/A	N/A	9.4	9.4	2022	No	Road salt. Industrial discharges.
Sulfate ¹ (ppm)	N/A	N/A	19	19	2022	No	Erosion of natural deposits
TTHM Total Trihalomethanes (ppb) Site #1	80	N/A	40	40	2022	No	Byproduct of drinking water disinfection
TTHM Total Trihalomethanes (ppb) Site #2	80	N/A	37	37	2022	No	Byproduct of drinking water disinfection
HAA5 Haloacetic Acids (ppb) Site #1	60	N/A	8.5	8.5	2022	No	Byproduct of drinking water disinfection
HAA5 Haloacetic Acids (ppb) Site #2	60	N/A	5.5	5.5	2022	No	Byproduct of drinking water disinfection
Chlorine ² (ppm)	4	4	1.17	0.04 to 1.24	2022	No	Water additive used to control microbes

1 Sodium, chloride, and sulfate are not regulated contaminants

2 The chlorine "Level Detected" was calculated using a running annual average.

Inorganic Contaminant Subject to ALs	AL	MCLG	Your Water ¹	Range of Results	Year Sampled	Number of Samples Above AL	Typical Source of Contaminant
Lead (ppb)	15	0	10	ND to 31	2020	2	Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits
Copper (ppm)	1.3	1.3	0.1	ND to 0.8	2020	0	Corrosion of household plumbing systems; Erosion of natural deposits

1 Ninety (90) percent of the samples collected were at or below the level reported for our water.