



MCCORMICK
COUNTY

"The Gem of the Freshwater Coast"

McCormick County Water and Sewer
P.O. Box 338
McCormick, SC 29835
Telephone Number 864-852-2807

REQUIREMENTS FOR WATER HOOK-UP TO COUNTY WATER SYSTEM

CUSTOMER RESPONSIBILITY

1. Must install dual check backflow valve equal to a Watt#7 valve.
2. Must install a pressure reducer valve.
3. Must install a cutoff in a convenient location before the first discharge between house and meter.
4. Line must be inspected before trench is covered up. (In case of rain call Building dept. for more information.)
5. All irrigation systems must install a testable dual check backflow valve and have it tested. First test must be turned into the Building Dept.
6. Line must be a minimum of 12 inches deep.
7. All equipment must be in a box accessible for inspecting, testing, servicing, etc.

Any questions concerning this matter, call the Building Dept.
(864)852-2433.