

Water System Water Main Replacement Priority List - July 7, 2017 Draft

Rank	Name	Description	Distance in Feet	Estimated Cost (if available)
1	US Rt7/ Cady Road	Major transmission main. East side of Route 7, starting at DPW south to Foster Motors	7,500	\$ 1,100,000
2	Exchange Street	Catamount Park North Pond Lane Mainelli Road to Hannaford Drive	3,775 1,812 1,374	\$ 533,000 \$ 255,000 \$ 194,000
3	Court Square Area	8-inch cast-iron pipe water main. Also 6-inch water main which runs across the Square to South Pleasant Street	-	\$ -
4	South Street	Main Street to Porter Field Road Upgrade 4 and 6-inch cast iron pipe to 12-inch main	-	\$ -
5	Gorham Subdivision	Replace 2, 4 and 6 inch universal pipe	4,000	\$ 565,000
6	Foote Street	Replace 6-inch cast iron pipe		\$ 367,000
7	Woodland Park, Meadow Way & Swanage Court	Replace Asbestos-Cement pipe	-	\$ -
8	Cross Country Line Palmer Springs to Colonial Drive	Replace circa 1930 water transmission main.	-	\$ -
9	Charles Avenue	Replace 6-inch main serving High School	-	\$ -
10	Sheep Farm Road	Replace cast iron pipe Weybridge Street to Sheep Farm Road Sheep Farm Road and Loop	2,600 3,400	\$ 305,000 \$ 480,000

Rank	Name	Description	Distance in Feet	Estimated Cost (if available)
11	Colonial Drive	Upgrade 2-inch universal pipe on southwest leg of Colonial Drive	-	\$ -
12	Washington Street Ext to Happy Valley	Replace 6-inch main	-	\$ -
13	Washington Street	Replace ductile iron pipe	-	\$ -
14	Happy Valley Road	Consider looping to Exchange Street	-	\$ -