

# Important Information About Your Drinking Water

## MONITORING REQUIREMENTS NOT MET FOR THE CITY OF SAGINAW

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During April 1, 2022 and April 30, 2022, we did not correctly monitor for trihalomethanes (TTHM). Therefore, we cannot be sure of the quality of your drinking water during that time.

**What should I do?** There is nothing you need to do at this time. This is not an emergency. You do not need to boil water or use an alternative source of water at this time. Even though this is not an emergency, as our customers, you have a right to know what happened and what we are doing to correct the situation. The table below lists the contaminants we did not properly test for, how often we are supposed to sample for these contaminants, how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the dates we collected follow-up samples.

Contaminant	Required Sampling Frequency	Number of Samples Taken	When All Samples Should Have Been Collected	Date Additional Samples Were Collected
TTHM	4 samples every three months	3	April 1, 2022 - April 30, 2022	July 1, 2022 - July 30, 2022

**What happened? What is being done?** A sample was not collected within this required sampling period. The City of Saginaw sampled according to the monitoring schedule but was not notified by the lab of a log-in error resulting in one required TTHM sample not being analyzed during the April 2022 monitoring period. The sample was recollected in May, with a result of 36 ppb, which is well below the Maximum Contaminant Level of 80 ppb. Regulatory samples collected in July 2022 indicate that the water met health standards. Steps have since been taken to ensure samples are collected, as required by law, in the future. There was no emergency and no need to boil water.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by the City of Saginaw. **For more information, please contact the Saginaw Water Treatment Plant at 989-759-1640.**

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Learn more about the Saginaw  
Water Treatment Plant and your  
drinking water by reviewing the  
Drinking Water Quality Report  
found on our website at  
**[www.saginaw-mi.com/ccr](http://www.saginaw-mi.com/ccr)**

PRSRT STD  
US POSTAGE  
PAID  
SAGINAW, MI  
PERMIT NO. 269

Saginaw Water Treatment Plant  
522 Ezra Rust Drive  
Saginaw, MI 48601