

NEC APPROVED
EXTERIOR BOX

20 AMP GFI PROTECTED
CIRCUIT WITH DUPLEX OUTLET

FINISHED GRADE/TOP
OF TREE GRATE IF USED

MAX 6"


3 - RIGID
CONDUITS
(1/2" DIA. MIN.)

18" MIN

36" MIN

36" MIN

TO POWER
MAY BE FLEXIBLE
CONDUIT BELOW 18"



U BOLTS ATTACH ALL
CONDUITS TO 1 1/2" X 1 1/2"
ALUMINUM ANGLE IRON

CITY ELECTRICAL INSPECTOR



PUBLIC WORKS
DEPARTMENT

CBD FESTIVAL OUTLET

DWG. NO.
3-32