



NOTES:

1. PIPE CONNECTION TO MANHOLES SHALL BE MADE BY CORING THE MANHOLE AND CONNECTING THE SEWER PIPE WITH A WATER TIGHT FLEXIBLE RUBBER BOOT IN MANHOLE WALL, KOR-N-SEAL BOOT OR EQUAL.
2. DROP OF GRADE THROUGH MANHOLE SHALL BE 0.10', UNLESS OTHERWISE NOTED



PUBLIC WORKS
DEPARTMENT

SANITARY SEWER MANHOLE SECTION

DWG. NO.

5-4