



*Sevier County Public Works
Department of Environmental Health
227 Cedar Street
Sevierville, TN 37862
865-429-1766 Office / 865-429-1965 Fax*

May 16th, 2025,

To All Prospective Septic Application Applicants:

In accordance and keeping with The Tennessee Department of Environment and Conservation Division of Water Resources Regulations to Govern Subsurface Sewage Disposal Systems along with Sevier County Division of Environmental Health, the following will be enforced July 1st, 2025

All Applications exceeding 5 (five) bedrooms must adhere to the following below:

Regulation 0400-48-01-.07(3)

(c) Large Conventional Systems- Those exceeding seven hundred fifty (750) gallons of estimated daily flow volume.

1. When the estimated daily flow volume exceeds seven hundred fifty (750) gallons for a single system, a properly designed dosing system shall be used for discharging septic tank effluent into the disposal field. The Commissioner shall require design plans by a licensed engineer. The Commissioner may also require:
 - (i) Prior to design approval, a licensed engineer must agree, in writing, to monitor the installation and construction of the system and upon completion, provide a final set of construction as-built plans encompassing all components of the system and certification that the installation is in accordance with the design specifications.
 - (ii) Prior to design approval, it shall be the responsibility of the Department to review the aforementioned design and notify the engineer in writing, of approval of the plans, denial of the plans or needed modifications to the plans.

Gary Loveday
Director, Environmental Health

Gary Loveday

Brenda Rhea
Assistant Director, Environmental Health

Brenda Rhea