


**Town of Stafford**  
**Water Pollution Control Authority**  
 Special Meeting  
 Warren Memorial Town Hall  
 Veteran's Meeting Room  
 1 Main Street  
 Tuesday, August 30, 2022  
 5:30 p.m.

RECEIVED  
 STAFFORD, CT

2022 AUG 31 PM 12:43

2 pages  
  
 TOWN CLERK

Members Present: Chairman Scott Bonett; Richard Dobson Jr; Mandy Fisher; and Allen Warren

Members Absent: Paul Burns; Roger Thomas and Dave Walsh

Also present: Superintendent Richard Hartenstein, Jr.; and Jane LaMorte, Business Manager

Index:

1. Call To Order
2. Discussion/Action Control Panel Failure Screen for Pretreatment
3. 0 West Stafford Road Sewer Connection, Map 46, Lot 70.1 (Proposed New Walgreens Building)
4. Adjournment

### **1. Call To Order**

The meeting was called to order at 5:36 p.m. A quorum was established.

### **2. Discussion/Action Control Panel Failure Screen for Pretreatment**

There was a complete rebuild of the pretreatment screen in 2018, the control panel was not addressed at this time. The screen is an integral part of the plant because it removes anything larger than 6mm in diameter. Allowing only water pass through keeps the plant running most efficiently. Recently, there have been faults in the control panel, technicians and engineers investigated the problem and a replacement was recommended, to include the panel, VFD and the PLC input and output wiring.

*Mandy Fisher made a motion to approve the purchase of the screen control parts and replacement totaling \$17,362.42. Richard Dobson seconded the motion. Motion carries with a 3 -0-1 vote, with Chairman Scott Bonett abstaining.*

### **3. 0 West Stafford Road Sewer Connection, Map 46, Lot 70.1 (Proposed New Walgreens Building)**


A new building is in construction phase at this location. Building plans have been submitted. No sewer application has been submitted, at this time. There have been connection discussions with the Superintendent.

*Richard Dobson made a motion to authorize the connection of 0 West Stafford Road, Map 46, Lot 70.1 to the sanitary sewer according to the Stafford WPCA Regulations for the Installation and Connection of Building Sewers and Superintendent approval. Mandy Fisher seconded the motion. Motion carries with a 3-0-1 vote, with Chairman Scott Bonett abstaining.*

**4. Adjournment**

***Mandy Fisher made a motion to adjourn the meeting at 5:48 p.m. and Richard Dobson seconded the motion. Motion carried with a 3-0-1 vote, with Chairman Scott Bonett abstaining.***

Respectfully Submitted,



Jane LaMorte  
Recording Secretary