



UNREGULATED CONTAMINANTS ASSESSMENT MONITORING

PFAS/PFOA

COMPOUND	MCL	HBWC	SAMPLE DATE			
			4/22/2014	7/15/2014	10/23/2014	1/22/2015
Perfluorooctanesulfonic acid (PFOS)	4.0 ng/L		<1.3 ng/L	<1.3 ng/L	<1.3 ng/L	<1.3 ng/L
Perfluorooctanoic acid (PFOA)	4.0 ng/L		<0.67 ng/L	<0.67 ng/L	<0.67 ng/L	<0.67 ng/L
Perfluorobutanesulfonic acid (PFBS)		2000 ng/L	<30 ng/L	<30 ng/L	<30 ng/L	<30 ng/L
Perfluoroheptanoic acid		n/a	<3.3 ng/L	<3.3 ng/L	<3.3 ng/L	<3.3 ng/L
Perfluorohexanesulfonic acid (PFHxS)		9 ng/L	<10 ng/L	<10 ng/L	<10 ng/L	<10 ng/L
Perfluorononanoic acid (PFNA)		10 ng/L	<0.67 ng/L	<0.67 ng/L	<0.67 ng/L	<0.67 ng/L
Hexafluoropropylene dimer Acid (Gen-X)		10 ng/L	Not tested			

MCL - Environmental Protection Agency proposed Maximum Contaminant Level

HBWC - Health-Based Water Concentration

< - indicates compound not detected at or below concentration shown.