



Town of Tarboro
P.O. Box 220 – 500 Main Street
Tarboro, NC 27886-0220
Telephone (252) 641-4200
Fax (252) 641-4286
www.tarboro-nc.com

CORRECTION TO PERFORMANCE ANNUAL REPORT

I. General Information

Facility/System Name: Town of Tarboro Wastewater Treatment Plant
Responsible Entity: Troy R. Lewis, Town Manager
Person in Charge/Contact: Michael Allen
Applicable Permit(s): NC0020605

The Town has included their new Mercury Minimization Plan on the Town website (www.tarboro-nc.com) as part of the requirements per the new NPDES permit.

Description of Collection System or Treatment Process:

5.0 MGD Wastewater Treatment Facility consisting of bar screens, aerated grit chamber, primary sedimentation using clarifiers, trickling filters and activated sludge, chlorination, dechlorination and cascade aeration.

II. Performance

Text Summary of System Performance for Fiscal Year 7-1-17 to 6-30-18.

The plant operated well within the permitted guidelines outlined in the NPDES permit issued by the N.C. Department of Environment and Natural Resources.

III. Violations


There were no violations reported.

IV. Notification-


This report has been made available to users by insertion into monthly utility bill.

V. Certification

I certify under penalty of law that this report is complete and accurate to the best of my knowledge. I further certify that this report has been made available to the users or customers of the name system and that those users have been notified of its availability.



John K. Moore, Director of Public Works
Town of Tarboro



Date