

## Maintenance Report 5/8/23 – 6/5/23

Hello All, another busy month in the maintenance department 362 meter registers replaced from touch read to radio read, 8 manual read meters switched out to radio read. That's a pretty big task in its self, a big thanks goes to all the maintenance staff part and full time for working hard to get this accomplished. We still have about 40 manual read meters to switch out but with brass supply issues it may be a few month before we have all the meters switch to radio read. We completed 14 miss utilities locates from go fiber contractor with another 15 coming is this morning. I'm sure many more will come in until the job is complete. We replaced 75' of 1" water service line on Lone Pine Drive with another 100' coming soon again waiting on supply issues. We replaced water filters (20) at the filter plant this is usually a 2 man job all day. We shut down well 2 for a day and preformed a day of general maintenance and stared up the filter plant while well was down. We had planned to run the spring a few days but couldn't because the spring couldn't keep up because of the dry weather. The rest of the report is below and again if anyone has any questions on this report or any other issues with the maintenance department do hesitate to call or email me thanks Chris.

Remove broken tree limb hanging in tree Memorial Park

Search for valve Belvedere and North Main

Shoot grade for sewer to bathrooms at legion Park

Seed and fertilize ground from water leak and electric service install

Install 3 signs and 3 post Memorial park

Repair 2' water leak Orchard Dr. and fix ground

Replace brakes calipers and rotors on 06 ford dump truck

Go to pick up Trailer in Ruckersville band stand

Meet with VDOT on sidewalk plan

Repair 8" sewer belvedere hit by contractor

Fill pot hole Walnut Dr.

Install new door town office Southside

Paint handrail Memorial Park

Service rotate tires Pd car

Clean shelter for school field trips 3 time last week