

**ADDENDUM NO. #6
CITY OF TRUTH OR CONSEQUENCES
MAIN STREET DISTRICT (MSD)
WATER SYSTEM IMPROVEMENTS****March 24, 2022****TO: All Holders of Contract Documents For:****FOR: CITY OF TRUTH OR CONSEQUENCES MAIN STREET DISTRICT (MSD) WATER
SYSTEM IMPROVEMENTS****FROM: Wilson & Company Inc.**

The following Addendum #6 shall be incorporated into the Contract Documents for the above referenced project.

**ADDENDUM NUMBER SIX (6):
Updated Stage wage rates attached.****CONTRACTOR QUESTIONS & ANSWERS:**

- 1. Question:** Bid Item #17 calls for 350LF of 18" DIP. Plans show 250LF. Please Clarify.
Answer: Bide Item #17 quantity is correct, 350 LF
- 2. Question:** Under which item will the Fire Hydrant Assembly shown on D101 be paid?
Answer: Line item 28.A "4 1/2'-Depth Fire Hydrant w/ piping valves, and connection
" to be added to bid form, new bid form for Construction Contract EJCDC C-410 attached
- 3. Question:** 4ea 18" gate valves are shown on plan sheet D101. Which bid item will they be paid under?
Answer: Line item 22.A to be added to bid form, new bid form for Construction Contract EJCDC C-410 attached
- 4. Question:** Bid item #29 calls for 40ea 18" joint restraints. In 350LF of 18" DIP there are only 19 joints. Please clarify.
Answer: Bid item #29 " Furnish and Install 18-Inch DI Mechanically Restrained Joint Assembly, per APWA Standard Spec. 801, Complete in Place" verified at 24 ea. New Bid Form for Construction Contract EJCDC C-410 attached with updated quantities.
- 5. Question:** Bid item #31 calls for 38LF of 6" FPVC for HDD. Plans show 65LF. Please clarify.
Answer: Bid item #31" 6-inch FPVC C-900, DR 18 PVC Pipe: Horizontal Directional Drill" verified at 66 LF. New Bid Form for Construction Contract EJCDC C-410 attached with updated quantities.

6. **Question:** Bid item #32 calls for 1126LF of 8" FPVC for HDD. Plans show 640LF. Please clarify.
Answer: [Bid item #32" 8-inch FPVC C-900, DR 18 PVC Pipe: Horizontal Directional Drill" verified at 653 LF. New Bid Form for Construction Contract EJCDC C-410 attached with updated quantities.](#)
7. **Question:** There are various places where 6" pipe is installed at connection points Via open cut. Under which item will this pipe be paid and will it be regular 6" C900 DR18 (G) pipe?
Answer: [6" pipe installed at connection points via Open Trench will be paid under line item 34" 6" Waterline C-900 DR-18 PVC Pipe Installed" unless specified otherwise.](#)
8. **Question:** Plan show a 12"x1" CARV assembly. There is no bid item for this. Under which item will it be paid?
Answer: [Line item 44.A to be added to bid form, new bid form for Construction Contract EJCDC C-410 attached](#)
9. **Question:** Bid item #36A calls for 935LF of 6" FPVC for Bursting. Plans show 1040LF. Please clarify.
Answer: [Bid item #36" 6-inch FPVC C-900, DR 18 PVC Pipe: Pipe Bursting Method" verified at 935 LF. New Bid Form for Construction Contract EJCDC C-410 attached with updated quantities.](#)
10. **Question:** Bid item #37 calls for 1084LF of 8" FPVC for Bursting. Plans show 1520LF. Please clarify.
Answer: [Bid item #37" 8-inch FPVC C-900, DR 18 PVC Pipe: Pipe Bursting Method" verified at 1556 LF. New Bid Form for Construction Contract EJCDC C-410 attached with updated quantities.](#)
11. **Question:** Bid item #39 calls for 6ea 6" MegaCplgs. Plans show 10ea. Please clarify.
Answer: [Bid item #39 "6" PVC pipe restrained coupling installed Series #3800S" verified at 10 ea. New Bid Form for Construction Contract EJCDC C-410 attached with updated quantities](#)
12. **Question:** Bid item #40 calls for 7ea 8" MegaCplgs. Plans show 8ea. Please clarify.
Answer: [Bid item #40 "8" PVC pipe restrained coupling installed Series #3808S" verified at 6 ea. New Bid Form for Construction Contract EJCDC C-410 attached with updated quantities](#)
13. **Question:** Bid item #41 calls for 1ea 12" MegaCplgs. Plans show 4ea. Please clarify.
Answer: [Bid item #41 "12" PVC pipe restrained coupling installed Series #3812S" verified at 3ea. New Bid Form for Construction Contract EJCDC C-410 attached with updated quantities](#)
14. **Question:** Bid item #42 calls for 23ea 6" Gate Valves. Plans show 15ea. Please clarify.
Answer: [Bid item #42 "6" Gate Valves w/ Valve Can, CIP" verified at 18ea. New Bid Form for Construction Contract EJCDC C-410 attached with updated quantities](#)

15. **Question:** Bid item #43 calls for 41ea 8" Gate Valves. Plans show 34ea. Please clarify
Answer: Bid item #43 "8" Gate Valves w/ Valve Can, CIP" verified at 34ea. New Bid Form for Construction Contract EJCDC C-410 attached with updated quantities
16. **Question:** Bid item #44 calls for 36ea 12" Gate Valves. Plans show 39ea. Please clarify.
Answer: Bid item #44 "12" Gate Valves w/ Valve Can, CIP" verified at 40ea. New Bid Form for Construction Contract EJCDC C-410 attached with updated quantities
17. **Question:** Bid item #47 calls for 9ea pressurized connections. The plans don't clearly indicate which of the many connections these are. Please clarify.
Answer: Pressurized connections shall be counted as new connection to existing waterline, which requires shut off. Bid item #47 "Pressurized waterline connections, CIP" verified at 13 ea. New Bid Form for Construction Contract EJCDC C-410 attached with updated quantities
18. **Question:** Bid item #50 calls for 314ea 10"-12" joint restraints. That is enough restraints to restrain 6300LF of pipe. There is not that much 12" PVC pipe installed by open cut on the project. Please clarify.
Answer: Bid item #50 "Furnish and Install 18-Inch DIP, Including Trenching and Compacted Backfill, per APWA Standard Spec. 801, Complete in Place" verified at 110 ea. New Bid Form for Construction Contract EJCDC C-410 attached with updated quantities

ALL OTHER PROVISIONS OF THE CONTRACT DOCUMENTS SHALL REMAIN UNCHANGED. THIS ADDENDUM IS HEREBY MADE A PART OF THE CONTRACT DOCUMENTS TO THE SAME EXTENT AS THOSE PROVISIONS CONTAINED IN THE ORIGINAL DOCUMENTS AND ALL ITEMIZED LISTINGS THEREOF.

Each bidder shall acknowledge receipt of the Addendum No. SIX (6) on the Bid Form in the space provided.



Mark A. Nasi P.E. # 13076
Wilson & Company

DATE: 03/24/2022

BID FORM FOR CONSTRUCTION CONTRACT

The terms used in this Bid with initial capital letters have the meanings stated in the Instructions to Bidders, the General Conditions, and the Supplementary Conditions.

ARTICLE 1—OWNER AND BIDDER

- 1.01 This Bid is submitted to: **City of Truth or Consequences, 505 Sims St. Truth or Consequences, NM 87901**
- 1.02 The undersigned Bidder proposes and agrees, if this Bid is accepted, to enter into an Agreement with Owner in the form included in the Bidding Documents to perform all Work as specified or indicated in the Bidding Documents for the prices and within the times indicated in this Bid and in accordance with the other terms and conditions of the Bidding Documents.

ARTICLE 2—ATTACHMENTS TO THIS BID

- 2.01 The following documents are submitted with and made a condition of this Bid:
- A. Required Bid security;
 - B. List of Proposed Subcontractors;
 - C. List of Proposed Suppliers;
 - D. Evidence of authority to do business in the state of the Project; or a written covenant to obtain such authority within the time for acceptance of Bids;
 - E. Contractor's license number as evidence of Bidder's State Contractor's License or a covenant by Bidder to obtain said license within the time for acceptance of Bids;
 - F. Required Bidder Qualification Statement with supporting data;
 - G. If Bid amount exceeds \$10,000 signed Compliance Statement (RD 400-6). Refer to specific equal opportunity requirements set forth in the Supplementary Conditions of the Construction Contract (EJCDC C-800);
 - H. If Bid amount exceeds \$25,000, signed Certification Regarding Debarment, Suspension, Ineligibility and Voluntary Exclusion – Lower Tier Covered Transactions (AS-1048);
 - I. If Bid amount exceeds \$100,000, signed RD Instruction 1940-Q Exhibit A-1, Certification for Contracts, Grants, and Loans.;
 - J. [List other documents and edit above as pertinent].

ARTICLE 3—BASIS OF BID—LUMP SUM BID AND UNIT PRICES

- 3.01 *Unit Price Bids*
- A. Bidder will perform the following Work at the indicated unit prices:

ITEM NO.	DESCRIPTION	UNIT	ESTIMATED QTY	BID UNIT PRICE	BID AMMOUNT
1	Mobilization & Demobilization	LS	1		
2	SWPPP Preparation	LS	1		
3	SWPPP Implementation and inspection	LS	1		
4	Construction Sign	LS	1		
5	Construction Survey to include staking, layout and identifying project boundaries.	LS	1		
6	Traffic Control	LS	1		
7	Utility Relocation	ALLW	1	\$ 50,000	
8	Material Testing Allowance	ALLW	1	\$ 55,540	
9	Subsurface Utility Locating	ALLW	1	\$ 50,000	
10	SCADA Allowance	ALLW	1	\$ 150,000	
COOK ST. TREATMENT FACILITY CONSTRUCTION ITEMS					
11	Site Grading/Excavation	CY	1,000		
12	Engineered Fill/Subgrade Prep for Tank Foundation, Including Compaction and Testing	CY	630		
13	6-Inch Gravel Pad, Including Subgrade Prep, Installed	SY	821		
14	Furnish and Install 0.300 million Gallon Welded Steel Tank, AWWA D100-11, CIP	LS	1		
15	Tank Foundation, Installed	LS	1		
16	Furnish and Install Cathodic Protection for Tank, Complete in Place	LS	1		
17	Furnish and Install 18-Inch DIP, Including Trenching and Compacted Backfill, per APWA Standard Spec. 801, Complete in Place	LF	350		
18	Finish and install Val-Matic Check valve, CIP	EA	2		
19	Furnish and install ARV W/ Furnish and appurtenances, CIP	EA	2		
20	Furnish and Install 10" E+H Magmeter, Promag W400, 5W4C2F, DN30 12 9'X5' in precast concrete vault with bypass, and new chlorine injection port. CIP	LS	1		
21	Furnish and install Pump and Motor W/ VFD	EA	2		
22	Ductile Iron MJ fittings, class 250, 18" Waterlines incl. Joining Material	LB	5,835		
22.A	8" Gate Valves w/ Valve Can, CIP	EA	4		
23	Furnish and Install 10-Inch Cast Iron Gate Valve (MJ)	EA	2		
24	Furnish and Install 12-Inch Cast Iron Gate Valve (MJ)	EA	2		
25	Connect to Existing 18-Inch Waterline, Complete in Place	EA	2		
26	Furnish and install new gas- chlorination disinfection system, including fiberglass shed, CIP.	EA	1		
27	Generator, 1MW, 480/277V, 3 Phase, 4W, Diesel Unit and Generator Pad, including subgrade prep reinforcement, Installed	LS	1		
28	Chlorination Building Foundation Pad, including subgrade prep reinforcement, Installed	LS	1		
28.A	4 1/2'-Depth Fire Hydrant w/ piping valves, and connection	EA	1		
29	Furnish and Install 18-Inch DI Mechanically Restrained Joint Assembly, per APWA Standard Spec. 801, Complete in Place	EA	40		
30	12" E+H Magmeter, Promag W400, 5W4C3H, DN30 12, 7'X7' in precast concrete vault with bypass. CIP	EA	1		
IMPROVEMENTS TO DISTRIBUTION SYSTEM					
31	6-inch FPVC C-900, DR 18 PVC Pipe: Horizontal Directional Drill	LF	66		
32	8-inch FPVC C-900, DR 18 PVC Pipe: Horizontal Directional Drill	LF	653		
33	12-inch FPVC C-900, DR 18 PVC Pipe: Horizontal Directional Drill	LF	340		
35	8" Waterline C-900 DR-18 PVC Pipe Installed	LF	2,142		
36	12" Waterline C-900 DR-18 PVC Pipe Installed	LF	5,433		
38	6-inch FPVC C-900, DR 18 PVC Pipe: Pipe Bursting Method	LF	935		
37	8-inch FPVC C-900, DR 18 PVC Pipe: Pipe Bursting Method	LF	1,556		
38	12-inch FPVC C-900, DR 18 PVC Pipe: Pipe Bursting Method	LF	177		
39	6" PVC pipe restrained coupling installed Series #3800S	EA	10		
40	8" PVC pipe restrained coupling installed Series #3808S	EA	6		
41	12" PVC pipe restrained coupling installed Series #3812S	EA	3		
42	6" Gate Valves w/ Valve Can, CIP	EA	18		

EJCDC® C-410, Bid Form for Construction Contract.

Copyright© 2018 National Society of Professional Engineers, American Council of Engineering Companies,
and American Society of Civil Engineers. All rights reserved.

ITEM NO.	DESCRIPTION	UNIT	ESTIMATED QTY	BID UNIT PRICE	BID AMMOUNT
43	8" Gate Valves w/ Valve Can, CIP	EA	34		
44	12" Gate Valves w/ Valve Can, CIP	EA	44		
44.A	1 "Combination Air Release Valve (CARV) Assembly	EA	1		
45	4 1/2'-Depth Fire Hydrant w/ piping valves, and connection	EA	1		
46	3 1/2'-Depth Fire Hydrant w/ piping valves, and connection	EA	11		
47	Pressurized waterline connections, CIP	EA	13		
48	Ductile Iron MJ Fittings, All Sizes, Class 25, CIP	LB	15,255		
49	Joint Restraints 4"-8", CIP	EA	181		
50	Joint Restraints 10"-12", CIP	EA	110		
51	Water Meter Box Remove & Replace,incl connectors & smart valve, compl.	EA	119		
52	Dewatering of Trench and Bore Pits, CIP	LF	3,000		
53	Temporary water services	LF	3,500		
54	Temporary Service connection	EA	32		
ROADWAY					
55	Asphalt Roadway, Remove, Dispose and Replace with SP III, 3" Thick for Residential Streets, include Subgrade Prep, CIP	SY	382		
56	Asphalt Roadway, Remove, Dispose and Replace with SP III, 6" Thick for NMDOT ROW, include Subgrade Prep, CIP	SY	7,142		
57	Excavate and Dispose of Unsuitable Material, CIP	CY	11,809		
58	Import of select material	CY	11,809		
59	Geogrid Base Roadway Reinforcement	SY	7,524		
60	Remove and replace Curb and Gutter, CIP	LF	580		
61	Remove and replace Sidewalk, CIP	SY	339		
ELECTRICAL / CONTROLS					
ITEM NO.	DESCRIPTION	UNIT	ESTIMATED QTY	UNIT PRICE	COST
62	Well 1 Demolition and Installation, CIP	LS	1		
63	Well 2 Demolition and Installation, CIP	LS	1		
64	Well 6 Demolition and Installation, CIP	LS	1		
65	Well 7 Demolition and Installation, CIP	LS	1		
66	Well 8 Demolition and Installation, CIP	LS	1		
67	Morgan St. Demolition and Installation, CIP	LS	1		
68	Cemetery St. Demolition and Installation, CIP	LS	1		
69	Cook St. Demolition and Installation, CIP	LS	1		
MECHANICAL					
70	Cook St. Demolition, Plumbing, HVAC and Installation, CIP	LS	1		
CONSTRUCTION SUBTOTAL					\$ -
PROJECT CONTINGENCY (10%)					\$ -
NMGRT (8.5%)					\$ -
TOTAL ESTIMATED PROJECT COSTS					\$ -

B. Bidder acknowledges that:

1. each Bid Unit Price includes an amount considered by Bidder to be adequate to cover Contractor's overhead and profit for each separately identified item, and
2. estimated quantities are not guaranteed, and are solely for the purpose of comparison of Bids, and final payment for all Unit Price Work will be based on actual quantities, determined as provided in the Contract Documents.

3.02 *Total Bid Price (Lump Sum and Unit Prices)*

Total Bid Price (Total of all Lump Sum and Unit Price Bids)	\$
---	----

ARTICLE 4—BASIS OF BID—COST-PLUS FEE “DELETED”

ARTICLE 5—PRICE-PLUS-TIME BID “DELETED”

ARTICLE 6—TIME OF COMPLETION

6.01 Bidder agrees that the Work will be substantially complete and will be completed and ready for final payment in accordance with Paragraph 15.06 of the General Conditions on or before the dates or within the number of calendar days indicated in the Agreement.

6.02 **“Deleted”**

6.03 **“Deleted”**

6.04 Bidder accepts the provisions of the Agreement as to liquidated damages.

ARTICLE 7—BIDDER’S ACKNOWLEDGEMENTS: ACCEPTANCE PERIOD, INSTRUCTIONS, AND RECEIPT OF ADDENDA

7.01 *Bid Acceptance Period*

A. This Bid will remain subject to acceptance for 60 days after the Bid opening, or for such longer period of time that Bidder may agree to in writing upon request of Owner.

7.02 *Instructions to Bidders*

A. Bidder accepts all of the terms and conditions of the Instructions to Bidders, including without limitation those dealing with the disposition of Bid security.

7.03 *Receipt of Addenda*

A. Bidder hereby acknowledges receipt of the following Addenda:

Addendum Number	Addendum Date

ARTICLE 8—BIDDER’S REPRESENTATIONS AND CERTIFICATIONS

8.01 *Bidder’s Representations*

A. In submitting this Bid, Bidder represents the following:

1. Bidder has examined and carefully studied the Bidding Documents, including Addenda.

2. Bidder has visited the Site, conducted a thorough visual examination of the Site and adjacent areas, and become familiar with the general, local, and Site conditions that may affect cost, progress, and performance of the Work.
3. Bidder is familiar with all Laws and Regulations that may affect cost, progress, and performance of the Work, including all American Iron and Steel requirements.
4. Bidder has carefully studied the reports of explorations and tests of subsurface conditions at or adjacent to the Site and the drawings of physical conditions relating to existing surface or subsurface structures at the Site that have been identified in the Supplementary Conditions, with respect to the Technical Data in such reports and drawings.
5. Bidder has carefully studied the reports and drawings relating to Hazardous Environmental Conditions, if any, at or adjacent to the Site that have been identified in the Supplementary Conditions, with respect to Technical Data in such reports and drawings.
6. Bidder has considered the information known to Bidder itself; information commonly known to contractors doing business in the locality of the Site; information and observations obtained from visits to the Site; the Bidding Documents; and the Technical Data identified in the Supplementary Conditions or by definition, with respect to the effect of such information, observations, and Technical Data on (a) the cost, progress, and performance of the Work; (b) the means, methods, techniques, sequences, and procedures of construction to be employed by Bidder, if selected as Contractor; and (c) Bidder's (Contractor's) safety precautions and programs.
7. Based on the information and observations referred to in the preceding paragraph, Bidder agrees that no further examinations, investigations, explorations, tests, studies, or data are necessary for the performance of the Work at the Contract Price, within the Contract Times, and in accordance with the other terms and conditions of the Contract.
8. Bidder is aware of the general nature of work to be performed by Owner and others at the Site that relates to the Work as indicated in the Bidding Documents.
9. Bidder has given Engineer written notice of all conflicts, errors, ambiguities, or discrepancies that Bidder has discovered in the Bidding Documents, and of discrepancies between Site conditions and the Contract Documents, and the written resolution thereof by Engineer is acceptable to Contractor.
10. The Bidding Documents are generally sufficient to indicate and convey understanding of all terms and conditions for performance and furnishing of the Work.
11. The submission of this Bid constitutes an incontrovertible representation by Bidder that without exception the Bid and all prices in the Bid are premised upon performing and furnishing the Work required by the Bidding Documents.

8.02 *Bidder's Certifications*

A. The Bidder certifies the following:

1. This Bid is genuine and not made in the interest of or on behalf of any undisclosed individual or entity and is not submitted in conformity with any collusive agreement or rules of any group, association, organization, or corporation.

2. Bidder has not directly or indirectly induced or solicited any other Bidder to submit a false or sham Bid.
3. Bidder has not solicited or induced any individual or entity to refrain from bidding.
4. Bidder has not engaged in corrupt, fraudulent, collusive, or coercive practices in competing for the Contract. For the purposes of this Paragraph 8.02.A:
 - a. Corrupt practice means the offering, giving, receiving, or soliciting of anything of value likely to influence the action of a public official in the bidding process.
 - b. Fraudulent practice means an intentional misrepresentation of facts made (a) to influence the bidding process to the detriment of Owner, (b) to establish bid prices at artificial non-competitive levels, or (c) to deprive Owner of the benefits of free and open competition.
 - c. Collusive practice means a scheme or arrangement between two or more Bidders, with or without the knowledge of Owner, a purpose of which is to establish bid prices at artificial, non-competitive levels.
 - d. Coercive practice means harming or threatening to harm, directly or indirectly, persons or their property to influence their participation in the bidding process or affect the execution of the Contract.

BIDDER hereby submits this Bid as set forth above:

Bidder:

(typed or printed name of organization)

By:

(individual's signature)

Name:

(typed or printed)

Title:

(typed or printed)

Date:

(typed or printed)

If Bidder is a corporation, a partnership, or a joint venture, attach evidence of authority to sign.

Attest:

(individual's signature)

Name:

(typed or printed)

Title:

(typed or printed)

Date:

(typed or printed)

Address for giving notices:

Bidder's Contact:

Name:

(typed or printed)

Title:

(typed or printed)

Phone:

Email:

Address:

Bidder's Contractor License No.: (if applicable)



LABOR RELATIONS DIVISION

401 Broadway NE
Albuquerque, NM 87102
Phone: 505-841-4400
Fax: 505-841-4424

226 South Alameda Blvd
Las Cruces, NM 88005
Phone: 575-524-6195
Fax: 575-524-6194

WWW.DWS.STATE.NM.US

1596 Pacheco St, Suite 103
Santa Fe, NM 87505
Phone: 505-827-6817
Fax: 505-827-9676

Wage Decision Approval Summary

1) Project Title: Main Street District Waterlines
Requested Date: 03/17/2022
Approved Date: 03/21/2022
Approved Wage Decision Number: SI-22-0735-A/H

Wage Decision Expiration Date for Bids: 07/19/2022

2) Physical Location of Jobsite for Project:
Job Site Address: Downtown/Main Street District
Job Site City: Truth or Consequences
Job Site County: Sierra

3) Contracting Agency Name (Department or Bureau): City of Truth or Consequences
Contracting Agency Contact's Name: Carol Kirkpatrick
Contracting Agency Contact's Phone: (575) 740-7323 Ext.

4) Estimated Bid Opening Date: 11/18/2021

- 5) Estimated total project cost:
 - a. Are any federal funds involved?: Yes -
 - b. Does this project involve a building?: No
 - c. Is this part of a larger plan for construction on or appurtenant to the property that is subject to this project?: No
 - d. Are there any other Public Works Wage Decisions related to this project?: No
 - e. What is the ultimate purpose or functional use of the construction once it is completed?: Potable Water System

6) Classifications of Construction:

Classification Type and Cost Total	Description
Highway/Utilities (A)	Project is to replace 23,600-feet of waterline in the Main Street District (MSD) of the City of Truth or Consequences with 6, 8, and 12-inch PVC waterline via open trench, pipe bursting, and horizontal directional drilling. All service connection will be replaced with new service lines, meter cans, and meters.
Heavy Engineering (H)	Upgrades to the Cook Street Booster Station site to include gas chlorination system, VFD booster pumps with electrical, diesel generator, meter and chlorination injection vaults, SCADA system, and a 300,000 - gallon steel ground water storage tank.



TYPE “A” – STREET, HIGHWAY, UTILITY & LIGHT ENGINEERING

Effective January 1, 2022

Trade Classification	Base Rate	Fringe Rate
Bricklayer/Block layer/Stonemason	24.46	8.81
Carpenter/Lather	26.48	12.14
Carpenter- Los Alamos County	29.24	13.94
Cement Mason	17.74	7.41
Drywall Finisher/Taper	25.21	8.00
Glazier		
Glazier/Fabricator	21.00	6.45
Delivery Driver	11.50	6.45
Ironworker	27.70	17.89
Painter- Commercial	17.75	8.20
Paper Hanger	17.75	8.20
Plumber/Pipefitter	33.10	13.10
Electricians- Outside Classifications: Zone 1		
Ground man	24.57	11.74
Equipment Operator	35.25	16.06
Lineman	44.32	18.08
Journeyman technician	41.47	17.37
Cable Splicer	48.75	19.19
Electricians-Outside Classifications: Zone 2		
Ground man	24.57	11.74
Equipment Operator	35.25	16.06
Lineman	44.32	18.08
Journeyman technician	41.47	17.37
Cable Splicer	48.75	19.19
Electricians-Outside Classifications: Los Alamos		
Ground man	25.27	11.76
Equipment Operator	36.27	16.09

Lineman	45.47	18.36
Journeyman technician	42.41	17.60
Cable Splicer	49.59	19.40
Laborers		
Group I	14.79	6.93
Group II	15.29	6.93
Group III	16.79	6.93
Group IV	17.29	6.93
Operators		
Group I	19.93	6.74
Group II	20.92	6.74
Group III	21.02	6.74
Group IV	21.14	6.74
Group V	21.24	6.74
Group VI	21.44	6.74
Group VII	21.61	6.74
Group VIII	21.92	6.74
Group IX	29.87	6.74
Group X	33.32	6.74
Soft Floor Layers	20.75	8.45
Truck Drivers		
Group I-IX	17.65	8.72

NOTE: All contractors are required to pay SUBSISTENCE, ZONE AND INCENTIVE PAY according to the particular trade. Details are located in a PDF attachment at WWW.DWS.STATE.NM.US. Search Labor Relations/Labor Information/Public Works/Prevailing Wage Rates.

For more information about the Subsistence, Zone, and Incentive Pay rates, or to file a wage claim, contact the Labor Relations Division at (505) 841-4400 or visit us online at www.dws.state.nm.us.



TYPE “H” – HEAVY ENGINEERING

Effective January 1, 2022

Trade Classification	Base Rate	Fringe Rate	Apprenticeship
Asbestos workers/Heat & Frost Insulators	34.51	12.06	0.60
Asbestos workers/Heat & Frost Insulators: Los Alamos County	36.94	12.06	0.60
Boilermaker/blacksmith	34.88	32.28	0.60
Boilermaker/blacksmith: San Juan County	35.83	31.88	0.60
Bricklayer/Block layer/Stonemason	25.54	8.81	0.60
Carpenter/Lather	26.48	12.14	0.60
Carpenter: Los Alamos County	29.24	13.94	0.60
Millwright/pile driver	35.08	27.57	0.60
Cement Mason	22.30	7.41	0.60
Electricians-Outside Classifications: Zone 1			
Ground man	24.57	11.74	0.60
Equipment Operator	35.25	16.06	0.60
Lineman/technician	44.32	18.08	0.60
Cable Splicer	48.75	19.19	0.60
Electricians-Outside Classifications: Zone 2			
Ground man	24.57	11.74	0.60
Equipment Operator	35.25	16.06	0.60
Lineman/technician	44.32	18.08	0.60
Cable Splicer	48.75	19.19	0.60
Electricians-Outside Classifications: Los Alamos			
Ground man	25.27	11.76	0.60
Equipment Operator	36.27	16.09	0.60
Lineman/technician	45.47	18.36	0.60
Cable Splicer	49.59	19.40	0.60

Electricians-Inside Classifications: Zone 1			
Wireman/low voltage technician	35.20	12.21	0.60
Cable Splicer	38.72	12.31	0.60
Electricians-Inside Classifications: Zone 2			
Wireman/low voltage technician	38.37	12.30	0.60
Cable Splicer	41.89	12.41	0.60
Electricians-Inside Classifications: Zone 3			
Wireman/low voltage technician	40.48	12.36	0.60
Cable Splicer	44.00	12.47	0.60
Electricians-Inside Classifications: Zone 4			
Wireman/low voltage technician	44.35	12.48	0.60
Cable Splicer	47.87	12.58	0.60
Electricians – Inside Classifications: Dona Ana, Hidalgo, Luna and Otero Counties			
Wireman/low voltage technician	31.42	8.87	0.60
Cable Splicer	30.77	8.64	0.60
Electricians-Inside Classifications: Los Alamos			
Wireman/low voltage technician	40.48	14.38	0.60
Cable Splicer	44.00	14.67	0.60
Glazier			
Glazier/Fabricator	21.00	6.45	0.60
Delivery Driver	11.50	6.45	0.60
Ironworker	27.70	17.89	0.60
Painter- Industrial	22.00	10.05	0.60
Paperhanger	19.50	10.05	0.60
Drywall Finisher/Taper - Industrial			
Ames tool Operator	27.06	8.00	0.60
Hand finisher/machine texture	26.06	8.00	0.60
Plumber/Pipefitter	36.40	14.25	0.60
Roofer	26.34	9.16	0.60
Sheet metal Worker	34.54	17.92	0.60
Operators			
Group I	21.81	6.74	0.60
Group II	22.01	6.74	0.60

Group III	22.22	6.74	0.60
Group IV	22.36	6.74	0.60
Group V	22.47	6.74	0.60
Group VI	22.67	6.74	0.60
Group VII	22.69	6.74	0.60
Group VIII	24.71	6.74	0.60
Group IX	30.72	6.74	0.60
Group X	34.15	6.74	0.60
Laborers			
Group I-Unskilled	19.18	6.93	0.60
Group II-Semi-Skilled	20.06	6.93	0.60
Group III-Skilled	21.93	6.93	0.60
Group IV-Specialty	22.30	6.93	0.60
Laborers-Underground			
Group I	21.43	6.93	0.60
Group II	21.85	6.93	0.60
Group III	22.26	6.93	0.60
Soft Floor Layer	20.75	8.45	0.60
Truck Drivers			
Group I	17.65	8.72	0.60
Group II	17.65	8.72	0.60
Group III	17.65	8.72	0.60
Group IV	17.65	8.72	0.60
Group V	17.65	8.72	0.60
Group VI	17.65	8.72	0.60
Group VII	17.65	8.72	0.60
Group VIII	17.71	8.72	0.60
Group IX	19.65	8.72	0.60
Maintenance Sub Group IX			
Rate I	20.90	9.00	0.60
Rate II	21.77	9.00	0.60
Rate III	22.24	9.00	0.60

NOTE: All contractors are required to pay SUBSISTENCE, ZONE AND INCENTIVE PAY according to the particular trade. Details are located in a PDF attachment at WWW.DWS.STATE.NM.US. Search Labor Relations/Labor Information/Public Works/Prevailing Wage Rates.

For more information about the Subsistence, Zone, and Incentive Pay rates, or to file a wage claim, contact the Labor Relations Division at (505) 841-4400 or visit us online at www.dws.state.nm.us.