



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Keith Langlotz
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

5/24/2021

Phone: (716) 626-8860
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/11/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012105003. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012105003
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-100
 Hallway Fountain Across from Room 100
Collected: 5/1/2021 6:43:00 AM
Lab ID: 012105003-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:49

Client Sample Description CP-101
 Room 100 Classroom Sink
Collected: 5/1/2021 6:15:00 AM
Lab ID: 012105003-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.74	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:53

Client Sample Description CP-103
 Library Office Sink
Collected: 5/1/2021 6:38:00 AM
Lab ID: 012105003-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.6	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:55

Client Sample Description CP-104
 Room 101 Classrom Sink #1
Collected: 5/1/2021 6:17:00 AM
Lab ID: 012105003-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.1	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:56

Client Sample Description CP-105
 Room 101 Classrom Sink #2
Collected: 5/1/2021 6:20:00 AM
Lab ID: 012105003-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.98	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:00

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012105003
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-107
 Room 102 Classrom Sink #1
Collected: 5/1/2021 6:21:00 AM
Lab ID: 012105003-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	25.6	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:01

Client Sample Description CP-108
 Room 102 Classrom Sink #2
Collected: 5/1/2021 6:22:00 AM
Lab ID: 012105003-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.29	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:03

Client Sample Description CP-110
 Room 103 Classrom Sink
Collected: 5/1/2021 6:23:00 AM
Lab ID: 012105003-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.7	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:04

Client Sample Description CP-112
 Room 104 Classrom Sink
Collected: 5/1/2021 6:25:00 AM
Lab ID: 012105003-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.42	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:05

Client Sample Description CP-114
 Room 105 Classrom Sink
Collected: 5/1/2021 6:25:00 AM
Lab ID: 012105003-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.01	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012105003
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-116 Room 106 Classrom Sink **Collected:** 5/1/2021 6:26:00 AM **Lab ID:** 012105003-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.2	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:08

Client Sample Description CP-118 Room 107 Classrom Sink **Collected:** 5/1/2021 6:28:00 AM **Lab ID:** 012105003-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.2	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:12

Client Sample Description CP-120 Room 108 Classrom Sink **Collected:** 5/1/2021 6:30:00 AM **Lab ID:** 012105003-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.4	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:16

Client Sample Description CP-122 Room 109 Classrom Sink **Collected:** 5/1/2021 6:33:00 AM **Lab ID:** 012105003-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.99	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:17

Client Sample Description CP-124 Room 110 Classrom Sink **Collected:** 5/1/2021 6:31:00 AM **Lab ID:** 012105003-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	25.0	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:18

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	012105003
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-126
Room 111 Classrom Sink
Collected: 5/1/2021 6:33:00 AM
Lab ID: 012105003-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.82	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:20

Client Sample Description CP-128
Room 112 Classrom Sink
Collected: 5/1/2021
Lab ID: 012105003-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.30	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:21

Client Sample Description CP-130
Room 113 Classrom Sink
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012105003-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.2	1.00 µg/L	5/20/2021 JD	5/21/2021 JW 14:02

Client Sample Description CP-132
Room 114 Classrom Sink
Collected: 5/1/2021 6:37:00 AM
Lab ID: 012105003-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.43	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:22

Client Sample Description CP-134
Room 115 Classrom Sink
Collected: 5/1/2021 6:39:00 AM
Lab ID: 012105003-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.65	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:23

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012105003
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-136 **Collected:** 5/1/2021 **Lab ID:** 012105003-0021
 Hallway Fountain Across from Room 115 6:41:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:25

Client Sample Description CP-137 **Collected:** 5/1/2021 **Lab ID:** 012105003-0022
 Speech Office Sink 6:43:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.6	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:33

Client Sample Description CP-138 **Collected:** 5/1/2021 **Lab ID:** 012105003-0023
 Main Office Sink 6:44:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.9	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:36

Client Sample Description CP-139 **Collected:** 5/1/2021 **Lab ID:** 012105003-0024
 Boys Bathroom Main Hallway 7:35:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.61	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:38

Client Sample Description CP-140 **Collected:** 5/1/2021 **Lab ID:** 012105003-0025
 Clinic Sink 6:44:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.83	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:39

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012105003
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-141
 Clinic Bathroom Sink
Collected: 5/1/2021 6:45:00 AM
Lab ID: 012105003-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.98	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:40

Client Sample Description CP-142
 Main Office Bathroom Sink
Collected: 5/1/2021 6:46:00 AM
Lab ID: 012105003-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.98	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:42

Client Sample Description CP-145
 Boys Locker Room Bathroom Sink #1
Collected: 5/1/2021 7:28:00 AM
Lab ID: 012105003-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.18	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:43

Client Sample Description CP-146
 Girls Locker Room Bathroom Sink #1
Collected: 5/1/2021 7:27:00 AM
Lab ID: 012105003-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.18	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:47

Client Sample Description CP-147
 Girls Locker Room Bathroom Sink #2
Collected: 5/1/2021 7:27:00 AM
Lab ID: 012105003-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.06	1.00 µg/L	5/20/2021 JD	5/21/2021 JW 14:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012105003
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-148
 Hallway Fountain by Computer Lab in 4th Grade
Collected: 5/1/2021 6:51:00 AM
Lab ID: 012105003-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:48

Client Sample Description CP-149
 Café Sink
Collected: 5/1/2021 6:53:00 AM
Lab ID: 012105003-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.22	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:50

Client Sample Description CP-150
 Faculty Lounge Sink
Collected: 5/1/2021 6:52:00 AM
Lab ID: 012105003-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.24	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:51

Client Sample Description CP-151
 Room 116 Classrom Sink
Collected: 5/1/2021 6:52:00 AM
Lab ID: 012105003-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.0	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:55

Client Sample Description CP-153
 Room 117 Classrom Sink
Collected: 5/1/2021 6:53:00 AM
Lab ID: 012105003-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	29.0	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:56

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012105003
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-155 **Collected:** 5/1/2021 **Lab ID:** 012105003-0036
 Room 118 Classrom Sink 6:54:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.9	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:57

Client Sample Description CP-157 **Collected:** 5/1/2021 **Lab ID:** 012105003-0037
 Room 119 Classrom Sink 6:55:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.6	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:59

Client Sample Description CP-158 **Collected:** 5/1/2021 **Lab ID:** 012105003-0038
 Room 120 Classrom Sink 6:55:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.70	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 03:03

Client Sample Description CP-160 **Collected:** 5/1/2021 **Lab ID:** 012105003-0039
 Room 121 Classrom Sink 7:00:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.7	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 03:04

Client Sample Description CP-162 **Collected:** 5/1/2021 **Lab ID:** 012105003-0040
 Room 123 Classrom Sink 6:57:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.9	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 03:05

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012105003
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: **2021 Lead in Water Testing**

Analytical Results

Client Sample Description CP-164
 Room 122 Classrom Sink **Collected:** 5/1/2021 7:00:00 AM **Lab ID:** 012105003-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	24.6	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 03:07

Client Sample Description CP-166
 Room 124 Classrom Sink **Collected:** 5/1/2021 7:00:00 AM **Lab ID:** 012105003-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.6	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 03:08

Client Sample Description CP-168
 Room 125 Classrom Sink **Collected:** 5/1/2021 7:00:00 AM **Lab ID:** 012105003-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	20.0	1.00 µg/L	5/20/2021 JD	5/21/2021 JW 14:06

Client Sample Description CP-170
 Room 126 Classrom Sink **Collected:** 5/1/2021 7:01:00 AM **Lab ID:** 012105003-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.14	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:36

Client Sample Description CP-172
 Room 127 Classrom Sink **Collected:** 5/1/2021 7:00:00 AM **Lab ID:** 012105003-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.5	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:42

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012105003
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-174
 Room 128 Classrom Sink **Collected:** 5/1/2021 7:01:00 AM **Lab ID:** 012105003-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.81	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:44

Client Sample Description CP-176
 Room 129 Classrom Sink **Collected:** 5/1/2021 7:03:00 AM **Lab ID:** 012105003-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.4	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:45

Client Sample Description CP-178
 Hallway Fountain Across from Room 129 **Collected:** 5/1/2021 7:03:00 AM **Lab ID:** 012105003-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:46

Client Sample Description CP-179
 Room 150 Classrom Sink **Collected:** 5/1/2021 7:05:00 AM **Lab ID:** 012105003-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.99	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:47

Client Sample Description CP-180
 Hallway Fountain Across from Room 139 **Collected:** 5/1/2021 7:08:00 AM **Lab ID:** 012105003-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:49

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012105003
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-181 Boys Bathroom Across from Room 139 Sink
Collected: 5/1/2021 7:07:00 AM
Lab ID: 012105003-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.86	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:50

Client Sample Description CP-182 Boys Bathroom Across from Room 139 Sink
Collected: 5/1/2021 7:08:00 AM
Lab ID: 012105003-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.94	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:51

Client Sample Description CP-183 OT/PT Classroom Sink
Collected: 5/1/2021 7:10:00 AM
Lab ID: 012105003-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:53

Client Sample Description CP-184 Faculty Bathroom Sink #1
Collected: 5/1/2021 7:10:00 AM
Lab ID: 012105003-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.96	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:57

Client Sample Description CP-185 Faculty Bathroom Sink #2
Collected: 5/1/2021 7:10:00 AM
Lab ID: 012105003-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.18	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:01

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105003

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-186 **Collected:** 5/1/2021 **Lab ID:** 012105003-0056
 Room 130 Classroom Sink 7:12:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.19	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:02

Client Sample Description CP-188 **Collected:** 5/1/2021 **Lab ID:** 012105003-0057
 Room 131 Classroom Sink 7:13:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.02	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:03

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results