



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Keith Langlotz
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

5/24/2021

Phone: (716) 626-8860
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/11/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012104945. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104945
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-100
 Hallway Fountain by Main Office
Collected: 5/1/2021 6:30:00 AM
Lab ID: 012104945-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:54

Client Sample Description DE-101
 Room 120 Bathroom Sink
Collected: 5/1/2021 6:34:00 AM
Lab ID: 012104945-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.34	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:58

Client Sample Description DE-102
 Room 103 Classroom Sink
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012104945-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.87	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:00

Client Sample Description DE-104
 Room 103 Bathroom Sink
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012104945-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.09	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:01

Client Sample Description DE-105
 Room 106 Bathroom Sink
Collected: 5/1/2021 6:39:00 AM
Lab ID: 012104945-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.05	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:05

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	012104945
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-107
Room 106 Bathroom Sink
Collected: 5/1/2021 6:45:00 AM
Lab ID: 012104945-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.7	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:06

Client Sample Description DE-108
Room 105 Bathroom Sink
Collected: 5/1/2021 6:43:00 AM
Lab ID: 012104945-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:07

Client Sample Description DE-110
Room 105 Bathroom Sink
Collected: 5/1/2021 7:00:00 AM
Lab ID: 012104945-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.1	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:09

Client Sample Description DE-111
Room 108 Bathroom Sink
Collected: 5/1/2021 6:57:00 AM
Lab ID: 012104945-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:10

Client Sample Description DE-113
Room 108 Bathroom Sink
Collected: 5/1/2021 6:57:00 AM
Lab ID: 012104945-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.64	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:11

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104945
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-114
 Room 107 Bathroom Sink **Collected:** 5/1/2021 6:52:00 AM **Lab ID:** 012104945-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.77	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:13

Client Sample Description DE-116
 Room 107 Bathroom Sink **Collected:** 5/1/2021 6:52:00 AM **Lab ID:** 012104945-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.90	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:17

Client Sample Description DE-117
 Room 110 Bathroom Sink **Collected:** 5/1/2021 6:52:00 AM **Lab ID:** 012104945-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.14	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:21

Client Sample Description DE-119
 Room 110 Bathroom Sink **Collected:** 5/1/2021 6:51:00 AM **Lab ID:** 012104945-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.60	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:22

Client Sample Description DE-120
 Room 109 Bathroom Sink **Collected:** 5/1/2021 6:54:00 AM **Lab ID:** 012104945-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.67	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:23

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	012104945
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-122
Room 109 Bathroom Sink
Collected: 5/1/2021 6:54:00 AM
Lab ID: 012104945-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.6	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:24

Client Sample Description DE-123
Room 112 Bathroom Sink
Collected: 5/1/2021 6:55:00 AM
Lab ID: 012104945-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.97	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:26

Client Sample Description DE-125
Room 112 Bathroom Sink
Collected: 5/1/2021 6:55:00 AM
Lab ID: 012104945-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.87	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:27

Client Sample Description DE-126
Room 121 Bathroom Sink #1
Collected: 5/1/2021 7:02:00 AM
Lab ID: 012104945-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:28

Client Sample Description DE-127
Room 121 Bathroom Sink #2
Collected: 5/1/2021 7:02:00 AM
Lab ID: 012104945-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:30

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104945
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-128 Room 122 Bathroom Sink **Collected:** 5/1/2021 7:03:00 AM **Lab ID:** 012104945-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.22	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:40

Client Sample Description DE-130 Room 123 Bathroom Sink **Collected:** 5/1/2021 7:04:00 AM **Lab ID:** 012104945-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:44

Client Sample Description DE-131 Room 124 Bathroom Sink **Collected:** 5/1/2021 7:04:00 AM **Lab ID:** 012104945-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:45

Client Sample Description DE-133 Room 125 Bathroom Sink **Collected:** 5/1/2021 7:05:00 AM **Lab ID:** 012104945-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:47

Client Sample Description DE-135 Room 126 Bathroom Sink **Collected:** 5/1/2021 7:06:00 AM **Lab ID:** 012104945-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.34	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:48

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104945
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-137 Room 127 Bathroom Sink **Collected:** 5/1/2021 7:07:00 AM **Lab ID:** 012104945-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:52

Client Sample Description DE-139 Room 128 Bathroom Sink **Collected:** 5/1/2021 **Lab ID:** 012104945-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:53

Client Sample Description DE-141 Room 129 Bathroom Sink **Collected:** 5/1/2021 7:09:00 AM **Lab ID:** 012104945-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:55

Client Sample Description DE-143 Hallway Fountain Across from Room 121 **Collected:** 5/1/2021 7:10:00 AM **Lab ID:** 012104945-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:56

Client Sample Description DE-144 Mens Bathroom by Room 121 Sink **Collected:** 5/1/2021 7:11:00 AM **Lab ID:** 012104945-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:57

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104945
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-145 **Collected:** 5/1/2021 **Lab ID:** 012104945-0031
 Womens Bathroom by Room 121 Sink 7:11:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.08	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:58

Client Sample Description DE-146 **Collected:** 5/1/2021 **Lab ID:** 012104945-0032
 Mens Bathroom by Room 120 Sink 7:12:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:02

Client Sample Description DE-147 **Collected:** 5/1/2021 **Lab ID:** 012104945-0033
 Womens Bathroom by Room 120 Sink 7:12:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:04

Client Sample Description DE-148 **Collected:** 5/1/2021 **Lab ID:** 012104945-0034
 Room 120 Bathroom Sink 7:12:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:08

Client Sample Description DE-149 **Collected:** 5/1/2021 **Lab ID:** 012104945-0035
 Café Sink 7:14:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.83	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:09

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104945
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-150 Café Fountain **Collected:** 5/1/2021 7:14:00 AM **Lab ID:** 012104945-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:10

Client Sample Description DE-151 Clinic Sink **Collected:** 5/1/2021 7:16:00 AM **Lab ID:** 012104945-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.2	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:12

Client Sample Description DE-152 Clinic Bathroom Sink **Collected:** 5/1/2021 7:16:00 AM **Lab ID:** 012104945-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.3	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:13

Client Sample Description DE-153 Mens Bathroom across from Gym Sink **Collected:** 5/1/2021 7:18:00 AM **Lab ID:** 012104945-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:14

Client Sample Description DE-154 Womens Bathroom across from Gym Sink **Collected:** 5/1/2021 7:18:00 AM **Lab ID:** 012104945-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.83	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:15

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104945
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-155
Boys Locker Room Sink #1
Collected: 5/1/2021 7:15:00 AM
Lab ID: 012104945-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:23

Client Sample Description DE-156
Boys Locker Room Sink #2
Collected: 5/1/2021 7:15:00 AM
Lab ID: 012104945-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.48	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:27

Client Sample Description DE-157
Boys Locker Room Coaches Office Sink
Collected: 5/1/2021 7:20:00 AM
Lab ID: 012104945-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.7	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:29

Client Sample Description DE-158
Boys Bathroom by Room 137 Sink #1
Collected: 5/1/2021 7:46:00 AM
Lab ID: 012104945-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.44	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:30

Client Sample Description DE-159
Boys Bathroom by Room 137 Sink #2
Collected: 5/1/2021 7:46:00 AM
Lab ID: 012104945-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.35	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:31

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104945
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-160 Boys Bathroom by Room 137 Sink #3 **Collected:** 5/1/2021 7:46:00 AM **Lab ID:** 012104945-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.66	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:32

Client Sample Description DE-161 Bathroom by Room 132 Sink #1 **Collected:** 5/1/2021 7:26:00 AM **Lab ID:** 012104945-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.10	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:34

Client Sample Description DE-162 Bathroom by Room 132 Sink #2 **Collected:** 5/1/2021 7:26:00 AM **Lab ID:** 012104945-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.45	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:35

Client Sample Description DE-163 Room 132 Classroom Sink **Collected:** 5/1/2021 7:48:00 AM **Lab ID:** 012104945-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.13	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:39

Client Sample Description DE-164 Room 130 Classroom Sink **Collected:** 5/1/2021 7:27:00 AM **Lab ID:** 012104945-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.96	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:40

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	012104945
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description	DE-165 Bathroom by Room 131 Sink #1	Collected:	5/1/2021 7:29:00 AM	Lab ID:	012104945-0051
----------------------------------	--	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.03	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:42

Client Sample Description	DE-166 Bathroom by Room 131 Sink #2	Collected:	5/1/2021 7:30:00 AM	Lab ID:	012104945-0052
----------------------------------	--	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.41	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:45

Client Sample Description	DE-169 Room 133 Classroom Sink	Collected:	5/1/2021 7:33:00 AM	Lab ID:	012104945-0053
----------------------------------	-----------------------------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.1	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:47

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results