

Williamsville CSD

Locations of Water Test Samples Greater than 15 ppb

NOTE: Fixture replacement is being prioritized by our facility staff and is occurring in an expedited manner. New water samples are sent to the testing lab with an accelerated turn-around time.

| | | | | | | | |
|-------------------|--------------------|---------------------|------------------------|-------------------|-----------------------|-------------------|---------------------|
| Maple East | | | | | | | |
| Location | Boiler Room Sample | Boiler Room Eyewash | Girl's ShBathroom Sink | 42 Classroom Sink | 29 Classroom Sink # 3 | 22 Classroom Sink | Library Office Sink |
| Test results | 18.10 | 47.40 | 1220.00 | 16.20 | 52.30 | 17.30 | 22.30 |
| Remediation | | | | | | | |
| Results | | | | | | | |
| Back in use | | | | | | | |
| Location | | | | | | | |
| Test results | | | | | | | |
| Remediation | | | | | | | |
| Results | | | | | | | |
| Results | | | | | | | |
| Back in use | | | | | | | |