



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Keith Langlotz
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

5/24/2021

Phone: (716) 626-8860
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/11/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012104879. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104879

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-100
Hallway Fountain by Room 129
Collected: 5/1/2021 6:42:00 AM
Lab ID: 012104879-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:34

Client Sample Description MW-101
Room 128 Classroom Sink
Collected: 5/1/2021 6:43:00 AM
Lab ID: 012104879-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.55	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:38

Client Sample Description MW-103
Room 127 Classroom Sink
Collected: 5/1/2021 6:44:00 AM
Lab ID: 012104879-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.31	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:39

Client Sample Description MW-105
Classroom 126 sink
Collected: 5/1/2021 6:45:00 AM
Lab ID: 012104879-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.47	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:40

Client Sample Description MW-107
Room 125 Classroom Sink
Collected: 5/1/2021 6:46:00 AM
Lab ID: 012104879-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.62	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:42

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104879
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: **2021 Lead in Water Testing**

Analytical Results

Client Sample Description MW-109
 Room 124 Classroom Sink
Collected: 5/1/2021 6:47:00 AM
Lab ID: 012104879-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.53	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:45

Client Sample Description MW-111
 Room 121 Classroom Sink
Collected: 5/1/2021 6:48:00 AM
Lab ID: 012104879-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.74	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:47

Client Sample Description MW-113
 Room 123 Classroom Sink
Collected: 5/1/2021 6:48:00 AM
Lab ID: 012104879-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.54	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:48

Client Sample Description MW-116
 Girls Lav by Gym Bathroom Sink #1
Collected: 5/1/2021 6:53:00 AM
Lab ID: 012104879-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.74	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:49

Client Sample Description MW-117
 Girls Lav by Gym Bathroom Sink #2
Collected: 5/1/2021 6:53:00 AM
Lab ID: 012104879-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.83	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:51

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104879
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-118
 Girls Lav by Gym Bathroom Sink #3
Collected: 5/1/2021 6:53:00 AM
Lab ID: 012104879-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.20	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:52

Client Sample Description MW-121
 Boys Lav by Gym Bathroom Sink #1
Collected: 5/1/2021 6:55:00 AM
Lab ID: 012104879-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.13	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:56

Client Sample Description MW-122
 Boys Lav by Gym Bathroom Sink #2
Collected: 5/1/2021 6:56:00 AM
Lab ID: 012104879-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.39	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:57

Client Sample Description MW-123
 Boys Lav by Gym Bathroom Sink #3
Collected: 5/1/2021 6:56:00 AM
Lab ID: 012104879-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.32	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:01

Client Sample Description MW-124
 Room 120 Classroom Sink
Collected: 5/1/2021 7:02:00 AM
Lab ID: 012104879-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.74	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:02

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104879

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-126
Room 122 Classroom Sink
Collected: 5/1/2021 7:03:00 AM
Lab ID: 012104879-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.37	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:04

Client Sample Description MW-128
Room 119 Classroom Sink
Collected: 5/1/2021 7:05:00 AM
Lab ID: 012104879-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.35	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:05

Client Sample Description MW-130
Room 118 Classroom Sink
Collected: 5/1/2021 7:04:00 AM
Lab ID: 012104879-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.71	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:06

Client Sample Description MW-132
Room 117 Classroom Sink
Collected: 5/1/2021 7:07:00 AM
Lab ID: 012104879-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.42	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:08

Client Sample Description MW-134
Room 116 Classroom Sink
Collected: 5/1/2021 7:08:00 AM
Lab ID: 012104879-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.84	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:09

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104879
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-136
Custodial Bathroom sink
Collected: 5/1/2021 7:52:00 AM
Lab ID: 012104879-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.30	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:17

Client Sample Description MW-137
Hand Sink Receiving
Collected: 5/1/2021 7:52:00 AM
Lab ID: 012104879-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.60	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:21

Client Sample Description MW-138
Kitchen Bathroom Sink
Collected: 5/1/2021 7:52:00 AM
Lab ID: 012104879-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:22

Client Sample Description MW-139
Kitchen Sink #1
Collected: 5/1/2021 6:25:00 AM
Lab ID: 012104879-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.37	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:23

Client Sample Description MW-140
Room 10 Classroom Sink
Collected: 5/1/2021 7:58:00 AM
Lab ID: 012104879-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.29	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:25

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104879
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: **2021 Lead in Water Testing**

Analytical Results

Client Sample Description MW-142
 Hallway Fountain by Room 138
Collected: 5/1/2021 6:38:00 AM
Lab ID: 012104879-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:26

Client Sample Description MW-143
 Boys Lav by Room 137 Bathroom Sink
Collected: 5/1/2021 6:26:00 AM
Lab ID: 012104879-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.93	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:27

Client Sample Description MW-144
 Room 138 Classroom Sink
Collected: 5/1/2021 6:23:00 AM
Lab ID: 012104879-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:29

Client Sample Description MW-145
 Room 137 Classroom Sink
Collected: 5/1/2021 6:27:00 AM
Lab ID: 012104879-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:33

Client Sample Description MW-146
 Faculty Mens Bathroom Sink #1
Collected: 5/1/2021 6:37:00 AM
Lab ID: 012104879-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:34

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104879
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-147
 Faculty Womens Bathroom Sink #2
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012104879-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.35	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:35

Client Sample Description MW-148
 Conference Room Sink
Collected: 5/1/2021 6:37:00 AM
Lab ID: 012104879-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.01	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:39

Client Sample Description MW-149
 Room 136 Classroom Sink
Collected: 5/1/2021 6:30:00 AM
Lab ID: 012104879-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:41

Client Sample Description MW-151
 Room 137 Bathroom Sink
Collected: 5/1/2021 6:29:00 AM
Lab ID: 012104879-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.21	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:42

Client Sample Description MW-152
 Room 135 Classroom Sink
Collected: 5/1/2021 6:31:00 AM
Lab ID: 012104879-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:43

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104879

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-154
Room 134 Classroom Sink
Collected: 5/1/2021 6:32:00 AM
Lab ID: 012104879-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.33	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:44

Client Sample Description MW-156
Room 133 Classroom Sink
Collected: 5/1/2021 6:32:00 AM
Lab ID: 012104879-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:48

Client Sample Description MW-158
Room 132 Classroom Sink
Collected: 5/1/2021 6:33:00 AM
Lab ID: 012104879-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:50

Client Sample Description MW-160
Room 131 Classroom Sink
Collected: 5/1/2021 6:34:00 AM
Lab ID: 012104879-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:51

Client Sample Description MW-162
Room 130 Classroom Sink
Collected: 5/1/2021 6:34:00 AM
Lab ID: 012104879-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:52

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104879
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-164
 Room 129 Classroom Sink
Collected: 5/1/2021 6:41:00 AM
Lab ID: 012104879-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.77	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:46

Client Sample Description MW-166
 Faculty Room Sink
Collected: 5/1/2021 7:10:00 AM
Lab ID: 012104879-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.25	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:50

Client Sample Description MW-168
 Staff Bathroom by Gym Bathroom Sink #1
Collected: 5/1/2021 7:43:00 AM
Lab ID: 012104879-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.95	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:52

Client Sample Description MW-169
 Staff Bathroom by Gym Bathroom Sink #2
Collected: 5/1/2021 7:43:00 AM
Lab ID: 012104879-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.11	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:53

Client Sample Description MW-170
 Room 115 Classroom Sink
Collected: 5/1/2021 7:13:00 AM
Lab ID: 012104879-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.14	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:54

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104879
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-172 Collected: 5/1/2021 Lab ID: 012104879-0046
 Hallway Fountain by Room 115 7:14:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:56

Client Sample Description MW-173 Collected: 5/1/2021 Lab ID: 012104879-0047
 Room 114 Classroom Sink 7:15:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.66	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:57

Client Sample Description MW-175 Collected: 5/1/2021 Lab ID: 012104879-0048
 Room 113 Classroom Sink #1 7:16:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.74	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:58

Client Sample Description MW-176 Collected: 5/1/2021 Lab ID: 012104879-0049
 Room 113 Classroom Sink #2 7:16:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:02

Client Sample Description MW-178 Collected: 5/1/2021 Lab ID: 012104879-0050
 Room 112 Classroom Sink #1 7:17:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.53	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:03

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012104879
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-180 **Collected:** 5/1/2021 **Lab ID:** 012104879-0051
 Room 111 Classroom Sink #1 7:18:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.81	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:05

Client Sample Description MW-182 **Collected:** 5/1/2021 **Lab ID:** 012104879-0052
 Room 110 Classroom Sink #1 7:19:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.41	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:09

Client Sample Description MW-184 **Collected:** 5/1/2021 **Lab ID:** 012104879-0053
 Room 109 Classroom Sink #1 7:20:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.4	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:10

Client Sample Description MW-186 **Collected:** 5/1/2021 **Lab ID:** 012104879-0054
 Room 107 Classroom Sink 7:21:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.06	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:11

Client Sample Description MW-188 **Collected:** 5/1/2021 **Lab ID:** 012104879-0055
 Hallway Fountain by Room 100 7:23:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:13

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104879

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860

Fax:

Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-189 **Collected:** 5/1/2021 **Lab ID:** 012104879-0056
 Library Office Sink 7:24:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.1	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:14

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results