



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Keith Langlotz
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107324. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	012107324
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-100
Boiler Room Source Sample
Collected: 6/12/2021 6:15:00 AM
Lab ID: 012107324-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.72	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:13

Client Sample Description EH-101
Custodial Area Bathroom Sink
Collected: 6/12/2021 6:21:00 AM
Lab ID: 012107324-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.31	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:17

Client Sample Description EH-102
Pool Chemical Room eye wash
Collected: 6/12/2021 6:22:00 AM
Lab ID: 012107324-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2080 D	50.0 µg/L	7/9/2021 JD	7/12/2021 JW 20:22

Client Sample Description EH-103
Men Faculty Lav/Blue Com Sink
Collected: 6/12/2021 6:23:00 AM
Lab ID: 012107324-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:18

Client Sample Description EH-104
Women Faculty Lav/Blue Com Sink
Collected: 6/12/2021 6:24:00 AM
Lab ID: 012107324-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:19

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107324
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-105
 Green Girls Lav Sink # 1
Collected: 6/12/2021 6:27:00 AM
Lab ID: 012107324-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.56	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:23

Client Sample Description EH-106
 Green Girls Lav Sink # 2
Collected: 6/12/2021 6:27:00 AM
Lab ID: 012107324-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.55	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:24

Client Sample Description EH-107
 Green Boys Lav Sink # 1
Collected: 6/12/2021 6:35:00 AM
Lab ID: 012107324-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:26

Client Sample Description EH-108
 Green Boys Lav Sink # 2
Collected: 6/12/2021 6:26:00 AM
Lab ID: 012107324-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:27

Client Sample Description EH-110
 Water Fountain in Common # 2
Collected: 6/12/2021 6:29:00 AM
Lab ID: 012107324-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:28

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107324
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-111
 Water Fountain in Common # 3
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107324-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:30

Client Sample Description EH-112
 Kitchen Sink # 1
Collected: 6/12/2021 6:26:00 AM
Lab ID: 012107324-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:31

Client Sample Description EH-113
 Kitchen Sink # 2
Collected: 6/12/2021 6:26:00 AM
Lab ID: 012107324-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.00	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:35

Client Sample Description EH-114
 Kitchen Sink # 3
Collected: 6/12/2021 6:30:00 AM
Lab ID: 012107324-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.63	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 12:31

Client Sample Description EH-116
 Kitchen Sink # 5
Collected: 6/12/2021 6:31:00 AM
Lab ID: 012107324-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	20.2	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:41

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107324
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-117
 Kitchen Sink # 6
Collected: 6/12/2021 6:31:00 AM
Lab ID: 012107324-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.2	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:42

Client Sample Description EH-118
 Kitchen Sink # 7
Collected: 6/12/2021 6:31:00 AM
Lab ID: 012107324-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.9	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:43

Client Sample Description EH-119
 Kitchen Sink # 8
Collected: 6/12/2021 6:32:00 AM
Lab ID: 012107324-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	27.5	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:45

Client Sample Description EH-120
 Kitchen Sink # 9
Collected: 6/12/2021 6:32:00 AM
Lab ID: 012107324-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.62	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:46

Client Sample Description EH-121
 Kitchen Bathroom Sink
Collected: 6/12/2021 6:28:00 AM
Lab ID: 012107324-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.12	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:47

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107324
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-122
 Room 102 Sink # 1 **Collected:** 6/12/2021 6:41:00 AM **Lab ID:** 012107324-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.6	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:48

Client Sample Description EH-123
 Room 103 Sink # 2 **Collected:** 6/12/2021 6:42:00 AM **Lab ID:** 012107324-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.48	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:56

Client Sample Description EH-124
 Room 103 Sink # 3 **Collected:** 6/12/2021 6:42:00 AM **Lab ID:** 012107324-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.0	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:00

Client Sample Description EH-125
 Room 103 Sink # 4 **Collected:** 6/12/2021 6:43:00 AM **Lab ID:** 012107324-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	20.4	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:02

Client Sample Description EH-126
 Room 101 Sink **Collected:** 6/12/2021 6:42:00 AM **Lab ID:** 012107324-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.95	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:03

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	012107324
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-127
Kiln Roon Sink
Collected: 6/12/2021 6:46:00 AM
Lab ID: 012107324-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	30.4	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:04

Client Sample Description EH-128
Room 108 Sink
Collected: 6/12/2021 6:35:00 AM
Lab ID: 012107324-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.16	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:05

Client Sample Description EH-129
Room 106 Sink
Collected: 6/12/2021 6:35:00 AM
Lab ID: 012107324-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.74	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:07

Client Sample Description EH-130
Room 117 Photo Sink # 1
Collected: 6/12/2021 6:36:00 AM
Lab ID: 012107324-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.87	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:11

Client Sample Description EH-131
Room 117 Photo Sink # 2
Collected: 6/12/2021 6:37:00 AM
Lab ID: 012107324-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.40	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:12

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107324

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-132
Room 117 Photo Sink # 3
Collected: 6/12/2021 6:37:00 AM
Lab ID: 012107324-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.08	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:13

Client Sample Description EH-133
Room 117 Photo Sink # 4
Collected: 6/12/2021 6:37:00 AM
Lab ID: 012107324-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	52.6	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:15

Client Sample Description EH-134
Room 117 Photo Sink # 5
Collected: 6/12/2021 6:38:00 AM
Lab ID: 012107324-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.55	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:19

Client Sample Description EH-135
Room 117 Photo Sink # 6
Collected: 6/12/2021 6:38:00 AM
Lab ID: 012107324-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	97.2	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:20

Client Sample Description EH-136
Room 117 Photo Sink # 7
Collected: 6/12/2021 6:38:00 AM
Lab ID: 012107324-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	101 D	5.00 µg/L	7/15/2021 VD	7/16/2021 VD 12:39

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107324
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-137
 Room 117 Photo Sink # 8
Collected: 6/12/2021 6:39:00 AM
Lab ID: 012107324-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	44.9	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:22

Client Sample Description EH-138
 Boys Orange Lav Sink # 1
Collected: 6/12/2021 6:53:00 AM
Lab ID: 012107324-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.10	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:26

Client Sample Description EH-139
 Boys Orange Lav Sink # 2
Collected: 6/12/2021 6:53:00 AM
Lab ID: 012107324-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.74	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:28

Client Sample Description EH-140
 Boys Orange Lav Sink # 3
Collected: 6/12/2021 6:54:00 AM
Lab ID: 012107324-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.15	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:29

Client Sample Description EH-141
 Girls Red Lav Sink # 1
Collected: 6/12/2021 6:55:00 AM
Lab ID: 012107324-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:30

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107324
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-142
 Girls Red Lav Sink # 2
Collected: 6/12/2021 6:55:00 AM
Lab ID: 012107324-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.14	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:32

Client Sample Description EH-143
 Girls Red Lav Sink # 3
Collected: 6/12/2021 6:54:00 AM
Lab ID: 012107324-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:53

Client Sample Description EH-144
 Room 119 Sink # 1
Collected: 6/12/2021 6:58:00 AM
Lab ID: 012107324-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	32.6	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:58

Client Sample Description EH-145
 Room 119 Sink # 2
Collected: 6/12/2021 6:59:00 AM
Lab ID: 012107324-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	23.0	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:00

Client Sample Description EH-146
 Room 119 Sink # 3
Collected: 6/12/2021 6:59:00 AM
Lab ID: 012107324-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	71.2	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107324
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-147
 Room 119 Sink # 4
Collected: 6/12/2021 6:57:00 AM
Lab ID: 012107324-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	50.4	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:08

Client Sample Description EH-148
 Room 119 Sink # 5
Collected: 6/12/2021 6:57:00 AM
Lab ID: 012107324-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.4	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:10

Client Sample Description EH-149
 Room 113 Sink
Collected: 6/12/2021 7:00:00 AM
Lab ID: 012107324-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	38.3	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:12

Client Sample Description EH-150
 Mens Lav by Aud Sink
Collected: 6/12/2021 7:02:00 AM
Lab ID: 012107324-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	29.2	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:13

Client Sample Description EH-151
 Health Office Sink # 1
Collected: 6/12/2021 7:03:00 AM
Lab ID: 012107324-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	21.8	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:15

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107324
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-152
Health Office Sink # 2
Collected: 6/12/2021 7:03:00 AM
Lab ID: 012107324-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.90	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:17

Client Sample Description EH-153
Health Office Bathroom Sink
Collected: 6/12/2021 7:04:00 AM
Lab ID: 012107324-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.16	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:19

Client Sample Description EH-154
Bathrm near school store sink
Collected: 6/12/2021 7:05:00 AM
Lab ID: 012107324-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.36	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:29

Client Sample Description EH-155
Band Room Office Sink
Collected: 6/12/2021 7:07:00 AM
Lab ID: 012107324-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.70	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:30

Client Sample Description EH-157
Boys Lav Music Sink
Collected: 6/12/2021 7:05:00 AM
Lab ID: 012107324-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.38	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:32

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	012107324
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-158 Ladies Lav Music Sink
Collected: 6/12/2021 7:05:00 AM
Lab ID: 012107324-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.68	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:34

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results