



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

---

Attn:

**Keith Langlotz  
Williamsville CSD - Facilities Dept  
480 Lawrence Bell Dr.  
Williamsville, NY 14221**

7/19/2021

Phone: (716) 626-8860

Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

**2021 Lead in Water Testing**

The reference number for these samples is EMSL Order #012107291. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107291

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** EH-159  
 Womans PE Coaches Office Lav Sink  
**Collected:** 6/12/2021 7:08:00 AM  
**Lab ID:** 012107291-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	21.2	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:30

**Client Sample Description** EH-160  
 Girls Yellow Locker Room Sink (Bradley)  
**Collected:** 6/12/2021 7:09:00 AM  
**Lab ID:** 012107291-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.22	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:31

**Client Sample Description** EH-161  
 Boys Red Locker Room Sink (Bradley)  
**Collected:** 6/12/2021 7:10:00 AM  
**Lab ID:** 012107291-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	19.2	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:32

**Client Sample Description** EH-162  
 Hallway Fountain by Team Rm  
**Collected:** 6/12/2021 7:11:00 AM  
**Lab ID:** 012107291-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:35

**Client Sample Description** EH-163  
 Mens PE Coaches Office Sink #1  
**Collected:** 6/12/2021 7:11:00 AM  
**Lab ID:** 012107291-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.09	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:37

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107291  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** EH-165  
 Boys Team Room #1 Sink  
**Collected:** 6/12/2021 7:12:00 AM  
**Lab ID:** 012107291-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	13.3	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:38

**Client Sample Description** EH-166  
 Small Blue Team Coach Rm #1Sink  
**Collected:** 6/12/2021 7:15:00 AM  
**Lab ID:** 012107291-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.78	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:39

**Client Sample Description** EH-167  
 B Team Coach Rm #1 Ice Mach  
**Collected:** 6/12/2021 7:15:00 AM  
**Lab ID:** 012107291-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.98	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:41

**Client Sample Description** EH-168  
 Big Blue Team Room #2 Sink  
**Collected:** 6/12/2021 7:13:00 AM  
**Lab ID:** 012107291-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	13.5	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:42

**Client Sample Description** EH-169  
 2nd Floor Mens Lav Sink  
**Collected:** 6/12/2021 6:30:00 AM  
**Lab ID:** 012107291-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:46

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107291

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** EH-170  
2nd Floor Womens Lav Sink  
**Collected:** 6/12/2021 6:30:00 AM  
**Lab ID:** 012107291-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:47

**Client Sample Description** EH-171  
Hallway fount/2nd floor/Fac Lav  
**Collected:** 6/12/2021 6:31:00 AM  
**Lab ID:** 012107291-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:49

**Client Sample Description** EH-172  
2nd Flr Boys Lav Orange Sink #1  
**Collected:** 6/12/2021 6:35:00 AM  
**Lab ID:** 012107291-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.57	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:50

**Client Sample Description** EH-173  
2nd Flr Boys Lav Orange Sink #2  
**Collected:** 6/12/2021 6:35:00 AM  
**Lab ID:** 012107291-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.00	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:54

**Client Sample Description** EH-174  
2nd Flr Boys Lav Orange Sink #3  
**Collected:** 6/12/2021 6:35:00 AM  
**Lab ID:** 012107291-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.66	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:55

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107291  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** EH-175  
 2nd Flr Boys Lav Red Sink #1  
**Collected:** 6/12/2021 6:37:00 AM  
**Lab ID:** 012107291-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:56

**Client Sample Description** EH-176  
 2nd Flr Boys Lav Red Sink #2  
**Collected:** 6/12/2021 6:37:00 AM  
**Lab ID:** 012107291-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:58

**Client Sample Description** EH-177  
 2nd Flr Boys Lav Red Sink #3  
**Collected:** 6/12/2021 6:37:00 AM  
**Lab ID:** 012107291-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.52	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:02

**Client Sample Description** EH-180  
 Faculty Lounge Sink #1  
**Collected:** 6/12/2021 6:44:00 AM  
**Lab ID:** 012107291-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	6.16	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:03

**Client Sample Description** EH-183  
 Hallway Fountain Green #1  
**Collected:** 6/12/2021 6:40:00 AM  
**Lab ID:** 012107291-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107291  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** EH-185  
 2nd flr Boys Lav Green Sink #1  
**Collected:** 6/12/2021 6:41:00 AM  
**Lab ID:** 012107291-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.47	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:06

**Client Sample Description** EH-186  
 2nd flr Boys Lav Green Sink #2  
**Collected:** 6/12/2021 6:41:00 AM  
**Lab ID:** 012107291-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.05	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:07

**Client Sample Description** EH-187  
 2nd flr Girls Lav Green Sink #1  
**Collected:** 6/12/2021 6:40:00 AM  
**Lab ID:** 012107291-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:12

**Client Sample Description** EH-188  
 2nd flr Girls Lav Green Sink #2  
**Collected:** 6/12/2021 6:40:00 AM  
**Lab ID:** 012107291-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.08	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:19

**Client Sample Description** EH-189  
 IMC Sink  
**Collected:** 6/12/2021 6:32:00 AM  
**Lab ID:** 012107291-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	7.51	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:20

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107291

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** EH-190  
Boys Changing Room Sink #1 (Bradley) **Collected:** 6/12/2021 6:50:00 AM **Lab ID:** 012107291-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	12.4	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:21

**Client Sample Description** EH-191  
Girls Changing Room Sink #1 (Bradley) **Collected:** 6/12/2021 6:48:00 AM **Lab ID:** 012107291-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.98	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:23

**Client Sample Description** EH-193  
Fitness Room Fountain #1 **Collected:** 6/12/2021 6:46:00 AM **Lab ID:** 012107291-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:24

**Client Sample Description** EH-194  
3rd Floor Mens Lav Sink **Collected:** 6/12/2021 6:21:00 AM **Lab ID:** 012107291-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:25

**Client Sample Description** EH-195  
Hallway Fountain/3rd FI Fac Lav **Collected:** 6/12/2021 6:21:00 AM **Lab ID:** 012107291-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107291

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** EH-196  
3rd Floor Womens Lav Sink  
**Collected:** 6/12/2021 6:21:00 AM  
**Lab ID:** 012107291-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:28

**Client Sample Description** EH-197  
3rd Floor Boys Lav Orange Sink #1  
**Collected:** 6/12/2021 6:25:00 AM  
**Lab ID:** 012107291-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.85	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:29

**Client Sample Description** EH-198  
3rd Floor Boys Lav Orange Sink #2  
**Collected:** 6/12/2021 6:25:00 AM  
**Lab ID:** 012107291-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.86	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:33

**Client Sample Description** EH-199  
3rd Floor Boys Lav Orange Sink #3  
**Collected:** 6/12/2021 6:25:00 AM  
**Lab ID:** 012107291-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.05	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:37

**Client Sample Description** EH-200  
3rd FI Girls Lav Red Sink #1  
**Collected:** 6/12/2021 6:28:00 AM  
**Lab ID:** 012107291-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.22	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:38



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107291

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** EH-201  
3rd Flr Girls Lav Red Sink #2  
**Collected:** 6/12/2021 6:28:00 AM  
**Lab ID:** 012107291-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:39

**Client Sample Description** EH-202  
3rd Flr Girls Lav Red Sink #3  
**Collected:** 6/12/2021 6:28:00 AM  
**Lab ID:** 012107291-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.59	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:41

**Client Sample Description** EH-209  
3rd Flr Girls Lav Green Sink #1  
**Collected:** 6/12/2021 6:37:00 AM  
**Lab ID:** 012107291-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.74	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:42

**Client Sample Description** EH-210  
3rd Flr Girls Lav Green Sink #2  
**Collected:** 6/12/2021 6:32:00 AM  
**Lab ID:** 012107291-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.65	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:43

**Client Sample Description** EH-211  
3rd Flr Boys Lav Green Sink #1  
**Collected:** 6/12/2021 6:32:00 AM  
**Lab ID:** 012107291-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.88	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:45

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107291

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** EH-212  
3rd Flr Boys Lav Green Sink #2  
**Collected:** 6/12/2021 6:32:00 AM  
**Lab ID:** 012107291-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.68	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:49

**Client Sample Description** EH-213  
Hallway Fountain Green Girls  
**Collected:** 6/12/2021 6:33:00 AM  
**Lab ID:** 012107291-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:50

**Client Sample Description** EH-215  
Kitchen Sink #10  
**Collected:** 6/12/2021 6:33:00 AM  
**Lab ID:** 012107291-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	12.1	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:12

**Client Sample Description** EH-216  
Kiln Room Sink #2  
**Collected:** 6/12/2021 6:41:00 AM  
**Lab ID:** 012107291-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	30.4	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:13

**Client Sample Description** EH-217  
Coaches Offices Sink #2  
**Collected:** 6/12/2021 7:15:00 AM  
**Lab ID:** 012107291-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.26	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:14



## EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012107291
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

### Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results