



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

---

Attn:

**Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

7/19/2021

Phone: (716) 626-8860  
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

**2021 Lead in Water Testing**

The reference number for these samples is EMSL Order #012107288. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107288  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** HE-100  
 Girl's Lav by Room 150 Bathroom Sink  
**Collected:** 6/12/2021 7:02:00 AM  
**Lab ID:** 012107288-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.37	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:41

**Client Sample Description** HE-101  
 Room 150 Classroom Sink  
**Collected:** 6/12/2021 7:08:00 AM  
**Lab ID:** 012107288-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:48

**Client Sample Description** HE-102  
 Hallway Fountatin by Room 160  
**Collected:** 6/12/2021 7:04:00 AM  
**Lab ID:** 012107288-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:49

**Client Sample Description** HE-103  
 Room 160 Bathroom Sink #1  
**Collected:** 6/12/2021 7:05:00 AM  
**Lab ID:** 012107288-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:50

**Client Sample Description** HE-104  
 Room 160 Bathroom Sink #2  
**Collected:** 6/12/2021 7:06:00 AM  
**Lab ID:** 012107288-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.00	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:52

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107288  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** HE-105  
 Room 150 Classroom Sink  
**Collected:** 6/12/2021 7:50:00 AM  
**Lab ID:** 012107288-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.19	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:53

**Client Sample Description** HE-106  
 Room 151 Classroom Sink  
**Collected:** 6/12/2021 7:50:00 AM  
**Lab ID:** 012107288-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	7.00	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:54

**Client Sample Description** HE-107  
 Boys Lav by Room 151 Sink  
**Collected:** 6/12/2021 7:03:00 AM  
**Lab ID:** 012107288-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.80	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:55

**Client Sample Description** HE-108  
 Room 159 Classroom Sink #1  
**Collected:** 6/12/2021 7:16:00 AM  
**Lab ID:** 012107288-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.33	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:57

**Client Sample Description** HE-110  
 Room 158 Classroom Sink  
**Collected:** 6/12/2021 7:15:00 AM  
**Lab ID:** 012107288-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.19	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:01

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107288  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** HE-112 Room 157 Classroom Sink **Collected:** 6/12/2021 7:15:00 AM **Lab ID:** 012107288-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.34	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:02

**Client Sample Description** HE-114 Room 156 Classroom Sink **Collected:** 6/12/2021 7:14:00 AM **Lab ID:** 012107288-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:06

**Client Sample Description** HE-116 Room 155 Classroom Sink **Collected:** 6/12/2021 7:13:00 AM **Lab ID:** 012107288-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:07

**Client Sample Description** HE-118 Room 154 Classroom Sink **Collected:** 6/12/2021 7:12:00 AM **Lab ID:** 012107288-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:08

**Client Sample Description** HE-120 Room 153 Classroom Sink **Collected:** 6/12/2021 7:09:00 AM **Lab ID:** 012107288-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	11.8	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:10

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012107288
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** HE-122  
Room 153 Bathroom Sink  
**Collected:** 6/12/2021 7:10:00 AM  
**Lab ID:** 012107288-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.72	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:11

**Client Sample Description** HE-123  
Room 188 Classroom Sink  
**Collected:** 6/12/2021 6:42:00 AM  
**Lab ID:** 012107288-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	14.0	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:12

**Client Sample Description** HE-124  
Room 140 Classroom Sink  
**Collected:** 6/12/2021 7:19:00 AM  
**Lab ID:** 012107288-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.55	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:16

**Client Sample Description** HE-126  
Hallway Fountain by Room 140  
**Collected:** 6/12/2021 7:20:00 AM  
**Lab ID:** 012107288-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:18

**Client Sample Description** HE-127  
Room 142 Classroom Sink  
**Collected:** 6/12/2021 7:20:00 AM  
**Lab ID:** 012107288-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	16.6	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:19

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107288

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860

Fax:

Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** HE-129  
Room 143 Classroom Sink  
**Collected:** 6/12/2021 7:21:00 AM  
**Lab ID:** 012107288-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	6.05	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:01

**Client Sample Description** HE-131  
Room 144 Classroom Sink  
**Collected:** 6/12/2021 7:22:00 AM  
**Lab ID:** 012107288-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.23	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:05

**Client Sample Description** HE-133  
Room 145 Classroom Sink  
**Collected:** 6/12/2021 7:23:00 AM  
**Lab ID:** 012107288-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	6.02	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:06

**Client Sample Description** HE-135  
Room 146 Classroom Sink  
**Collected:** 6/12/2021 7:25:00 AM  
**Lab ID:** 012107288-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	6.54	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:07

**Client Sample Description** HE-137  
Room 147 Classroom Sink  
**Collected:** 6/12/2021 7:25:00 AM  
**Lab ID:** 012107288-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	5.44	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:09

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107288  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** HE-139 Room 148 Classroom Sink **Collected:** 6/12/2021 7:26:00 AM **Lab ID:** 012107288-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	16.8	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:10

**Client Sample Description** HE-141 Café Classroom Sink **Collected:** 6/12/2021 7:27:00 AM **Lab ID:** 012107288-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.43	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:14

**Client Sample Description** HE-142 Hallway Foutain Outside Room 130 **Collected:** 6/12/2021 7:37:00 AM **Lab ID:** 012107288-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:15

**Client Sample Description** HE-143 Room 131 Classroom Sink **Collected:** 6/12/2021 7:38:00 AM **Lab ID:** 012107288-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.89	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:16

**Client Sample Description** HE-144 Room 132 Classroom Sink **Collected:** 6/12/2021 7:39:00 AM **Lab ID:** 012107288-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.92	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:18

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012107288
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** HE-146  
Room 134 Classroom Sink  
**Collected:** 6/12/2021 7:40:00 AM  
**Lab ID:** 012107288-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.93	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:19

**Client Sample Description** HE-148  
Room 135 Classroom Sink  
**Collected:** 6/12/2021 7:41:00 AM  
**Lab ID:** 012107288-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	10.8	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:23

**Client Sample Description** HE-150  
Room 136 Classroom Sink  
**Collected:** 6/12/2021 7:42:00 AM  
**Lab ID:** 012107288-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.85	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:24

**Client Sample Description** HE-152  
Room 137 Classroom Sink  
**Collected:** 6/12/2021 7:43:00 AM  
**Lab ID:** 012107288-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.97	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:26

**Client Sample Description** HE-154  
Room 138 Classroom Sink  
**Collected:** 6/12/2021 7:43:00 AM  
**Lab ID:** 012107288-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	7.28	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:29



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107288  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** HE-158 **Collected:** 6/12/2021 **Lab ID:** 012107288-0036  
 Boys Lav by Gym Bathroom Sink #3 7:34:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.09	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:31

**Client Sample Description** HE-159 **Collected:** 6/12/2021 **Lab ID:** 012107288-0037  
 Boys Lav by Gym Bathroom Sink #4 7:35:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.78	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:32

**Client Sample Description** HE-160 **Collected:** 6/12/2021 **Lab ID:** 012107288-0038  
 Boys Lav by Gym Bathroom Sink #5 7:36:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.81	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:33

**Client Sample Description** HE-161 **Collected:** 6/12/2021 **Lab ID:** 012107288-0039  
 Girls Lav by Gym Bathroom Sink #1 7:37:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.15	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:35

**Client Sample Description** HE-162 **Collected:** 6/12/2021 **Lab ID:** 012107288-0040  
 Girls Lav by Gym Bathroom Sink #2 7:32:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.24	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:36

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107288  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** HE-163  
 Girls Lav by Gym Bathroom Sink #3  
**Collected:** 6/12/2021 7:31:00 AM  
**Lab ID:** 012107288-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.57	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:32

**Client Sample Description** HE-164  
 Staff Bathroom by Clinic Bathroom Sink #1  
**Collected:** 6/12/2021 7:53:00 AM  
**Lab ID:** 012107288-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.30	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:38

**Client Sample Description** HE-165  
 Staff Bathroom by Clinic Bathroom Sink #2  
**Collected:** 6/12/2021 7:53:00 AM  
**Lab ID:** 012107288-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.45	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:39

**Client Sample Description** HE-166  
 Main Office Kitchen Sink  
**Collected:** 6/12/2021 7:49:00 AM  
**Lab ID:** 012107288-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	7.85	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:41

**Client Sample Description** HE-167  
 Clinic Bathroom Sink  
**Collected:** 6/12/2021 7:51:00 AM  
**Lab ID:** 012107288-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.46	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:42

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107288  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** HE-168  
 Clinic Classroom Sink  
**Collected:** 6/12/2021 7:51:00 AM  
**Lab ID:** 012107288-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	6.61	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:43

**Client Sample Description** HE-169  
 Room 100 Classroom Sink  
**Collected:** 6/12/2021 7:54:00 AM  
**Lab ID:** 012107288-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.44	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:45

**Client Sample Description** HE-171  
 Hallway Fountain by Room 100  
**Collected:** 6/12/2021 7:55:00 AM  
**Lab ID:** 012107288-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:46

**Client Sample Description** HE-172  
 Room 102 Classroom Sink  
**Collected:** 6/12/2021 7:57:00 AM  
**Lab ID:** 012107288-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	8.12	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:47

**Client Sample Description** HE-174  
 Room 103 Classroom Sink  
**Collected:** 6/12/2021 8:00:00 AM  
**Lab ID:** 012107288-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.47	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:51

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012107288
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** HE-176  
Room 104 Classroom Sink  
**Collected:** 6/12/2021 8:08:00 AM  
**Lab ID:** 012107288-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.19	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:52

**Client Sample Description** HE-178  
Room 105 Classroom Sink  
**Collected:** 6/12/2021 8:04:00 AM  
**Lab ID:** 012107288-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.30	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:56

**Client Sample Description** HE-180  
Room 106 Classroom Sink  
**Collected:** 6/12/2021 8:05:00 AM  
**Lab ID:** 012107288-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.94	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:58

**Client Sample Description** HE-182  
Room 107 Classroom Sink  
**Collected:** 6/12/2021 8:06:00 AM  
**Lab ID:** 012107288-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	13.9	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:59

**Client Sample Description** HE-184  
Room 108 Classroom Sink  
**Collected:** 6/12/2021 8:09:00 AM  
**Lab ID:** 012107288-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.87	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 12:00

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107288  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** HE-186  
 Room 109 Classroom Sink  
**Collected:** 6/12/2021 8:10:00 AM  
**Lab ID:** 012107288-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	8.83	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 12:02

**Client Sample Description** HE-187  
 Hallway Fountain Outside Room 120  
**Collected:** 6/12/2021 8:13:00 AM  
**Lab ID:** 012107288-0057

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 12:03

**Client Sample Description** HE-188  
 Room 120 Classroom Sink  
**Collected:** 6/12/2021 8:12:00 AM  
**Lab ID:** 012107288-0058

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.02	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 12:07

**Client Sample Description** HE-190  
 Room 121 Classroom Sink  
**Collected:** 6/12/2021 8:13:00 AM  
**Lab ID:** 012107288-0059

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.60	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 12:08

**Client Sample Description** HE-192  
 Room 122 Classroom Sink  
**Collected:** 6/12/2021 8:18:00 AM  
**Lab ID:** 012107288-0060

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.86	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 12:09

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107288  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** HE-194  
 Room 123 Classroom Sink  
**Collected:** 6/12/2021 8:19:00 AM  
**Lab ID:** 012107288-0061

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.51	1.00 µg/L	7/13/2021 VD	7/13/2021 KB 23:14

**Client Sample Description** HE-196  
 Room 124 Classroom Sink  
**Collected:** 6/12/2021 8:21:00 AM  
**Lab ID:** 012107288-0062

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	5.72	1.00 µg/L	7/13/2021 VD	7/13/2021 KB 23:15

**Client Sample Description** HE-198  
 Room 125 Classroom Sink  
**Collected:** 6/12/2021 8:22:00 AM  
**Lab ID:** 012107288-0063

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.55	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:05

**Client Sample Description** HE-200  
 Room 126 Classroom Sink  
**Collected:** 6/12/2021 8:23:00 AM  
**Lab ID:** 012107288-0064

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.30	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:09

**Client Sample Description** HE-202  
 Room 127 Classroom Sink  
**Collected:** 6/12/2021 8:23:00 AM  
**Lab ID:** 012107288-0065

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.98	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:10

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107288

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860

Fax:

Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** HE-204  
Kitchen Bathroom Sink  
**Collected:** 6/12/2021 6:40:00 AM  
**Lab ID:** 012107288-0066

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	10.6	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:14

**Client Sample Description** HE-205  
Boys Locker Room Bathroom Sink  
**Collected:** 6/12/2021 6:36:00 AM  
**Lab ID:** 012107288-0067

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:15

**Client Sample Description** HE-206  
Handicapped Lav by Kitchen Bathroom Sink  
**Collected:** 6/12/2021 6:36:00 AM  
**Lab ID:** 012107288-0068

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:17

**Client Sample Description** HE-207  
Kitchen Sink #1  
**Collected:** 6/12/2021 6:29:00 AM  
**Lab ID:** 012107288-0069

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.65	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:18

**Client Sample Description** HE-208  
Kitchen Sink #2  
**Collected:** 6/12/2021 6:33:00 AM  
**Lab ID:** 012107288-0070

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	10.1	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:19

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107288  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** HE-209  
 Kitchen Sink #3  
**Collected:** 6/12/2021 6:33:00 AM  
**Lab ID:** 012107288-0071

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	12.4	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:21

**Client Sample Description** HE-210  
 Kitchen Pot Filler  
**Collected:** 6/12/2021 6:34:00 AM  
**Lab ID:** 012107288-0072

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.04	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:22

**Client Sample Description** HE-211  
 Custodial Area Bathroom Sink  
**Collected:** 6/12/2021 6:28:00 AM  
**Lab ID:** 012107288-0073

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.47	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:23

**Client Sample Description** HE-212  
 Girls Locker Room Bathroom Sink #1  
**Collected:** 6/12/2021 6:38:00 AM  
**Lab ID:** 012107288-0074

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:30

**Client Sample Description** HE-213  
 Boiler Room Source  
**Collected:** 6/12/2021 6:12:00 AM  
**Lab ID:** 012107288-0075

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.67	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:31



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107288

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** HE-214 **Collected:** 6/12/2021 **Lab ID:** 012107288-0076  
 Girls Locker Room Sink #2 6:38:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:32

**Client Sample Description** HE-215 **Collected:** 6/12/2021 **Lab ID:** 012107288-0077  
 Room 103 Classroom Sink #2 8:01:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.52	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:34

**Client Sample Description** HE-216 **Collected:** 6/12/2021 **Lab ID:** 012107288-0078  
 Room 102 Classroom Sink #2 7:57:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.49	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:35

**Definitions:**

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results