



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860

Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107299. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-100
Boiler Room Source
Collected: 6/5/2021 7:30:00 AM
Lab ID: 012107299-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.1	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 19:57

Client Sample Description HM-101
Custodial Area Bathroom Sink
Collected: 6/5/2021 6:08:00 AM
Lab ID: 012107299-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:16

Client Sample Description HM-102
Custodial Area Sink
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107299-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:17

Client Sample Description HM-103
Room D7 Classroom Sink # 1
Collected: 6/5/2021 7:02:00 AM
Lab ID: 012107299-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.11	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:18

Client Sample Description HM-104
Room D7 Classroom Sink # 2
Collected: 6/5/2021 7:04:00 AM
Lab ID: 012107299-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.21	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:20

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-105
 Room D7 Classroom Sink # 3
Collected: 6/5/2021 7:03:00 AM
Lab ID: 012107299-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.46	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:21

Client Sample Description HM-106
 Room D7 Classroom Sink # 4
Collected: 6/5/2021 7:00:00 AM
Lab ID: 012107299-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.22	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:22

Client Sample Description HM-107
 Room D7 Wash Machine Room Sink
Collected: 6/5/2021 6:59:00 AM
Lab ID: 012107299-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.8	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:23

Client Sample Description HM-108
 Hallway fountain by D6
Collected: 6/5/2021 7:06:00 AM
Lab ID: 012107299-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:25

Client Sample Description HM-109
 Room D4 Sink
Collected: 6/5/2021 7:12:00 AM
Lab ID: 012107299-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.69	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107299

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-110
Room D3 Sink # 1
Collected: 6/5/2021 7:14:00 AM
Lab ID: 012107299-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.53	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:33

Client Sample Description HM-111
Room D3 Sink # 2
Collected: 6/5/2021 7:15:00 AM
Lab ID: 012107299-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:34

Client Sample Description HM-112
Room D6 Sink # 1
Collected: 6/5/2021 7:09:00 AM
Lab ID: 012107299-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	28.8	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:35

Client Sample Description HM-113
Room D3 Sink # 3
Collected: 6/5/2021 7:16:00 AM
Lab ID: 012107299-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.89	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:37

Client Sample Description HM-114
Room D11 Sink # 1
Collected: 6/5/2021 7:19:00 AM
Lab ID: 012107299-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.6	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:38

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-115 Room D11 Sink # 2 **Collected:** 6/5/2021 7:21:00 AM **Lab ID:** 012107299-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.66	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:39

Client Sample Description HM-116 Room D11 Sink # 3 **Collected:** 6/5/2021 7:22:00 AM **Lab ID:** 012107299-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.12	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:41

Client Sample Description HM-117 Boys Gym Teachers Office Sink **Collected:** 6/5/2021 7:27:00 AM **Lab ID:** 012107299-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.13	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:42

Client Sample Description HM-118 Fountain Boys Locker Room **Collected:** 6/5/2021 7:25:00 AM **Lab ID:** 012107299-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:43

Client Sample Description HM-119 Boys Locker Room # 1 **Collected:** 6/5/2021 7:25:00 AM **Lab ID:** 012107299-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.7	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:18

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-120
Boys Locker Room # 2
Collected: 6/5/2021 7:25:00 AM
Lab ID: 012107299-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.46	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:22

Client Sample Description HM-121
Water Fountain Hall by Gym/Café
Collected: 6/5/2021 7:30:00 AM
Lab ID: 012107299-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:23

Client Sample Description HM-122
Girls Locker Room # 1
Collected: 6/5/2021 7:37:00 AM
Lab ID: 012107299-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.13	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:27

Client Sample Description HM-123
Girls Locker Room # 2
Collected: 6/5/2021 7:37:00 AM
Lab ID: 012107299-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.82	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:28

Client Sample Description HM-124
Fountain in Girls Locker Room
Collected: 6/5/2021 7:35:00 AM
Lab ID: 012107299-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.41	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 20:00

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-125
 Girls Gym Teacher Office Sink
Collected: 6/5/2021 7:39:00 AM
Lab ID: 012107299-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.97	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:30

Client Sample Description HM-126
 Stage Sink
Collected: 6/5/2021 7:42:00 AM
Lab ID: 012107299-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.14	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:31

Client Sample Description HM-127
 Handicapped Bathroom Sink by D-1
Collected: 6/5/2021 7:43:00 AM
Lab ID: 012107299-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.20	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:32

Client Sample Description HM-128
 Hallway Fountain Near Aud
Collected: 6/5/2021 7:45:00 AM
Lab ID: 012107299-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:33

Client Sample Description HM-129
 Boys Lav by C-15 Sink # 1
Collected: 6/5/2021 7:49:00 AM
Lab ID: 012107299-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:35

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107299

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-130
Boys Lav by C-15 Sink # 2
Collected: 6/5/2021 7:49:00 AM
Lab ID: 012107299-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:36

Client Sample Description HM-131
Boys Lav by C-15 Sink # 3
Collected: 6/5/2021 7:49:00 AM
Lab ID: 012107299-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:43

Client Sample Description HM-132
Boys Lav by C-15 Sink # 4
Collected: 6/5/2021 7:49:00 AM
Lab ID: 012107299-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:44

Client Sample Description HM-133
Girls Lav by C-15 Sink # 1
Collected: 6/5/2021 7:51:00 AM
Lab ID: 012107299-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.51	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:45

Client Sample Description HM-134
Girls Lav by C-15 Sink # 2
Collected: 6/5/2021 7:51:00 AM
Lab ID: 012107299-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.23	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:47

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-135
 Girls Lav by C-15 Sink # 3
Collected: 6/5/2021 7:51:00 AM
Lab ID: 012107299-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.66	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:48

Client Sample Description HM-136
 Girls Lav by C-15 Sink # 4
Collected: 6/5/2021 7:51:00 AM
Lab ID: 012107299-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.05	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:49

Client Sample Description HM-137
 Classroom C-13 Eye Wash
Collected: 6/5/2021 7:55:00 AM
Lab ID: 012107299-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	51.7 D	5.00 µg/L	7/13/2021 JD	7/15/2021 JW 20:35

Client Sample Description HM-138
 Classroom C-11 Eye Wash
Collected: 6/5/2021 8:12:00 AM
Lab ID: 012107299-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	93.9 D	5.00 µg/L	7/13/2021 JD	7/15/2021 JW 20:44

Client Sample Description HM-139
 Classroom C-12 Eye Wash
Collected: 6/5/2021 8:18:00 AM
Lab ID: 012107299-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.4	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 20:10

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-140
 Classroom C-14 Eye Wash
Collected: 6/5/2021 8:51:00 AM
Lab ID: 012107299-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.64	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:50

Client Sample Description HM-141
 Hallway fountain by C-13
Collected: 6/5/2021 7:59:00 AM
Lab ID: 012107299-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:52

Client Sample Description HM-142
 Library Office Sink
Collected: 6/5/2021 8:42:00 AM
Lab ID: 012107299-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.31	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:53

Client Sample Description HM-143
 Boys Bathroom by B-Wing Sink # 1
Collected: 6/5/2021 8:00:00 AM
Lab ID: 012107299-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.34	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:35

Client Sample Description HM-144
 Boys Bathroom by B-Wing Sink # 2
Collected: 6/5/2021 8:00:00 AM
Lab ID: 012107299-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.05	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 20:13

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-145
 Boys Bathroom by B-Wing Sink # 3
Collected: 6/5/2021 8:00:00 AM
Lab ID: 012107299-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:41

Client Sample Description HM-146
 Boys Bathroom by B-Wing Sink # 4
Collected: 6/5/2021 8:00:00 AM
Lab ID: 012107299-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.05	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:43

Client Sample Description HM-147
 Girls Bathroom by B-Wing Sink # 1
Collected: 6/5/2021 8:49:00 AM
Lab ID: 012107299-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.53	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:44

Client Sample Description HM-148
 Girls Bathroom by B-Wing Sink # 2
Collected: 6/5/2021 8:49:00 AM
Lab ID: 012107299-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.27	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:45

Client Sample Description HM-149
 Girls Bathroom by B-Wing Sink # 3
Collected: 6/5/2021 8:50:00 AM
Lab ID: 012107299-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.27	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:47

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-150
 Girls Bathroom by B-Wing Sink # 4
Collected: 6/5/2021 8:50:00 AM
Lab ID: 012107299-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.15	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:48

Client Sample Description HM-151
 Hallway fountain by C-14
Collected: 6/5/2021 9:06:00 AM
Lab ID: 012107299-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:49

Client Sample Description HM-152
 IMC Sink
Collected: 6/5/2021 8:01:00 AM
Lab ID: 012107299-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.39	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:51

Client Sample Description HM-153
 Room A-16 Sink
Collected: 6/5/2021 8:55:00 AM
Lab ID: 012107299-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.13	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:52

Client Sample Description HM-154
 Mens Lav A-Wing Sink # 1
Collected: 6/5/2021 8:56:00 AM
Lab ID: 012107299-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.15	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:58

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-155
 Mens Lav A-Wing Sink # 2
Collected: 6/5/2021 8:56:00 AM
Lab ID: 012107299-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:02

Client Sample Description HM-156
 Mens Lav A-Wing Sink # 3
Collected: 6/5/2021 8:56:00 AM
Lab ID: 012107299-0057

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.01	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 20:16

Client Sample Description HM-157
 Mens Lav A-Wing Sink # 4
Collected: 6/5/2021 8:57:00 AM
Lab ID: 012107299-0058

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.67	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:04

Client Sample Description HM-158
 Womens Lav A-Wing Sink # 1
Collected: 6/5/2021 8:58:00 AM
Lab ID: 012107299-0059

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:05

Client Sample Description HM-159
 Womens Lav A-Wing Sink # 2
Collected: 6/5/2021 8:58:00 AM
Lab ID: 012107299-0060

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 20:19

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-160
 Womens Lav A-Wing Sink # 3
Collected: 6/5/2021 8:58:00 AM
Lab ID: 012107299-0061

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:06

Client Sample Description HM-161
 Womens Lav A-Wing Sink # 4
Collected: 6/5/2021 8:58:00 AM
Lab ID: 012107299-0062

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.82	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:07

Client Sample Description HM-162
 Classroom A-13 Eye Wash
Collected: 6/5/2021 8:59:00 AM
Lab ID: 012107299-0063

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.47	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:11

Client Sample Description HM-163
 Hallway Fountain By A-13
Collected: 6/5/2021 9:03:00 AM
Lab ID: 012107299-0064

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:13

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results