



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Keith Langlotz
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/20/2021

Phone: (716) 626-8860
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107289. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107289
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-164
 Classroom A-11 Eye Wash
Collected: 6/5/2021 8:59:00 AM
Lab ID: 012107289-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	23.2 D	5.00 µg/L	7/19/2021 KB	7/19/2021 KB 15:54

Client Sample Description HM-165
 Health Office Sink
Collected: 6/5/2021 8:54:00 AM
Lab ID: 012107289-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 15:48

Client Sample Description HM-166
 Health Office Bathroom Sink
Collected: 6/5/2021 7:43:00 AM
Lab ID: 012107289-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.65	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 15:57

Client Sample Description HM-167
 Main Office Sink
Collected: 6/5/2021 7:45:00 AM
Lab ID: 012107289-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 15:58

Client Sample Description HM-168
 Hallway Fountain by Aud
Collected: 6/5/2021 7:47:00 AM
Lab ID: 012107289-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 16:00

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	012107289
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-169
 Womens Faculty by Aud Sink #1
Collected: 6/5/2021 7:51:00 AM
Lab ID: 012107289-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.06	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 16:01

Client Sample Description HM-170
 Womens Faculty by Aud Sink #2
Collected: 6/5/2021 7:52:00 AM
Lab ID: 012107289-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.0	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 16:02

Client Sample Description HM-171
 Faculty Dining Sink
Collected: 6/5/2021 7:53:00 AM
Lab ID: 012107289-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.63	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 16:03

Client Sample Description HM-172
 Kitchen Sink #1
Collected: 6/5/2021 8:02:00 AM
Lab ID: 012107289-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.56	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 16:05

Client Sample Description HM-173
 Kitchen Sink #2
Collected: 6/5/2021 7:56:00 AM
Lab ID: 012107289-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.98	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 16:09

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107289
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-174 Kitchen Sink #3 **Collected:** 6/5/2021 7:57:00 AM **Lab ID:** 012107289-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.52	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:58

Client Sample Description HM-175 Kitchen Sink #4 **Collected:** 6/5/2021 7:57:00 AM **Lab ID:** 012107289-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.15	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 10:02

Client Sample Description HM-176 Kitchen Sink #5 **Collected:** 6/5/2021 7:58:00 AM **Lab ID:** 012107289-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.86	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 10:03

Client Sample Description HM-177 Outlet by Steamer in Kitchen **Collected:** 6/5/2021 8:05:00 AM **Lab ID:** 012107289-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	119 D	5.00 µg/L	7/13/2021 JD	7/20/2021 JW 12:31

Client Sample Description HM-178 Kitchen Sink by Dishwasher #1 **Collected:** 6/5/2021 7:59:00 AM **Lab ID:** 012107289-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.83	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 10:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107289

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-179
 Kitchen Sink by Dishwasher #2
Collected: 6/5/2021 7:58:00 AM
Lab ID: 012107289-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.21	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 10:05

Client Sample Description HM-180
 Kitchen Staff Bathroom Sink
Collected: 6/5/2021 8:06:00 AM
Lab ID: 012107289-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.74	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 10:07

Client Sample Description HM-181
 Boiler Room Eye Wash
Collected: 6/5/2021 8:38:00 AM
Lab ID: 012107289-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	46.9	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 10:08

Client Sample Description HM-182
 Basement Pool Eye Wash
Collected: 6/5/2021 8:46:00 AM
Lab ID: 012107289-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.91	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 10:09

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results