



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Keith Langlotz  
Williamsville CSD - Facilities Dept  
480 Lawrence Bell Dr.  
Williamsville, NY 14221**

7/19/2021

Phone: (716) 626-8860  
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

**2021 Lead in Water Testing**

The reference number for these samples is EMSL Order #012107313. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107313  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** NH-100  
 Boiler Room Source  
**Collected:** 6/12/2021 6:02:00 AM  
**Lab ID:** 012107313-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	23.5	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:01

**Client Sample Description** NH-101  
 Basement Break Room Sink # 1  
**Collected:** 6/12/2021 6:05:00 AM  
**Lab ID:** 012107313-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.11	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:07

**Client Sample Description** NH-102  
 Basement Break Room Sink # 2  
**Collected:** 6/12/2021 6:05:00 AM  
**Lab ID:** 012107313-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	6.03	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:09

**Client Sample Description** NH-103  
 Basement Lockr Rm Bathrm Sink  
**Collected:** 6/12/2021 6:09:00 AM  
**Lab ID:** 012107313-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.26	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:11

**Client Sample Description** NH-104  
 A Wing Girls Lav Sink # 1  
**Collected:** 6/12/2021 6:26:00 AM  
**Lab ID:** 012107313-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.95	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:12

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107313  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** NH-105  
 A Wing Girls Lav Sink # 2  
**Collected:** 6/12/2021 6:26:00 AM  
**Lab ID:** 012107313-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.14	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:18

**Client Sample Description** NH-106  
 A Wing Girls Lav Sink # 3  
**Collected:** 6/12/2021 6:26:00 AM  
**Lab ID:** 012107313-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.05	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:20

**Client Sample Description** NH-107  
 A Wing Girls Lav Sink # 4  
**Collected:** 6/12/2021 6:26:00 AM  
**Lab ID:** 012107313-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.15	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:22

**Client Sample Description** NH-108  
 A Wing Boys Lav Sink # 1  
**Collected:** 6/12/2021 6:29:00 AM  
**Lab ID:** 012107313-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.10	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:24

**Client Sample Description** NH-109  
 A Wing Boys Lav Sink # 2  
**Collected:** 6/12/2021 6:29:00 AM  
**Lab ID:** 012107313-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.10	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012107313
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** NH-111  
Room A-159 Sink  
**Collected:** 6/12/2021 6:32:00 AM  
**Lab ID:** 012107313-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	5.72	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:28

**Client Sample Description** NH-112  
Conference Room Sink # 1  
**Collected:** 6/12/2021 6:34:00 AM  
**Lab ID:** 012107313-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	21.3	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:33

**Client Sample Description** NH-113  
Conference Room Sink # 2  
**Collected:** 6/12/2021 6:34:00 AM  
**Lab ID:** 012107313-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	17.1	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:35

**Client Sample Description** NH-114  
Guidance Office Sink  
**Collected:** 6/12/2021 6:38:00 AM  
**Lab ID:** 012107313-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.06	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:41

**Client Sample Description** NH-115  
Room A-103 Sink  
**Collected:** 6/12/2021 6:41:00 AM  
**Lab ID:** 012107313-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	5.93	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:43

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107313  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** NH-116  
 Room A-109 Sink  
**Collected:** 6/12/2021 6:43:00 AM  
**Lab ID:** 012107313-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:45

**Client Sample Description** NH-117  
 Hallway Fountain by Rm A-105  
**Collected:** 6/12/2021 6:41:00 AM  
**Lab ID:** 012107313-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:46

**Client Sample Description** NH-120  
 Room A-134 Bathroom Sink  
**Collected:** 6/12/2021 6:45:00 AM  
**Lab ID:** 012107313-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:48

**Client Sample Description** NH-121  
 Kitchen Sink # 1  
**Collected:** 6/12/2021 6:47:00 AM  
**Lab ID:** 012107313-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:50

**Client Sample Description** NH-122  
 Kitchen Sink # 2  
**Collected:** 6/12/2021 6:47:00 AM  
**Lab ID:** 012107313-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:52

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107313  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** NH-123  
 Kitchen Sink # 3  
**Collected:** 6/12/2021 6:47:00 AM  
**Lab ID:** 012107313-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.27	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:24

**Client Sample Description** NH-124  
 Kitchen Sink # 4  
**Collected:** 6/12/2021 6:48:00 AM  
**Lab ID:** 012107313-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:28

**Client Sample Description** NH-125  
 Kitchen Sink # 5  
**Collected:** 6/12/2021 6:48:00 AM  
**Lab ID:** 012107313-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:34

**Client Sample Description** NH-126  
 Kitchen Sink # 6  
**Collected:** 6/12/2021 6:48:00 AM  
**Lab ID:** 012107313-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.96	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:36

**Client Sample Description** NH-127  
 Kitchen Sink # 7  
**Collected:** 6/12/2021 6:49:00 AM  
**Lab ID:** 012107313-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.03	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:37

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012107313
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** NH-128  
Serving Area Sink # 1  
**Collected:** 6/12/2021 6:51:00 AM  
**Lab ID:** 012107313-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.21	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:38

**Client Sample Description** NH-129  
Serving Area Sink # 2  
**Collected:** 6/12/2021 6:52:00 AM  
**Lab ID:** 012107313-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.62	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:40

**Client Sample Description** NH-130  
Kitchen Dish Room Sink # 1  
**Collected:** 6/12/2021 6:55:00 AM  
**Lab ID:** 012107313-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.86	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:41

**Client Sample Description** NH-131  
Kitchen Dish Room Sink # 2  
**Collected:** 6/12/2021 6:55:00 AM  
**Lab ID:** 012107313-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	21.9	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:42

**Client Sample Description** NH-132  
Hallway Fountain by Rm A-120  
**Collected:** 6/12/2021 6:59:00 AM  
**Lab ID:** 012107313-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:43

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107313  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** NH-166  
 Hallway Fountain by B-103  
**Collected:** 6/12/2021 7:01:00 AM  
**Lab ID:** 012107313-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:47

**Client Sample Description** NH-178  
 Girls Lav by Rm A-123 Sink # 1  
**Collected:** 6/12/2021 7:04:00 AM  
**Lab ID:** 012107313-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.43	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:51

**Client Sample Description** NH-179  
 Girls Lav by Rm A-123 Sink # 2  
**Collected:** 6/12/2021 7:04:00 AM  
**Lab ID:** 012107313-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.98	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:53

**Client Sample Description** NH-180  
 Girls Lav by Rm A-123 Sink # 3  
**Collected:** 6/12/2021 7:04:00 AM  
**Lab ID:** 012107313-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.87	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:54

**Client Sample Description** NH-181  
 Girls Lav by Rm A-123 Sink # 4  
**Collected:** 6/12/2021 7:04:00 AM  
**Lab ID:** 012107313-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.89	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:55



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012107313
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** NH-182  
Boys Lav by Rm A-123 Sink # 1  
**Collected:** 6/12/2021 7:07:00 AM  
**Lab ID:** 012107313-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.69	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:56

**Client Sample Description** NH-183  
Boys Lav by Rm A-123 Sink # 2  
**Collected:** 6/12/2021 7:07:00 AM  
**Lab ID:** 012107313-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.78	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:58

**Client Sample Description** NH-184  
Boys Lav by Rm A-123 Sink # 3  
**Collected:** 6/12/2021 7:07:00 AM  
**Lab ID:** 012107313-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.42	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:59

**Client Sample Description** NH-200  
Womens Lav by C-108 Sink # 1  
**Collected:** 6/12/2021 7:12:00 AM  
**Lab ID:** 012107313-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	9.65	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:03

**Client Sample Description** NH-201  
Womens Lav by C-108 Sink # 2  
**Collected:** 6/12/2021 7:12:00 AM  
**Lab ID:** 012107313-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	13.1	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107313  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** NH-202  
 Womens Lav by C-108 Sink # 3  
**Collected:** 6/12/2021 7:12:00 AM  
**Lab ID:** 012107313-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	21.4	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:09

**Client Sample Description** NH-203  
 Room C-108 Sink # 1  
**Collected:** 6/12/2021 7:20:00 AM  
**Lab ID:** 012107313-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	24.6	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:13

**Client Sample Description** NH-204  
 Room C-108 Sink # 2  
**Collected:** 6/12/2021 7:21:00 AM  
**Lab ID:** 012107313-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	17.1	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:15

**Client Sample Description** NH-205  
 Hallway Fountain by C-108  
**Collected:** 6/12/2021 7:22:00 AM  
**Lab ID:** 012107313-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:19

**Client Sample Description** NH-206  
 Room C-107 Sink # 1  
**Collected:** 6/12/2021 7:24:00 AM  
**Lab ID:** 012107313-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.91	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:20

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107313  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** NH-207  
 Room C-107 Sink # 2  
**Collected:** 6/12/2021 7:24:00 AM  
**Lab ID:** 012107313-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.69	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:21

**Client Sample Description** NH-208  
 Room C-105 (Dark Room) Sink # 1  
**Collected:** 6/12/2021 7:27:00 AM  
**Lab ID:** 012107313-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	7.54	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:22

**Client Sample Description** NH-209  
 Room C-105 (Clay Room) Sink # 1  
**Collected:** 6/12/2021 7:31:00 AM  
**Lab ID:** 012107313-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	53.6	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:24

**Client Sample Description** NH-210  
 Room C-103 Sink # 1  
**Collected:** 6/12/2021 7:32:00 AM  
**Lab ID:** 012107313-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.40	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:25

**Client Sample Description** NH-211  
 Room C-103 Sink # 2  
**Collected:** 6/12/2021 7:32:00 AM  
**Lab ID:** 012107313-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	6.50	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107313  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** NH-212  
 Room C-102 Sink # 1  
**Collected:** 6/12/2021 7:33:00 AM  
**Lab ID:** 012107313-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	5.54	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:28

**Client Sample Description** NH-213  
 Room C-102 Sink # 2  
**Collected:** 6/12/2021 7:33:00 AM  
**Lab ID:** 012107313-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.49	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:34

**Client Sample Description** NH-214  
 Room C-101 Sink # 1  
**Collected:** 6/12/2021 7:35:00 AM  
**Lab ID:** 012107313-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	14.3	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:35

**Client Sample Description** NH-215  
 Room C-101 Sink # 2  
**Collected:** 6/12/2021 7:35:00 AM  
**Lab ID:** 012107313-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	6.96	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:37

**Client Sample Description** NH-216  
 C-162 Auto Shop Sink # 1  
**Collected:** 6/12/2021 7:37:00 AM  
**Lab ID:** 012107313-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	19.2	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:38

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012107313
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** NH-217 **Collected:** 6/12/2021 **Lab ID:** 012107313-0056  
 C-162 Auto Shop Sink # 2 7:37:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	92.2	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:39

**Definitions:**

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results