



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Keith Langlotz
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107287. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-220
 Mens Lav by C-137 Sink # 1
Collected: 6/12/2021 7:43:00 AM
Lab ID: 012107287-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.00	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:59

Client Sample Description NH-221
 Mens Lav by C-137 Sink # 2
Collected: 6/12/2021 7:43:00 AM
Lab ID: 012107287-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.98	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:03

Client Sample Description NH-222
 Womens Lav by C-137 Sink # 1
Collected: 6/12/2021 7:41:00 AM
Lab ID: 012107287-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.26	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:04

Client Sample Description NH-223
 Womens Lav by C-137 Sink # 2
Collected: 6/12/2021 7:41:00 AM
Lab ID: 012107287-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.20	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:05

Client Sample Description NH-224
 Health Office Sink # 1
Collected: 6/12/2021 7:45:00 AM
Lab ID: 012107287-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.8	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 19:36

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-225
 Health Office Sink # 2
Collected: 6/12/2021 7:45:00 AM
Lab ID: 012107287-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.1	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:06

Client Sample Description NH-226
 Health Office Bathroom Sink
Collected: 6/12/2021 6:18:00 AM
Lab ID: 012107287-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.97	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:10

Client Sample Description NH-227
 Bathroom C-122 Sink
Collected: 6/12/2021 8:09:00 AM
Lab ID: 012107287-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.10	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:12

Client Sample Description NH-229
 Mens Lav by 130 Sink # 1
Collected: 6/12/2021 6:27:00 AM
Lab ID: 012107287-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	28.0	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:13

Client Sample Description NH-230
 Mens Lav by 130 Sink # 2
Collected: 6/12/2021 6:27:00 AM
Lab ID: 012107287-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.2	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:14

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-231
 Mens Lav by 130 Sink # 3
Collected: 6/12/2021 6:27:00 AM
Lab ID: 012107287-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.7	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:16

Client Sample Description NH-232
 D-102 Bathroom Sink
Collected: 6/12/2021 6:40:00 AM
Lab ID: 012107287-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.57	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:17

Client Sample Description NH-233
 Boys Locker Room Ice Machine
Collected: 6/12/2021 6:35:00 AM
Lab ID: 012107287-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:21

Client Sample Description NH-234
 Boys Locker Rm Bathrm (Bradely) Sink # 1
Collected: 6/12/2021 6:34:00 AM
Lab ID: 012107287-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.09	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:22

Client Sample Description NH-235
 Hallwy Fountain/Boys Lock Rm
Collected: 6/12/2021 6:41:00 AM
Lab ID: 012107287-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-236
 Water Fountain Gym by D-126
Collected: 6/12/2021 6:32:00 AM
Lab ID: 012107287-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:27

Client Sample Description NH-240
 Boys Lav by D-121 Sink # 1
Collected: 6/12/2021 6:43:00 AM
Lab ID: 012107287-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.95	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:29

Client Sample Description NH-241
 Boys Lav by D-121 Sink # 2
Collected: 6/12/2021 6:43:00 AM
Lab ID: 012107287-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.82	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:30

Client Sample Description NH-242
 Girls Lav by D-121 Sink # 1
Collected: 6/12/2021 6:44:00 AM
Lab ID: 012107287-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.13	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:31

Client Sample Description NH-243
 Girls Lav by D-121 Sink # 2
Collected: 6/12/2021 6:44:00 AM
Lab ID: 012107287-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.12	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:32

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-244
 Hallway fountrn/D-123 Pool Stair
Collected: 6/12/2021 6:45:00 AM
Lab ID: 012107287-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:34

Client Sample Description NH-245
 Girl Locker Rm Bathrm (Bradley) Sink # 1
Collected: 6/12/2021 6:45:00 AM
Lab ID: 012107287-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.00	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:42

Client Sample Description NH-246
 Handicapped Locker Room Sink
Collected: 6/12/2021 6:50:00 AM
Lab ID: 012107287-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:45

Client Sample Description NH-247
 Handicap Lockr Rm Shower # 1
Collected: 6/12/2021 6:50:00 AM
Lab ID: 012107287-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.9	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:47

Client Sample Description NH-248
 Handicap Lockr Rm Shower # 2
Collected: 6/12/2021 6:50:00 AM
Lab ID: 012107287-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:48

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-249
 Girls Pool Locker Rm Bathrm Sink
Collected: 6/12/2021 6:54:00 AM
Lab ID: 012107287-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.46	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:49

Client Sample Description NH-250
 Boy Pool Locker Rm Bathrm Sink
Collected: 6/12/2021 6:54:00 AM
Lab ID: 012107287-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.27	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:51

Client Sample Description NH-252
 Mens Bathroom by 2B Sink # 1
Collected: 6/12/2021 7:44:00 AM
Lab ID: 012107287-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.1	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:52

Client Sample Description NH-253
 Mens Bathroom by 2B Sink # 2
Collected: 6/12/2021 7:44:00 AM
Lab ID: 012107287-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.32	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:53

Client Sample Description NH-254
 Mens Bathroom by 2B Sink # 3
Collected: 6/12/2021 7:44:00 AM
Lab ID: 012107287-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.71	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:57

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-255
 Womens Bathrm by 2B Sink # 1
Collected: 6/12/2021 7:45:00 AM
Lab ID: 012107287-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.67	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:59

Client Sample Description NH-256
 Womens Bathrm by 2B Sink # 2
Collected: 6/12/2021 7:45:00 AM
Lab ID: 012107287-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.20	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:00

Client Sample Description NH-257
 Womens Bathrm by 2B Sink # 3
Collected: 6/12/2021 7:45:00 AM
Lab ID: 012107287-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.52	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:04

Client Sample Description NH-258
 Womens Bathrm by 2B Sink # 4
Collected: 6/12/2021 7:45:00 AM
Lab ID: 012107287-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.90	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:05

Client Sample Description NH-259
 Library Office Sink
Collected: 6/12/2021 7:47:00 AM
Lab ID: 012107287-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.31	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-260
 Hallway Fountain by B201
Collected: 6/12/2021 7:48:00 AM
Lab ID: 012107287-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:08

Client Sample Description NH-261
 Hallway Fountain by B220
Collected: 6/12/2021 7:50:00 AM
Lab ID: 012107287-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:09

Client Sample Description NH-262
 2nd Floor Kitchen Sink # 1
Collected: 6/12/2021 7:40:00 AM
Lab ID: 012107287-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.51	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:13

Client Sample Description NH-263
 2nd Floor Kitchen Sink # 2
Collected: 6/12/2021 7:40:00 AM
Lab ID: 012107287-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:14

Client Sample Description NH-264
 2nd Floor Kitchen Sink # 3
Collected: 6/12/2021 7:40:00 AM
Lab ID: 012107287-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.01	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:15

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107287

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-265
2nd Floor Kitchen Sink # 4
Collected: 6/12/2021 7:40:00 AM
Lab ID: 012107287-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.47	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:17

Client Sample Description NH-266
Girls Lav by 2-A Sink # 1
Collected: 6/12/2021 7:30:00 AM
Lab ID: 012107287-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.03	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:22

Client Sample Description NH-267
Girls Lav by 2-A Sink # 2
Collected: 6/12/2021 7:30:00 AM
Lab ID: 012107287-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.46	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:28

Client Sample Description NH-268
Girls Lav by 2-A Sink # 3
Collected: 6/12/2021 7:30:00 AM
Lab ID: 012107287-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.19	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:30

Client Sample Description NH-269
Girls Lav by 2-A Sink # 4
Collected: 6/12/2021 7:30:00 AM
Lab ID: 012107287-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.89	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:31

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-270
 Boys Lav by 2-A Sink # 1
Collected: 6/12/2021 7:31:00 AM
Lab ID: 012107287-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.81	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:32

Client Sample Description NH-271
 Boys Lav by 2-A Sink # 2
Collected: 6/12/2021 7:31:00 AM
Lab ID: 012107287-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.58	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:34

Client Sample Description NH-272
 Boys Lav by 2-A Sink # 3
Collected: 6/12/2021 7:31:00 AM
Lab ID: 012107287-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.11	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:35

Client Sample Description NH-273
 Boys Lav by 2-A Sink # 4
Collected: 6/12/2021 7:31:00 AM
Lab ID: 012107287-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.59	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:36

Client Sample Description NH-274
 Fountain by Staff Work Rooms
Collected: 6/12/2021 7:36:00 AM
Lab ID: 012107287-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:38

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-275
 Staff Work Room Sink
Collected: 6/12/2021 7:36:00 AM
Lab ID: 012107287-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.87	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:39

Client Sample Description NH-276
 Womens Lav by A-210 Sink
Collected: 6/12/2021 7:34:00 AM
Lab ID: 012107287-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.54	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:40

Client Sample Description NH-277
 Mens Lav by A-210 Sink
Collected: 6/12/2021 7:34:00 AM
Lab ID: 012107287-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.79	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 19:38

Client Sample Description NH-278
 Hallway Fountain by A-244
Collected: 6/12/2021 7:38:00 AM
Lab ID: 012107287-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:47

Client Sample Description NH-279
 Water Fountains Outside # 1
Collected: 6/12/2021 7:05:00 AM
Lab ID: 012107287-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:48

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-281 Unisex Bathroom Sink **Collected:** 6/12/2021 7:06:00 AM **Lab ID:** 012107287-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:49

Client Sample Description NH-282 Boys Lav Sink **Collected:** 6/12/2021 7:06:00 AM **Lab ID:** 012107287-0057

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:51

Client Sample Description NH-283 Girls Lav Sink **Collected:** 6/12/2021 7:06:00 AM **Lab ID:** 012107287-0058

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:52

Client Sample Description NH-284 Sink in Concessions # 1 **Collected:** 6/12/2021 7:03:00 AM **Lab ID:** 012107287-0059

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:53

Client Sample Description NH-285 Sink in Concessions # 2 **Collected:** 6/12/2021 7:03:00 AM **Lab ID:** 012107287-0060

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:55

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-286
 Sink in Concessions # 3
Collected: 6/12/2021 7:03:00 AM
Lab ID: 012107287-0061

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.21	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:56

Client Sample Description NH-287
 Womens 1st Floor Coaches Office Bathroom Sink
Collected: 6/12/2021 7:13:00 AM
Lab ID: 012107287-0062

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	305 D	10.0 µg/L	7/13/2021 JD	7/15/2021 JW 20:30

Client Sample Description NH-288
 Accessible Bathroom Sink in Music Room
Collected: 6/12/2021 7:59:00 AM
Lab ID: 012107287-0063

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:03

Client Sample Description NH-289
 Pump Room Eye Wash
Collected: 6/12/2021 8:25:00 AM
Lab ID: 012107287-0064

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	30.4	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:08

Client Sample Description NH-290
 Dark Room Eye Wash
Collected: 6/12/2021 7:28:00 AM
Lab ID: 012107287-0065

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.35	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:12



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

EMSL Order:	012107287
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results