



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Keith Langlotz
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107279. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107279
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-172
 New Gym Foyer Boy Lav Sink # 2
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107279-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:27

Client Sample Description SH-173
 New Gym Foyer Boy Lav Sink # 3
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107279-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:29

Client Sample Description SH-174
 New Gym Foyer Boy Lav Sink # 4
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107279-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:30

Client Sample Description SH-175
 New Gym Foyer Boy Lav Sink # 5
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107279-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:32

Client Sample Description SH-176
 New Gym Foyer Boy Lav Sink # 6
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107279-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:34

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107279
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-177
 Room 134 Sink # 1
Collected: 6/12/2021 6:30:00 AM
Lab ID: 012107279-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	23.5	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:36

Client Sample Description SH-178
 Room 134 Sink # 2
Collected: 6/12/2021 6:30:00 AM
Lab ID: 012107279-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	31.3	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:38

Client Sample Description SH-179
 Room 134 Bathroom Sink
Collected: 6/12/2021 6:30:00 AM
Lab ID: 012107279-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.00	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:40

Client Sample Description SH-181
 ic Bathrm/Rm 132 Sink # 1
Collected: 6/12/2021 6:37:00 AM
Lab ID: 012107279-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.1	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:51

Client Sample Description SH-182
 Fountain in Café # 1
Collected: 6/12/2021 6:39:00 AM
Lab ID: 012107279-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:57

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107279
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-184
 Staf Unisex Bathrm/Caf Sink # 1
Collected: 6/12/2021 6:41:00 AM
Lab ID: 012107279-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.9	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:59

Client Sample Description SH-185
 Staf Unisex Bathrm/Caf Sink # 2
Collected: 6/12/2021 6:41:00 AM
Lab ID: 012107279-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.47	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:01

Client Sample Description SH-186
 Kitchen Sink # 1
Collected: 6/12/2021 6:45:00 AM
Lab ID: 012107279-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.06	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:03

Client Sample Description SH-187
 Kitchen Sink # 2
Collected: 6/12/2021 6:45:00 AM
Lab ID: 012107279-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.30	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:05

Client Sample Description SH-188
 Kitchen Sink # 3
Collected: 6/12/2021 6:45:00 AM
Lab ID: 012107279-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:07

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107279
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-189 Kitchen Sink # 4 **Collected:** 6/12/2021 6:45:00 AM **Lab ID:** 012107279-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.45	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:12

Client Sample Description SH-190 Kitchen Sink # 5 **Collected:** 6/12/2021 6:45:00 AM **Lab ID:** 012107279-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:14

Client Sample Description SH-191 Kitchen Pot Filler **Collected:** 6/12/2021 6:45:00 AM **Lab ID:** 012107279-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.72	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:16

Client Sample Description SH-192 Kitchen Locker Room Sink **Collected:** 6/12/2021 6:45:00 AM **Lab ID:** 012107279-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.35	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:18

Client Sample Description SH-193 Womens Lav by 122B Sink # 1 **Collected:** 6/12/2021 6:55:00 AM **Lab ID:** 012107279-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.90	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:24

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107279
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-194
 Womens Lav by 122B Sink # 2
Collected: 6/12/2021 6:55:00 AM
Lab ID: 012107279-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.95	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:26

Client Sample Description SH-195
 Mens Lav by 122B Sink # 1
Collected: 6/12/2021 6:55:00 AM
Lab ID: 012107279-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.25	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:27

Client Sample Description SH-197
 Girls Lab by 118 Sink # 1
Collected: 6/12/2021 7:00:00 AM
Lab ID: 012107279-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.87	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:29

Client Sample Description SH-198
 Girls Lab by 118 Sink # 2
Collected: 6/12/2021 7:00:00 AM
Lab ID: 012107279-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.75	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:35

Client Sample Description SH-199
 Boy Bathrm by Main Off Sink # 1
Collected: 6/12/2021 7:01:00 AM
Lab ID: 012107279-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.13	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:37

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107279
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-200
 Boy Bathrm by Main Off Sink # 2
Collected: 6/12/2021 7:01:00 AM
Lab ID: 012107279-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.59	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:39

Client Sample Description SH-201
 Principal Office Bathrm Sink
Collected: 6/12/2021 7:02:00 AM
Lab ID: 012107279-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.43	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:41

Client Sample Description SH-203
 Mens Lav by Room 200 Sink
Collected: 6/12/2021 7:07:00 AM
Lab ID: 012107279-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.99	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:43

Client Sample Description SH-204
 Womens Lav by Room 200 Sink
Collected: 6/12/2021 7:07:00 AM
Lab ID: 012107279-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.98	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:50

Client Sample Description SH-205
 Room 200 Sink
Collected: 6/12/2021 7:10:00 AM
Lab ID: 012107279-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.22	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:00

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107279
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-207
 Boys Lav by Room 204 Sink # 1
Collected: 6/12/2021 7:11:00 AM
Lab ID: 012107279-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.18	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:02

Client Sample Description SH-208
 Boys Lav by Room 204 Sink # 2
Collected: 6/12/2021 7:11:00 AM
Lab ID: 012107279-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.49	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:04

Client Sample Description SH-209
 Hallway fountain by Room 218
Collected: 6/12/2021 7:12:00 AM
Lab ID: 012107279-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:05

Client Sample Description SH-210
 Room 220 Sink
Collected: 6/12/2021 7:14:00 AM
Lab ID: 012107279-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.49	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:07

Client Sample Description SH-211
 Room 226 Sink
Collected: 6/12/2021 7:12:00 AM
Lab ID: 012107279-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.80	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:09

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107279
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-213 Unisex Bathrm Sink by Rm 230 **Collected:** 6/12/2021 7:16:00 AM **Lab ID:** 012107279-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.07	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:11

Client Sample Description SH-214 Library Sink **Collected:** 6/12/2021 7:20:00 AM **Lab ID:** 012107279-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.65	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:13

Client Sample Description SH-215 Hallway Fountain near Library **Collected:** 6/12/2021 7:20:00 AM **Lab ID:** 012107279-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:15

Client Sample Description SH-216 Womens Lav by Library Sink **Collected:** 6/12/2021 7:24:00 AM **Lab ID:** 012107279-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.97	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:21

Client Sample Description SH-217 Library Storeroom Sink **Collected:** 6/12/2021 7:25:00 AM **Lab ID:** 012107279-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.6	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012107279
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-218
 Room 223 IMC Sink
Collected: 6/12/2021 7:28:00 AM
Lab ID: 012107279-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.10	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:28

Client Sample Description SH-219
 Boys Lav by Room 207 Sink # 1
Collected: 6/12/2021 7:35:00 AM
Lab ID: 012107279-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.06	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:30

Client Sample Description SH-220
 Boys Lav by Room 207 Sink # 2
Collected: 6/12/2021 6:35:00 AM
Lab ID: 012107279-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.09	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:32

Client Sample Description SH-221
 Hallway Fountain by 221
Collected: 6/12/2021 6:31:00 AM
Lab ID: 012107279-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:34

Client Sample Description SH-222
 Girl Handi lav by 219 Sink # 1
Collected: 6/12/2021 6:33:00 AM
Lab ID: 012107279-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.12	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:36

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107279

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860

Fax:

Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-223 **Collected:** 6/12/2021 **Lab ID:** 012107279-0046
 Girl Handi lav by 219 Sink # 2 6:35:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.09	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:38

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results