



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

7/19/2021

Phone: (716) 626-8860  
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

**2021 Lead in Water Testing**

The reference number for these samples is EMSL Order #012107292. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107292  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** Trans-100  
 Eye Wash Bay #1  
**Collected:** 6/5/2021 6:25:00 AM  
**Lab ID:** 012107292-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 00:37

**Client Sample Description** Trans-101  
 Drinking Fountain Bay #1  
**Collected:** 6/5/2021 6:23:00 AM  
**Lab ID:** 012107292-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 00:40

**Client Sample Description** Trans-102  
 Bay #1 Sink  
**Collected:** 6/5/2021 6:19:00 AM  
**Lab ID:** 012107292-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 00:43

**Client Sample Description** Trans-103  
 Mens Mechanics Bathroom Sink  
**Collected:** 6/5/2021 6:24:00 AM  
**Lab ID:** 012107292-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 00:51

**Client Sample Description** Trans-104  
 Mens Staff Bathroom Sink#1  
**Collected:** 6/5/2021 6:20:00 AM  
**Lab ID:** 012107292-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.27	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 00:53

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107292  
 CustomerID: WCSD21A  
 CustomerPO: 20-04919  
 ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860  
 Fax:  
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** Trans-105  
 Mens Staff Bathroom Sink #2  
**Collected:** 6/5/2021 6:17:00 AM  
**Lab ID:** 012107292-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 01:01

**Client Sample Description** Trans-106  
 Womens Staff Bathroom Sink #1  
**Collected:** 6/5/2021 6:22:00 AM  
**Lab ID:** 012107292-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.23	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 01:04

**Client Sample Description** Trans-107  
 Womens Staff Bathroom Sink #2  
**Collected:** 6/5/2021 6:18:00 AM  
**Lab ID:** 012107292-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	17.1	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 01:07

**Client Sample Description** Trans-108  
 Womens Staff Bathroom Sink #3  
**Collected:** 6/5/2021 6:16:00 AM  
**Lab ID:** 012107292-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 01:09

**Client Sample Description** Trans-109  
 Supervisors Bathroom Sink  
**Collected:** 6/5/2021 6:21:00 AM  
**Lab ID:** 012107292-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 01:12

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012107292

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**  
**Williamsville CSD - Facilities Dept**  
**480 Lawrence Bell Dr.**  
**Williamsville, NY 14221**

Phone: (716) 626-8860

Fax:

Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

**Analytical Results**

**Client Sample Description** Trans-110  
Break Room Sink  
**Collected:** 6/5/2021  
6:04:00 AM  
**Lab ID:** 012107292-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:39

**Client Sample Description** Trans-111  
Mechanics Break Room Sink  
**Collected:** 6/5/2021  
6:15:00 AM  
**Lab ID:** 012107292-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.51	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:43

**Definitions:**

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results