

Williamsville Central School District  
 New York State Public School District  
 Water Testing for Lead Report (5/27/2021)

School	Number of Samples Tested (1)	Number of above 15ppb	Location of Samples Tested above 15ppb												Received All Results Yes - No
			Drinking Fountains	Student Lavatories	Classroom Faucets	Classroom Fountains	Science-Tech Classroom	Student-staff Showers/ Locker rooms	Office Sinks	Staff Lavatories	Custodial Outlets	Child Nutrition Faucets	Pool Faucets	Outdoor Faucets	
Country Parkway	81	15	0	0	0	0	0	0	1	1	0	0	NA	NA	Yes
Dodge	91	4	0	2	0	0	0	0	0	0	2	0	NA	NA	Yes
Forest	93	8	0	2	5	0	0	0	1	0	0	0	NA	NA	Yes
Heim	78	2	0	0	2	0	0	0	0	0	0	0	NA	NA	Yes
Maple East	96	7	0	0	3	0	0	1	1	0	2	0	NA	NA	Yes
Maple West	82	8	0	0	4	0	0	0	1	0	2	1	NA	NA	Yes
Casey middle	94	7	0	0	4	0	0	1	1	1	0	0	NA	NA	Yes
Heim middle	83	8	0	1	3	0	1	0	0	1	1	1	NA	NA	Yes
Mill middle	98	34	1	8	20	0	0	3	1	1	0	0	NA	NA	Yes
Transit middle	118	23	0	0	21	0	0	1	0	0	1	0	NA	NA	Yes
East high	101	21	0	0	14	0	1	1	2	1	2	0	NA	NA	Yes
North high	121	14	0	0	3	0	0	2	6	2	1	0	NA	NA	Yes
South high	110	9	0	0	8	0	0	1	0	0	0	0	NA	NA	Yes
AIM building	5	0	0	0	0	0	0	0	0	0	0	0	NA	NA	Yes
Transportation	12	1	0	0	0	0	0	0	0	1	0	0	NA	NA	Yes
Lawrence Bell Dr.	16	0	0	0	0	0	0	0	0	0	0	0	NA	NA	Yes
District office	12	0	0	0	0	0	0	0	0	0	0	0	NA	NA	Yes
<b>Total Samples</b>	<b>1291</b>	<b>161</b>	<b>1</b>	<b>13</b>	<b>87</b>	<b>0</b>	<b>2</b>	<b>10</b>	<b>14</b>	<b>8</b>	<b>11</b>	<b>2</b>	<b>0</b>	<b>0</b>	
														<b>148</b>	

(1) New York State water testing parameters for lead require all water outlets to be tested after water has been stagnant in the water pipes and faucets for a minimum of eight hours. Flushing water through the water outlet is not permitted per the test