

Important Information about your Drinking Water

Levels of Gross Alpha, Excl. R & U in Winneconne Waterworks water exceed standard

Water samples collected to determine compliance with the Gross Alpha, Excl. R & U Maximum Contaminant Level (MCL) of 15 PCI/L indicate our drinking water exceeds the MCL, which is a violation of State and Federal Safe Drinking Water standards. Samples collected on the following dates with the following results were used in making this determination:

December 17th, 2020 – 15.8 PCI/L
February 4th, 2021 – 8.97 PCI/L
June 2, 2021 – 16.87 PCI/L
July 12, 2021 – 21.93 PCI/L

What precautions should be taken at this time?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. However, you should be aware of the following:
Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

What is being done to correct the problem?

Corrective action(s) taken: A Preliminary Engineering Report evaluating alternatives to address Gross Alpha was previously completed and submitted to DNR. A pilot study of reverse osmosis (RO) treatment for Gross Alpha removal followed, and the Reverse Osmosis Pilot Study Report has been approved by DNR. McMahon Associates, Inc. is currently under Agreement with the Village for design of proposed improvements to the Well 2 Facility incorporating new RO treatment for both the Well #1 and Well #2 supplies.

We are working to resolve this problem as soon as possible. We will notify you when the problem is resolved.

If you have questions regarding the safety of our drinking water, please contact:

Eric Voigt (Midwest Contract Operations)

920-582-4381

Name of Responsible Person

Area Code-Telephone Number

30 South 1st St. Winneconne, WI 54986

Street Address

City

State

Zip

I certify that the information and statements contained in this public notice are true and correct and have been provided to consumers in accordance with the delivery, content, format, and deadline requirements in Subchapter VII of ch. NR 809, Wis. Adm. Code.

X *Eric Voigt*

Signature

8/24/2021

Date

Tier 2 Notice