

Notice is hereby given pursuant of s. NR 210.21 (5) that the Village of Winneconne Wastewater Treatment Facility experienced a treatment facility overflow (TFO) event from 12:50 am on July 15, 2021 until 12:51 am on July 15, 2021. Water overflowed the aerated grit chamber and was contained to the treatment facility grounds.

The TFO is the result of excessive precipitation on already saturated ground which in-flowed and infiltrated into the sanitary collection sewer system. Village staff responded to the high flow conditions which mitigated the impacts to public health, the environment, and property. The TFO event was reported to the Wisconsin Department of Natural Resources pursuant of NR 210.21 (4).

Published by the authority of the Village of Winneconne.