

*Town of Yarmouth,
Maine*

Incorporated 1849
*YARMOUTH FIRE RESCUE
178 NORTH ROAD
YARMOUTH, MAINE 04096*



MICHAEL ROBITAILLE, CHIEF OF DEPARTMENT

BILL GODDARD, DEPUTY CHIEF

TO: Erin Zwirko, Town Planner
CC: Nicholas Ciarimboli, Code Enforcement Officer
Subject: 53 West Elm Street

On April 7, 2024, I reviewed the application submitted by Janice Cooper for the Minor Site plan for an ADU located at 53 West Elm Street, Yarmouth. The following is required based on National Fire Protection Standards and local municipal ordinances.

- Interconnect smoke detectors are required.
- Carbon Monoxide detectors are required to be installed.
- House numbers are required and must be visible from the road if within 50 feet of road. If the home is greater than 50 feet, the applicant will be required to have 4" numbers at the entryway of the road.

Sincerely,

Michael Robitaille

Michael Robitaille
Fire Chief